

BALTASOUND, United KingdomWMO: **030020**Lat: **60.7483N**Lon: **0.8556W**Elev: **49**StdP: **14.67**Time Zone: **0.00 (EUW)**Period: **94-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	27.3	29.8	21.2	16.0	32.8	23.5	17.8	34.4	44.3	39.4	41.5	40.1	9.3	330	0.848

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	8.0	62.7	58.4	60.8	57.2	59.3	56.2	59.6	61.7	58.2	60.0	56.9	58.5	12.5	140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
58.5	73.2	60.6	57.1	69.8	59.1	56.0	66.9	58.0	26.1	61.9	25.2	60.1	24.5	58.7	66.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 38.8	33.7	30.3	21.8	67.0	3.9	3.1	19.0	69.3	16.7	71.1	14.5	72.8	11.6	75.1		
(5)			21.8	61.4	4.1	1.9	18.8	62.8	16.4	64.0	14.1	65.0	11.1	66.4		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	46.2	40.1	39.4	40.6	43.4	46.6	50.8	54.5	54.9	52.3	47.6	43.3	40.7
	DBStd	6.82	4.18	4.73	4.43	4.09	3.82	3.10	3.00	2.96	3.36	4.14	4.49	5.14
	HDD50	1850	307	297	292	200	117	27	2	2	17	96	203	290
	HDD65	6862	772	717	757	649	570	427	326	314	382	541	652	755
	CDD50	462	0	0	0	1	11	50	141	153	85	20	1	0
	CDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH74	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0
	WSAvg	15.4	18.8	17.8	17.3	15.2	13.6	12.9	11.6	11.8	14.4	16.7	17.4	17.3
	PrecAvg	47.6	5.4	3.7	4.6	3.0	2.2	2.3	2.3	3.0	4.5	5.2	5.7	5.6
(15) Precipitation	PrecMax	61.3	9.0	7.8	8.3	5.6	4.4	4.7	4.7	5.4	8.8	10.8	10.4	10.9
	PrecMin	38.4	1.7	1.1	1.2	0.2	0.6	0.2	0.9	0.6	1.1	2.4	1.8	3.1
	PrecStd	5.6	1.9	1.7	1.5	1.2	1.0	1.0	0.9	1.2	1.7	1.8	1.8	1.9
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	50.0	50.2	51.1	55.2	60.0	63.1	66.2	66.0	61.6	56.7	53.2	51.8
		MCWB	48.2	48.9	47.3	50.1	54.5	57.1	61.0	61.0	57.1	54.0	51.2	50.3
	2%	DB	48.5	49.0	49.2	52.4	56.0	59.0	62.9	62.4	59.3	55.3	51.8	50.4
		MCWB	46.9	47.6	46.4	48.4	51.3	54.4	59.0	58.4	55.9	53.1	50.4	48.9
	5%	DB	47.4	47.6	48.0	50.7	53.9	56.9	60.8	60.8	58.1	54.1	50.8	49.2
		MCWB	45.8	46.0	45.6	47.4	50.0	52.9	57.4	57.5	55.3	52.0	49.3	47.7
	10%	DB	46.3	46.2	46.8	49.2	52.2	55.4	59.2	59.4	57.0	53.2	49.8	47.9
		MCWB	44.6	44.5	44.4	46.4	48.9	52.2	56.2	56.5	54.8	51.1	48.2	46.3
	0.4%	WB	48.9	49.6	48.6	51.3	55.1	58.0	62.0	61.4	58.4	55.1	52.2	50.8
		MCDB	49.4	49.9	50.1	53.6	59.4	62.0	64.7	64.3	60.2	56.0	52.7	51.3
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	47.4	48.0	47.3	49.3	52.2	55.2	59.8	59.7	57.1	53.7	50.8	49.4
		MCDB	48.3	48.8	48.6	51.3	54.7	57.9	62.0	61.8	58.3	54.7	51.5	50.1
	5%	WB	46.0	46.4	46.1	48.1	50.8	53.9	58.2	58.4	56.1	52.7	49.5	48.0
		MCDB	47.0	47.4	47.6	50.1	53.0	55.9	60.0	60.0	57.4	53.8	50.5	49.0
	10%	WB	44.8	44.7	44.8	46.9	49.6	52.8	56.8	57.1	55.2	51.7	48.4	46.5
		MCDB	46.1	46.0	46.4	48.8	51.7	54.7	58.5	58.6	56.6	52.9	49.6	47.8
(35) Mean Daily Temperature Range	5% DB	MDBR	6.6	7.1	7.7	8.4	9.0	7.8	7.6	8.0	7.4	7.2	6.8	7.0
		MCDBR	7.2	7.1	8.1	9.6	10.5	9.6	9.5	9.1	8.3	7.1	6.8	7.1
		MCWBR	7.3	7.0	7.0	6.8	7.1	6.7	6.3	6.3	6.2	6.4	7.4	7.7
	5% WB	MCDBR	7.4	7.1	7.6	8.9	9.6	8.5	8.8	8.6	7.2	6.5	6.8	7.1
		MCWBR	7.7	7.4	7.1	7.0	7.0	6.4	6.5	6.6	6.1	6.5	7.6	7.8
(40) Clear-Sky Solar Irradiance	taub		0.333	0.355	0.368	0.381	0.372	0.365	0.379	0.366	0.363	0.346	0.325	0.400
	taud		2.073	2.194	2.271	2.306	2.398	2.458	2.437	2.473	2.437	2.315	2.129	2.355
	Ebn at Noon		115	192	236	257	270	274	267	261	239	195	118	74
	Edh at Noon		15	23	29	34	33	32	32	29	25	20	13	10
(44) All-Sky Solar Radiation	RadAvg		68	223	564	1060	1481	1533	1381	1126	679	337	99	42
	RadStd		6	24	43	62	100	167	121	108	62	35	10	3

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47) Regional (21 neighbors)		N/A	+1.17	+1.12	N/A	N/A	N/A	-184	-241	N/A	N/A	

Nomenclature: See separate page