

BALTASOUND, United KingdomWMO: **030020**Lat: **60.7483N**Lon: **0.8556W**Elev: **15**StdP: **101.14**Time Zone: **0.00 (EUW)**Period: **94-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-2.6	-1.2	-6.0	2.3	0.4	-4.7	2.5	1.3	19.8	4.1	18.5	4.5	4.1	330	0.848

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	4.5	17.1	14.7	16.0	14.0	15.2	13.4	15.3	16.5	14.5	15.5	13.9	14.7	5.6	140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
14.7	10.5	15.9	14.0	10.0	15.0	13.3	9.6	14.4	42.9	16.6	40.8	15.6	39.0	14.8	19.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 17.3	15.1	13.5	DB	-5.7	19.5	2.2	1.7	-7.2	20.7	-8.5	21.7	-9.7	22.7	-11.3	23.9	
(5)			WB	-5.7	16.4	2.3	1.1	-7.3	17.1	-8.7	17.8	-9.9	18.4	-11.6	19.1	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	7.9	4.5	4.1	4.8	6.3	8.1	10.4	12.5	12.7	11.3	8.6	6.3	4.8
	DBStd	3.79	2.32	2.63	2.46	2.27	2.12	1.72	1.67	1.64	1.87	2.30	2.50	2.85
	HDD10.0	1028	171	165	162	111	65	15	1	1	9	53	113	161
	HDD18.3	3812	429	398	421	361	317	237	181	174	212	301	362	419
	CDD10.0	257	0	0	0	1	6	28	78	85	47	11	1	0
	CDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH23.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH27.7	0	0	0	0	0	0	0	0	0	0	0	0	0
(14) Wind	WSAvg	6.9	8.4	8.0	7.8	6.8	6.1	5.8	5.2	5.3	6.4	7.5	7.8	7.8
(15) Precipitation	PrecAvg	1210	137	95	118	75	56	58	59	76	115	132	144	143
	PrecMax	1558	228	199	211	143	112	119	120	138	223	275	265	277
	PrecMin	976	43	29	31	4	14	6	22	16	29	60	45	80
	PrecStd	142	48	42	39	30	25	25	23	31	42	46	45	47
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	10.0	10.1	10.6	12.9	15.6	17.3	19.0	18.9	16.4	13.7	11.8	11.0
		MCWB	9.0	9.4	8.5	10.1	12.5	13.9	16.1	16.1	14.0	12.2	10.7	10.1
	2%	DB	9.2	9.4	9.6	11.3	13.3	15.0	17.1	16.9	15.2	12.9	11.0	10.2
		MCWB	8.3	8.7	8.0	9.1	10.7	12.4	15.0	14.7	13.3	11.7	10.2	9.4
	5%	DB	8.6	8.7	8.9	10.4	12.2	13.8	16.0	16.0	14.5	12.3	10.4	9.6
		MCWB	7.6	7.8	7.6	8.6	10.0	11.6	14.1	14.2	13.0	11.1	9.6	8.7
	10%	DB	7.9	7.9	8.2	9.5	11.2	13.0	15.1	15.2	13.9	11.8	9.9	8.9
		MCWB	7.0	6.9	6.9	8.0	9.4	11.2	13.5	13.6	12.6	10.6	9.0	8.0
	0.4%	WB	9.4	9.8	9.2	10.7	12.8	14.4	16.7	16.3	14.7	12.8	11.2	10.4
		MCDB	9.7	9.9	10.0	12.0	15.2	16.7	18.2	18.0	15.6	13.3	11.5	10.7
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	8.6	8.9	8.5	9.6	11.2	12.9	15.5	15.4	13.9	12.1	10.5	9.7
		MCDB	9.0	9.3	9.2	10.7	12.6	14.4	16.6	16.6	14.6	12.6	10.8	10.1
	5%	WB	7.8	8.0	7.8	8.9	10.5	12.1	14.6	14.6	13.4	11.5	9.7	8.9
		MCDB	8.4	8.5	8.7	10.0	11.7	13.3	15.6	15.6	14.1	12.1	10.3	9.5
	10%	WB	7.1	7.1	7.1	8.3	9.8	11.6	13.8	14.0	12.9	10.9	9.1	8.1
		MCDB	7.8	7.8	8.0	9.3	10.9	12.6	14.7	14.8	13.7	11.6	9.8	8.8
	5% DB	MDBR	3.7	3.9	4.3	4.7	5.0	4.3	4.2	4.5	4.1	4.0	3.8	3.9
		MCDBR	4.0	3.9	4.5	5.3	5.9	5.3	5.3	5.1	4.6	3.9	3.8	3.9
		MCWBR	4.1	3.9	3.9	3.8	4.0	3.7	3.5	3.5	3.5	3.6	4.1	4.3
		MCWBR	4.1	4.0	4.2	4.9	5.3	4.7	4.9	4.8	4.0	3.6	3.8	3.9
(35) Mean Daily Temperature Range	5% WB	MCWBR	4.3	4.1	4.0	3.9	3.9	3.5	3.6	3.7	3.4	3.6	4.2	4.3
		MCWBR	4.3	4.1	4.0	3.9	3.9	3.5	3.6	3.7	3.4	3.6	4.2	4.3
	Clear-Sky Solar Irradiance	taub	0.333	0.355	0.368	0.381	0.372	0.365	0.379	0.366	0.363	0.346	0.325	0.400
		taud	2.073	2.194	2.271	2.306	2.398	2.458	2.437	2.473	2.437	2.315	2.129	2.355
(42) All-Sky Solar Radiation	RadAvg	Ebn at Noon	363	604	743	811	852	865	841	824	753	616	371	234
		Edh at Noon	46	73	92	106	104	100	100	90	78	63	42	30
(44) All-Sky Solar Radiation	RadAvg	0.21	0.70	1.78	3.34	4.67	4.83	4.36	3.55	2.14	1.06	0.31	0.13	
(45) All-Sky Solar Radiation	RadStd	0.02	0.08	0.14	0.20	0.31	0.53	0.38	0.34	0.20	0.11	0.03	0.01	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (21 neighbors)	N/A	+0.65	+0.62	N/A	N/A	N/A	-102	-134	N/A	N/A