

SELLA NESS, United Kingdom

WMO: 030060

Lat: 60.450N

Lon: 1.267W

Elev: 23

StdP: 14.68

Time Zone: 0.00 (EUW)

Period: 94-04

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	29.0	30.9	21.6	16.2	34.7	23.4	17.7	35.8	49.1	40.2	46.1	42.1	10.7	320	0.876

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	6.9	65.2	59.8	62.5	58.2	60.3	56.8	60.9	64.3	59.1	61.7	57.5	59.5	13.7	150

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
59.2	75.1	62.6	57.5	70.7	60.5	56.3	67.5	58.9	27.0	64.7	25.8	61.8	24.7	59.6	68.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 41.5	36.4	32.7	DB	24.9	69.4	3.5	3.9	22.5	72.2	20.4	74.5	18.5	76.6	16.0	79.4	(4)
(5)			WB	23.2	63.1	2.8	2.8	21.1	65.1	19.5	66.8	17.9	68.4	15.9	70.4	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	46.5	40.5	39.3	40.6	43.1	46.6	50.7	54.5	55.9	52.7	48.1	44.2	40.6	(6)	
	DBStd	6.88	3.86	4.35	4.05	3.91	3.71	3.32	3.53	3.63	3.40	4.02	4.09	4.89	(7)	
	HDD50	1807	294	299	291	208	116	31	3	1	14	82	176	292	(8)	
	HDD65	6772	759	719	756	656	569	429	326	284	369	523	625	757	(9)	
	CDD50	511	0	0	0	2	12	52	142	182	95	24	2	0	(10)	
	CDD65	0	0	0	0	0	0	0	0	0	0	0	0	0	(11)	
	CDH74	0	0	0	0	0	0	0	0	0	0	0	0	0	(12)	
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0	(13)	
(14) Wind	WSAvg	16.1	18.0	19.9	18.3	16.1	14.4	14.9	12.9	12.6	15.0	17.8	17.9	16.2	(14)	
(15) Precipitation	PrecAvg	46.0	5.8	4.5	4.2	2.5	2.4	2.2	2.4	3.3	3.7	4.6	5.1	5.4	(15)	
	PrecMax	55.7	11.3	7.0	7.6	4.3	5.0	4.2	5.1	6.5	5.5	7.0	7.8	9.4	(16)	
	PrecMin	38.7	1.9	2.0	1.4	0.9	0.4	0.4	0.9	1.5	1.1	1.9	2.2	2.1	(17)	
	PrecStd	4.7	2.1	1.3	1.2	0.7	1.0	1.0	1.0	1.2	1.1	1.3	1.3	1.5	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	49.5	49.6	50.4	57.8	60.7	64.1	68.0	70.4	64.0	58.3	53.9	51.2	(19)	
		MCWB	47.2	47.6	45.9	51.3	52.5	55.3	62.4	62.0	58.9	54.7	51.5	49.0	(20)	
	2%	DB	48.2	48.6	48.5	52.0	55.6	59.4	64.3	66.6	60.1	55.6	52.1	50.1	(21)	
		MCWB	46.1	47.0	45.5	47.5	50.5	53.7	59.4	61.1	56.2	53.1	50.0	48.3	(22)	
	5%	DB	47.3	47.2	47.5	49.8	53.3	57.1	61.7	63.3	58.6	54.5	50.8	49.1	(23)	
		MCWB	45.4	45.4	44.9	46.6	49.5	53.0	57.8	59.5	55.5	52.2	48.9	47.3	(24)	
	10%	DB	46.4	45.7	46.4	48.4	51.8	55.4	59.6	60.9	57.3	53.5	49.9	47.7	(25)	
		MCWB	44.6	43.6	44.2	45.8	48.6	52.2	56.4	57.9	54.9	51.3	48.1	45.7	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	48.0	48.6	47.6	51.5	54.0	56.5	63.1	63.0	59.3	55.4	52.1	49.9	(27)	
		MCDB	48.8	49.2	48.6	57.5	58.3	60.4	67.3	67.1	61.8	57.1	53.3	50.4	(28)	
	2%	WB	46.7	47.3	46.5	48.6	51.4	54.8	60.3	61.5	57.3	53.9	50.4	48.8	(29)	
		MCDB	47.7	48.2	47.7	50.6	54.0	57.9	63.2	65.4	58.9	55.1	51.4	49.8	(30)	
	5%	WB	45.7	45.6	45.6	47.6	50.3	53.8	58.6	59.9	56.3	52.8	49.5	47.6	(31)	
		MCDB	47.0	46.9	47.1	49.1	52.5	56.3	61.0	63.1	57.8	54.1	50.5	48.9	(32)	
	10%	WB	44.7	44.0	44.4	46.3	49.2	52.8	56.9	58.3	55.3	51.7	48.4	46.0	(33)	
		MCDB	46.2	45.6	46.3	47.8	51.4	55.0	59.0	60.6	56.8	53.2	49.8	47.5	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	5.8	6.6	6.5	7.2	7.4	6.6	6.6	6.9	6.0	6.0	6.0	6.3	(35)	
		MCDBR	5.9	6.8	6.8	8.9	9.4	9.2	10.7	11.1	8.2	6.3	6.3	5.5	(36)	
	5% WB	MCWBR	6.0	6.8	6.0	5.9	5.9	5.6	6.6	6.7	5.5	5.8	6.7	6.1	(37)	
		MCWBR	6.0	6.8	6.5	8.0	8.7	8.1	10.2	10.5	6.9	6.1	6.6	5.6	(38)	
(40) Clear-Sky Solar Irradiance	taub	taub	0.337	0.356	0.370	0.384	0.374	0.367	0.381	0.368	0.364	0.348	0.331	0.412	(40)	
		taud	2.077	2.194	2.266	2.292	2.390	2.451	2.428	2.466	2.433	2.315	2.132	2.385	(41)	
	Ebn at Noon	Ebn at Noon	118	193	236	257	270	274	266	261	239	196	120	78	(42)	
		Edh at Noon	15	23	30	34	33	32	32	29	25	20	14	10	(43)	
(44) All-Sky Solar Radiation	RadAvg	RadAvg	71	229	571	1064	1485	1538	1388	1128	683	342	104	45	(44)	
	RadStd	RadStd	7	26	40	63	92	164	121	108	62	35	10	3	(45)	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (20 neighbors)	+0.61	+0.90	+1.30	N/A	N/A	N/A	-167	-221	N/A	N/A

Nomenclature: See separate page