

SELLA NESS, United Kingdom

WMO: 030060

Lat: 60.450N

Lon: 1.267W

Elev: 7

StdP: 101.24

Time Zone: 0.00 (EUW)

Period: 94-04

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-1.7	-0.6	-5.8	2.3	1.5	-4.8	2.5	2.1	22.0	4.6	20.6	5.6	4.8	320	0.876

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	3.9	18.4	15.5	17.0	14.6	15.7	13.8	16.1	18.0	15.0	16.5	14.2	15.3	6.1	150

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
15.1	10.7	17.0	14.2	10.1	15.8	13.5	9.6	14.9	45.0	18.1	42.1	16.5	39.7	15.3	20.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 18.6	16.3	14.6	DB	-3.9	20.8	1.9	2.1	-5.3	22.3	-6.4	23.6	-7.5	24.8	-8.9	26.3	(4)
(5)			WB	-4.9	17.3	1.6	1.6	-6.0	18.4	-7.0	19.3	-7.8	20.2	-9.0	21.3	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	8.0	4.7	4.1	4.8	6.2	8.1	10.4	12.5	13.3	11.5	9.0	6.8	4.8	(6)	
	DBStd	3.82	2.15	2.41	2.25	2.17	2.06	1.84	1.96	2.02	1.89	2.23	2.27	2.72	(7)	
	HDD10.0	1004	163	166	162	116	64	17	2	1	8	46	98	162	(8)	
	HDD18.3	3762	422	399	420	364	316	238	181	158	205	291	347	421	(9)	
	CDD10.0	284	0	0	0	1	7	29	79	101	53	13	1	0	(10)	
	CDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0	(11)	
	CDH23.3	0	0	0	0	0	0	0	0	0	0	0	0	0	(12)	
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0	(13)	
	Wind	WSAvg	7.2	8.0	8.9	8.2	7.2	6.4	6.6	5.8	5.7	6.7	7.9	8.0	7.2	(14)
(15) Precipitation	PrecAvg	1169	147	115	106	64	60	57	60	83	93	117	130	136	(15)	
	PrecMax	1416	287	179	194	109	127	106	130	166	140	177	197	240	(16)	
	PrecMin	983	48	51	36	22	10	11	22	38	29	47	56	54	(17)	
	PrecStd	120	54	32	30	19	25	25	25	30	28	33	33	39	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	9.7	9.8	10.2	14.3	15.9	17.8	20.0	21.3	17.8	14.6	12.2	10.6	(19)	
		MCWB	8.5	8.7	7.7	10.7	11.4	12.9	16.9	16.7	14.9	12.6	10.8	9.4	(20)	
	2%	DB	9.0	9.2	9.2	11.1	13.1	15.2	17.9	19.2	15.6	13.1	11.2	10.1	(21)	
		MCWB	7.8	8.3	7.5	8.6	10.3	12.1	15.2	16.2	13.5	11.7	10.0	9.1	(22)	
	5%	DB	8.5	8.4	8.6	9.9	11.8	14.0	16.5	17.4	14.8	12.5	10.5	9.5	(23)	
		MCWB	7.4	7.4	7.2	8.1	9.7	11.7	14.4	15.3	13.0	11.2	9.4	8.5	(24)	
	10%	DB	8.0	7.6	8.0	9.1	11.0	13.0	15.3	16.1	14.0	11.9	9.9	8.7	(25)	
		MCWB	7.0	6.4	6.8	7.7	9.2	11.2	13.6	14.4	12.7	10.7	8.9	7.6	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	8.9	9.2	8.7	10.8	12.2	13.6	17.3	17.2	15.2	13.0	11.2	10.0	(27)	
		MCDB	9.3	9.5	9.2	14.2	14.6	15.8	19.6	19.5	16.6	13.9	11.8	10.2	(28)	
	2%	WB	8.2	8.5	8.0	9.2	10.8	12.7	15.7	16.4	14.1	12.2	10.2	9.3	(29)	
		MCDB	8.7	9.0	8.7	10.3	12.2	14.4	17.3	18.5	14.9	12.9	10.8	9.9	(30)	
	5%	WB	7.6	7.5	7.5	8.7	10.1	12.1	14.8	15.5	13.5	11.6	9.7	8.7	(31)	
		MCDB	8.3	8.3	8.4	9.5	11.4	13.5	16.1	17.3	14.3	12.3	10.3	9.4	(32)	
	10%	WB	7.0	6.6	6.9	8.0	9.5	11.5	13.8	14.6	12.9	11.0	9.1	7.8	(33)	
		MCDB	7.9	7.6	8.0	8.8	10.8	12.8	15.0	15.9	13.8	11.8	9.9	8.6	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	3.2	3.7	3.6	4.0	4.1	3.6	3.7	3.9	3.3	3.4	3.3	3.5	(35)	
		MCDBR	3.3	3.8	3.8	4.9	5.2	5.1	6.0	6.2	4.5	3.5	3.5	3.1	(36)	
	5% WB	MCWBR	3.3	3.8	3.3	3.3	3.3	3.1	3.7	3.7	3.1	3.2	3.7	3.4	(37)	
		MCWBR	3.3	3.8	3.6	4.4	4.8	4.5	5.6	5.8	3.8	3.4	3.7	3.1	(38)	
(40) Clear-Sky Solar Irradiance	taub	taub	0.337	0.356	0.370	0.384	0.374	0.367	0.381	0.368	0.364	0.348	0.331	0.412	(40)	
		taud	2.077	2.194	2.266	2.292	2.390	2.451	2.428	2.466	2.433	2.315	2.132	2.385	(41)	
	Edn at Noon	Edn at Noon	371	608	743	809	851	864	840	824	754	619	377	245	(42)	
		Edh at Noon	47	74	93	108	105	101	101	90	79	64	43	32	(43)	
(44) All-Sky Solar Radiation	RadAvg	RadAvg	0.23	0.72	1.80	3.35	4.68	4.85	4.38	3.56	2.15	1.08	0.33	0.14	(44)	
	RadStd	RadStd	0.02	0.08	0.13	0.20	0.29	0.52	0.38	0.34	0.20	0.11	0.03	0.01	(45)	

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47) Regional (20 neighbors)		+0.34	+0.50	+0.72	N/A	N/A	N/A	-93	-123	N/A	N/A	

Nomenclature: See separate page