

SULE SKERRY, United Kingdom

WMO: 030100

Lat: 59.084N

Lon: 4.407W

Elev: 12

StdP: 101.18

Time Zone: 0.00 (EUW)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	1.6	2.5	-3.3	2.9	3.6	-2.2	3.1	3.8	23.4	6.0	21.9	6.3	9.9	230	0.926

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	1.9	16.7	15.3	15.8	14.7	15.0	14.0	15.7	16.5	15.1	15.8	14.4	15.1	6.6	140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
15.2	10.8	16.2	14.6	10.4	15.5	14.1	10.0	14.9	44.1	16.6	42.2	15.9	40.5	15.1	20.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 20.4	18.5	16.4	DB	0.0	17.9	1.6	1.9	-1.1	19.3	-2.0	20.4	-2.9	21.4	-4.0	22.8	(4)
(5)			WB	-1.6	17.2	1.2	1.9	-2.4	18.6	-3.2	19.7	-3.8	20.7	-4.7	22.1	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	9.4	6.6	6.0	6.5	7.6	9.0	11.0	12.8	13.4	12.6	10.8	8.7	7.2	(6)	
	DBStd	3.07	1.72	1.82	1.96	1.67	1.64	1.32	1.36	1.31	1.49	1.67	2.08	2.07	(7)	
	HDD10.0	589	105	111	109	72	39	5	0	0	1	12	47	88	(8)	
	HDD18.3	3270	363	344	368	321	290	221	171	152	173	234	288	345	(9)	
	CDD10.0	361	0	0	0	1	7	34	88	107	78	36	8	2	(10)	
	CDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0	(11)	
	CDH23.3	0	0	0	0	0	0	0	0	0	0	0	0	0	(12)	
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0	(13)	
(14) Wind	WSAvg	8.5	10.9	10.3	9.6	8.2	7.2	6.4	5.8	6.2	7.3	9.9	10.3	10.4	(14)	
(15) Precipitation	PrecAvg	1316	147	119	114	81	75	75	75	92	108	136	146	148	(15)	
	PrecMax	1662	258	224	238	122	148	125	124	170	274	250	211	250	(16)	
	PrecMin	1031	38	44	42	41	14	34	38	36	41	56	45	39	(17)	
	PrecStd	150	61	49	45	22	31	25	25	33	44	44	41	51	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	10.8	10.9	10.8	11.8	13.6	15.2	17.3	18.3	17.3	14.8	14.4	12.2	(19)	
		MCWB	9.7	9.6	9.5	10.5	12.3	13.7	15.8	16.8	15.8	13.3	13.5	11.1	(20)	
	2%	DB	10.1	10.0	9.9	10.7	12.3	14.0	16.1	16.9	16.1	13.9	12.7	11.5	(21)	
		MCWB	9.1	9.0	9.0	9.6	11.2	12.8	14.7	15.6	15.0	12.7	11.7	10.5	(22)	
	5%	DB	9.6	9.2	9.3	10.2	11.6	13.2	15.4	16.1	15.0	13.3	12.1	10.7	(23)	
		MCWB	8.6	8.4	8.5	9.1	10.5	12.1	14.2	14.9	14.1	12.3	11.1	9.8	(24)	
	10%	DB	9.1	8.6	8.8	9.7	11.0	12.7	14.7	15.1	14.3	12.9	11.4	10.1	(25)	
		MCWB	8.2	7.7	8.0	8.7	10.1	11.7	13.7	14.2	13.5	11.9	10.4	9.0	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	10.0	10.1	9.8	10.9	12.7	14.1	16.3	17.1	16.2	13.9	13.7	11.5	(27)	
		MCDB	10.5	10.7	10.2	11.5	13.4	14.8	17.0	18.1	17.1	14.4	14.3	12.0	(28)	
	2%	WB	9.4	9.2	9.2	9.9	11.4	13.1	15.2	16.0	15.3	13.2	12.0	10.7	(29)	
		MCDB	9.9	9.7	9.7	10.5	12.0	13.7	15.8	16.8	16.0	13.5	12.5	11.3	(30)	
	5%	WB	8.9	8.6	8.7	9.3	10.8	12.5	14.5	15.3	14.5	12.7	11.3	10.0	(31)	
		MCDB	9.5	9.1	9.2	9.9	11.4	13.0	15.2	16.0	15.1	13.1	11.9	10.7	(32)	
	10%	WB	8.3	7.9	8.2	8.9	10.2	11.9	13.9	14.6	13.8	12.2	10.7	9.2	(33)	
		MCDB	9.1	8.5	8.8	9.5	10.9	12.5	14.6	15.3	14.3	12.8	11.4	10.0	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	2.5	2.5	2.2	2.1	2.1	2.0	2.1	1.9	2.0	2.2	2.5	2.7	(35)	
		MCDBR	3.0	3.0	2.4	2.4	2.6	2.6	2.8	2.6	2.5	2.6	2.8	3.1	(36)	
	5% WB	MCWBR	3.3	3.2	2.5	2.2	2.4	2.4	2.5	2.3	2.3	2.8	3.1	3.5	(37)	
		MCDWR	3.0	3.0	2.4	2.3	2.5	2.6	2.8	2.5	2.4	2.6	2.7	3.0	(38)	
(40) Clear-Sky Solar Irradiance	taub	taub	0.334	0.353	0.368	0.386	0.378	0.372	0.381	0.370	0.363	0.348	0.329	0.317	(40)	
		taud	2.131	2.244	2.305	2.309	2.396	2.454	2.444	2.478	2.462	2.358	2.188	2.089	(41)	
	Edn at Noon	Edn at Noon	435	644	763	816	853	864	845	829	770	650	441	318	(42)	
		Edh at Noon	51	74	92	108	106	102	101	91	79	65	47	37	(43)	
(44) All-Sky Solar Radiation	RadAvg	RadAvg	0.29	0.86	1.98	3.53	4.80	4.80	4.42	3.65	2.35	1.17	0.41	0.19	(44)	
	RadStd	RadStd	0.03	0.10	0.13	0.28	0.37	0.39	0.35	0.24	0.16	0.10	0.04	0.02	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (19 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page