

NORTH RONA ISLAND, United Kingdom

WMO: 030110

Lat: 59.121N

Lon: 5.815W

Elev: 338

StdP: 14.52

Time Zone: 0.00 (EUW)

Period: 94-09

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	32.2	33.9	19.7	15.0	35.6	21.9	16.6	36.3	71.7	42.3	64.8	44.1	28.8	350	1.137

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	3.6	60.7	57.6	58.5	56.0	57.4	55.1	58.1	59.8	56.6	57.9	55.5	56.7	14.6	130

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
57.1	70.5	59.1	55.8	67.1	57.5	54.7	64.4	56.5	25.3	60.1	24.3	58.1	23.6	56.8	70.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
61.8	55.3	49.7	DB	28.9	65.9	2.6	5.6	27.0	69.9	25.5	73.2	24.1	76.4	22.2	80.5
			WB	26.4	61.5	1.9	3.5	25.0	64.1	23.9	66.1	22.9	68.1	21.5	70.7

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	47.0	42.3	41.4	41.5	44.0	46.5	49.9	53.3	54.0	52.0	49.4	45.7	43.2
	DBStd	5.61	3.11	3.83	3.57	3.55	3.38	2.74	2.93	2.90	3.38	3.51	3.76	4.15
	HDD50	1498	239	241	262	183	116	34	3	4	20	54	132	210
	HDD65	6578	704	661	727	631	572	452	362	340	390	485	579	675
	CDD50	397	0	0	0	2	9	32	107	129	80	34	4	0
	CDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH74	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	24.8	31.5	30.8	28.8	24.5	19.7	19.9	17.7	17.2	22.5	27.6	28.8	29.2
Precipitation	PrecAvg	70.7	8.6	6.9	6.5	4.1	3.5	3.6	4.0	4.6	5.9	7.3	7.6	8.2
	PrecMax	98.0	15.6	14.4	15.9	6.4	8.3	5.8	5.9	9.2	9.4	11.2	12.7	14.3
	PrecMin	49.7	3.2	2.8	2.1	2.0	0.7	1.7	1.8	2.1	2.0	3.2	3.6	2.2
	PrecStd	10.1	3.2	3.3	2.6	1.1	1.5	1.1	0.9	1.7	1.9	2.1	2.2	3.1
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	50.3	49.4	49.3	56.7	58.7	59.5	64.1	65.7	59.6	57.7	55.1	52.2
		MCWB	48.1	47.5	47.1	50.1	52.2	55.7	61.0	60.9	56.1	54.6	53.0	49.8
	2%	DB	49.2	48.6	47.9	50.0	54.1	56.3	60.6	61.1	57.7	55.9	52.6	50.8
		MCWB	47.1	46.9	45.8	47.4	50.8	53.6	58.0	58.4	55.3	53.4	50.5	48.9
	5%	DB	48.2	47.8	47.2	48.7	51.8	54.5	58.5	58.4	56.7	54.8	51.4	49.9
		MCWB	46.3	46.1	45.1	46.6	49.3	52.2	56.2	56.3	54.7	52.5	49.4	48.1
	10%	DB	47.2	46.9	46.4	47.9	50.4	53.3	57.0	57.3	55.8	53.8	50.7	49.0
		MCWB	45.0	45.0	44.3	45.9	48.1	51.2	55.1	55.2	53.9	51.6	48.6	47.0
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	49.2	48.4	47.7	50.4	52.9	56.5	61.0	60.5	57.4	55.3	53.4	50.9
		MCDB	50.1	48.8	48.6	54.4	56.6	59.2	63.8	63.7	58.6	56.5	54.5	51.5
	2%	WB	47.7	47.5	46.6	48.2	51.0	53.9	58.4	58.2	56.1	54.1	51.3	49.5
		MCDB	48.6	48.2	47.6	49.5	53.6	55.6	60.2	59.8	57.1	55.4	52.3	50.4
	5%	WB	46.6	46.6	45.7	47.1	49.5	52.6	56.7	56.6	55.2	53.0	50.0	48.5
		MCDB	47.9	47.5	46.9	48.5	51.5	54.1	58.1	57.8	56.3	54.5	51.1	49.7
	10%	WB	45.3	45.4	44.6	46.2	48.4	51.6	55.2	55.4	54.4	52.0	48.9	47.3
		MCDB	47.0	46.7	46.2	47.7	50.2	52.9	56.5	56.7	55.7	53.7	50.4	48.9
Mean Daily Temperature Range	5% DB	MDBR	5.1	5.1	4.8	4.4	4.1	3.6	3.6	3.6	3.9	4.2	4.7	5.1
		MCDBR	6.4	5.5	5.3	4.8	5.9	5.4	6.0	5.3	4.8	4.7	4.9	5.5
		MCWBR	7.3	6.2	5.8	4.3	4.7	4.9	5.1	4.8	4.7	5.0	5.9	6.6
	5% WB	MCDBR	6.5	5.4	5.7	4.8	5.7	5.0	6.0	5.0	4.4	4.8	5.1	5.7
		MCWBR	7.6	6.3	6.4	4.4	4.9	4.8	5.0	4.9	4.7	5.5	6.4	6.9
Clear-Sky Solar Irradiance	taub	0.337	0.351	0.364	0.379	0.373	0.367	0.373	0.364	0.361	0.346	0.322	0.308	
	taud	2.109	2.235	2.310	2.326	2.405	2.464	2.461	2.492	2.459	2.349	2.182	2.070	
	Ebn at Noon	135	205	243	261	272	276	271	265	245	207	142	102	
	Edh at Noon	16	23	29	34	33	32	31	28	25	21	15	12	
All-Sky Solar Radiation	RadAvg	90	271	627	1119	1518	1533	1406	1165	749	370	131	59	
	RadStd	11	28	41	87	120	126	116	80	47	32	13	5	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (13 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page