

SOUTH UIST RANGE, United Kingdom

WMO: 030230

Lat: 57.3575N

Lon: 7.3850W

Elev: 13

StdP: 14.69

Time Zone: 0.00 (EUW)

Period: 96-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	31.2	33.0	24.3	18.5	36.1	26.4	20.4	36.4	49.7	45.4	45.4	44.1	8.6	10	0.875

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	7.5	66.9	60.8	64.0	59.2	62.1	58.1	62.1	65.3	60.4	62.8	59.1	61.1	14.5	150

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
60.6	79.1	63.4	59.2	75.2	61.5	58.2	72.3	60.2	27.9	65.8	26.7	63.0	25.8	61.3	72.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 43.0	38.0	33.6	28.3	72.4	2.2	3.3	26.7	74.8	25.4	76.7	24.1	78.6	22.5	81.0		
(5)			27.1	64.7	2.3	1.6	25.4	65.9	24.1	66.8	22.8	67.8	21.1	69.0		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	48.9	42.3	42.2	43.6	46.5	50.3	53.9	56.8	57.1	54.8	50.5	45.9	43.1
	DBStd	6.68	3.92	4.10	3.80	4.06	4.06	3.30	3.00	2.83	3.09	3.94	4.46	4.68
	HDD50	1218	238	219	202	117	44	4	0	0	3	42	133	216
	HDD65	5859	703	638	665	556	456	332	254	247	305	449	574	680
	CDD50	834	0	0	2	11	53	122	212	219	147	58	9	1
	CDD65	2	0	0	0	0	0	0	1	1	0	0	0	0
	CDH74	2	0	0	0	0	0	0	1	1	0	0	0	0
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	17.3	19.8	19.4	18.5	16.5	15.7	15.1	13.8	14.7	17.3	18.1	19.1	19.4
Precipitation	PrecAvg	50.6	6.0	4.3	4.2	3.0	2.5	2.8	3.2	3.9	4.2	5.4	5.4	5.4
	PrecMax	66.7	10.3	10.0	8.5	4.8	6.3	5.2	5.6	10.4	8.2	9.2	8.9	9.4
	PrecMin	37.0	2.6	1.8	0.8	1.2	0.2	0.9	1.4	1.7	1.3	2.0	3.6	1.2
	PrecStd	6.7	1.9	2.0	1.6	0.9	1.4	1.1	1.0	1.8	1.6	2.1	1.2	2.1
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	51.9	52.1	55.4	62.7	68.3	69.0	71.5	70.7	65.4	60.9	57.4	53.8
		MCWB	50.0	49.1	50.0	52.3	59.7	61.3	63.1	64.9	58.6	57.0	54.0	52.3
	2%	DB	50.4	50.3	51.4	56.3	62.7	63.9	66.4	65.7	62.1	58.4	54.7	52.0
		MCWB	49.0	48.6	48.4	50.6	56.1	58.5	61.3	61.6	57.8	55.6	52.4	50.6
	5%	DB	49.3	49.3	49.9	53.5	58.9	61.0	63.4	62.9	60.5	57.1	53.3	50.9
		MCWB	48.0	47.8	47.9	49.6	53.6	56.7	59.5	59.7	57.3	54.5	51.1	49.4
	10%	DB	48.2	48.1	48.8	51.8	56.1	58.7	61.5	61.1	59.3	56.0	52.1	49.8
		MCWB	46.7	46.5	47.0	48.7	52.1	55.2	58.2	58.0	56.6	53.5	49.9	48.2
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	50.9	50.4	51.0	53.8	60.2	62.1	64.5	65.4	60.8	58.6	55.5	52.8
		MCDB	51.7	50.8	53.2	59.3	66.4	67.3	70.4	68.5	62.8	59.4	56.0	53.4
	2%	WB	49.6	49.4	49.4	51.8	57.1	59.3	62.0	62.2	59.3	56.6	53.1	51.1
		MCDB	50.1	49.9	50.5	54.4	61.4	63.0	65.3	64.9	60.6	57.7	54.0	51.8
	5%	WB	48.5	48.4	48.5	50.6	54.6	57.3	60.3	60.3	58.4	55.3	51.7	50.0
		MCDB	49.2	49.1	49.5	52.7	57.7	59.9	62.8	62.2	59.7	56.6	52.9	50.8
	10%	WB	47.2	47.1	47.5	49.4	52.8	56.0	58.9	59.0	57.3	54.1	50.3	48.6
		MCDB	48.1	48.1	48.7	51.3	55.3	58.2	61.0	60.4	58.8	55.6	51.8	49.8
Mean Daily Temperature Range	5% DB	MDBR	6.5	6.8	7.4	7.9	8.5	7.5	7.4	7.5	7.1	7.1	6.9	7.1
		MCDBR	6.3	6.0	7.2	9.8	12.6	10.8	10.6	9.4	8.0	7.0	6.6	6.9
		MCWBR	7.2	6.2	6.4	6.8	8.2	6.9	6.9	6.9	6.2	6.3	7.1	7.8
	5% WB	MCDBR	6.4	5.7	6.8	8.6	11.0	9.2	9.7	8.6	6.9	6.4	6.8	7.0
		MCWBR	7.4	6.2	6.5	6.9	8.1	6.6	6.6	7.0	6.5	6.8	7.9	8.1
Clear-Sky Solar Irradiance	taub	0.355	0.361	0.376	0.387	0.388	0.376	0.379	0.370	0.372	0.354	0.339	0.332	
	taud	2.126	2.234	2.283	2.313	2.365	2.445	2.449	2.480	2.431	2.356	2.202	2.110	
	Ebn at Noon	147	210	243	261	269	274	271	266	245	213	154	120	
	Edh at Noon	19	25	31	35	35	33	32	29	27	22	17	14	
All-Sky Solar Radiation	RadAvg	118	311	681	1184	1564	1593	1458	1161	762	396	158	80	
	RadStd	13	30	51	82	117	159	101	75	37	38	14	10	

Historical Trends

		Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (18 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page