

HYSKEIR LH, United Kingdom

WMO: 030240

Lat: 56.967N

Lon: 6.683W

Elev: 10

StdP: 101.20

Time Zone: 0.00 (EUW)

Period: 86-95

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	2.0	2.8	-3.0	2.9	3.6	-1.9	3.2	3.8	27.6	7.1	25.4	7.1	8.0	90	0.893

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	2.6	18.6	15.8	17.2	15.0	16.1	14.3	16.2	18.0	15.3	16.7	14.6	15.7	3.4	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
15.4	10.9	17.0	14.6	10.4	16.0	14.0	10.0	15.3	45.4	18.1	42.9	16.9	41.0	15.8	20.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	(q)
(4) 22.9	20.7	18.3	DB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(5)			WB	-0.9	17.2	1.9	1.5	-2.2	18.3	-3.3	19.2	-4.4	20.0	-5.8	21.2	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	9.6	6.2	6.1	6.3	7.8	10.5	12.0	13.7	13.6	12.4	10.5	8.7	7.4
	DBStd	3.24	1.78	1.72	1.62	1.47	2.26	1.80	1.69	1.31	1.32	1.86	1.70	1.71
	HDD10.0	574	117	109	115	67	19	2	0	0	1	18	45	81
	HDD18.3	3183	376	342	373	317	244	190	145	146	178	244	289	338
	CDD10.0	434	0	0	0	1	33	62	114	113	73	32	6	1
	CDD18.3	1	0	0	0	0	0	0	1	0	0	0	0	0
	CDH23.3	1	0	0	0	0	0	0	1	0	0	0	0	0
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	8.5	11.2	10.4	10.0	7.8	6.5	6.1	5.9	6.7	8.1	9.2	10.2	10.1
Precipitation	PrecAvg	1969	233	173	161	118	99	100	124	144	170	213	213	221
	PrecMax	2602	386	381	316	187	250	194	186	325	316	387	344	359
	PrecMin	1453	93	53	50	48	33	27	39	48	55	55	123	51
	PrecStd	270	72	88	63	40	49	37	35	57	68	87	60	92
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	10.5	10.0	10.0	12.7	19.2	19.2	21.6	19.6	17.2	14.7	12.5	11.7
		MCWB	9.8	9.3	9.0	10.3	14.6	15.8	17.6	16.9	15.0	12.8	11.2	11.0
	2%	DB	9.8	9.4	9.5	11.3	16.7	17.4	18.7	17.6	15.7	13.8	11.9	11.0
		MCWB	9.1	8.8	8.6	9.4	13.2	14.6	16.3	15.7	13.9	12.1	11.1	10.2
	5%	DB	9.2	9.0	9.0	10.4	14.8	15.7	17.2	16.2	14.9	13.2	11.5	10.4
		MCWB	8.4	8.4	8.2	8.9	12.2	13.6	15.2	14.7	13.5	11.8	10.6	9.7
	10%	DB	8.7	8.5	8.5	9.7	13.5	14.5	16.1	15.4	14.4	12.7	11.0	10.0
		MCWB	7.9	7.7	7.8	8.4	11.3	12.7	14.5	14.0	13.0	11.5	10.1	9.3
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	10.2	9.5	9.6	10.7	15.5	16.0	18.2	17.5	15.6	13.2	11.9	11.4
		MCDB	10.4	9.6	9.7	12.0	18.8	18.8	20.9	19.4	16.9	14.0	12.0	11.5
	2%	WB	9.4	9.0	8.9	9.8	13.5	14.7	16.5	16.0	14.6	12.6	11.4	10.4
		MCDB	9.7	9.2	9.2	10.8	16.2	16.9	18.4	17.3	15.2	13.2	11.8	10.6
	5%	WB	8.7	8.6	8.5	9.2	12.3	13.7	15.5	15.1	13.9	12.2	10.8	10.0
		MCDB	9.1	8.8	8.8	9.9	14.5	15.4	16.9	16.0	14.7	12.9	11.4	10.2
	10%	WB	8.1	8.0	8.0	8.8	11.5	13.0	14.6	14.5	13.3	11.8	10.2	9.5
		MCDB	8.6	8.4	8.4	9.4	13.1	14.1	15.8	15.2	14.0	12.6	10.9	9.9
Mean Daily Temperature Range	5% DB	MDBR	2.3	2.1	2.5	2.9	3.6	3.2	2.9	2.6	2.6	2.3	2.0	2.2
		MCDBR	2.9	2.1	2.5	3.7	5.8	5.2	4.9	3.8	3.5	2.5	2.2	2.5
		MCWBR	3.3	2.4	2.6	2.9	3.9	3.4	3.2	2.8	2.7	2.4	2.7	3.0
	5% WB	MCDBR	2.8	1.9	2.4	3.2	5.3	4.6	4.6	3.4	3.1	2.2	2.2	2.3
		MCWBR	3.4	2.3	2.7	2.8	3.7	3.2	3.3	2.7	3.0	2.6	2.8	3.0
Clear-Sky Solar Irradiance	taub	0.352	0.358	0.374	0.385	0.388	0.376	0.379	0.369	0.369	0.353	0.338	0.333	
	taud	2.143	2.253	2.292	2.318	2.365	2.440	2.443	2.478	2.448	2.377	2.221	2.125	
	Ebn at Noon	482	674	773	828	850	865	854	839	780	680	503	393	
	Edh at Noon	59	79	97	110	111	105	102	93	83	69	54	46	
All-Sky Solar Radiation	RadAvg	0.39	1.02	2.21	3.84	5.02	5.13	4.71	3.78	2.49	1.30	0.52	0.27	
	RadStd	0.04	0.10	0.16	0.26	0.38	0.51	0.32	0.25	0.14	0.13	0.05	0.03	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (30 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page