

SKYE LUSA, United Kingdom

WMO: 030370

Lat: 57.250N

Lon: 5.800W

Elev: 59

StdP: 14.66

Time Zone: 0.00 (EUW)

Period: 98-17

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	26.7	29.0	21.7	16.3	32.0	24.2	18.4	32.7	35.9	43.0	32.4	42.8	3.0	120	0.651

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.1	70.2	60.7	66.8	59.2	64.1	57.8	62.5	67.6	60.6	64.6	59.1	62.5	8.0	220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
60.3	78.3	64.3	58.8	74.2	62.2	57.5	70.6	60.8	28.2	67.7	26.9	64.7	25.8	62.5	81.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 29.5	25.3	22.0	DB	24.6	76.5	2.6	3.7	22.8	79.2	21.3	81.3	19.8	83.4	17.9	86.0	(4)
(5)			WB	23.7	65.7	2.5	2.2	21.9	67.3	20.4	68.6	19.0	69.8	17.2	71.5	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	48.2	41.0	40.8	42.9	45.9	49.9	54.0	56.8	56.8	54.6	49.6	44.8	41.2
	DBStd	7.43	4.86	4.35	4.39	4.62	4.47	3.89	3.48	3.49	3.78	4.45	4.88	5.92
	HDD50	1466	278	256	221	138	56	8	0	1	7	62	164	275
	HDD65	6123	743	676	684	574	470	329	256	256	312	478	607	738
	CDD50	823	0	0	2	14	52	129	211	211	145	49	8	2
	CDD65	3	0	0	0	0	0	0	1	2	0	0	0	0
	CDH74	30	0	0	0	0	2	6	9	13	0	0	0	0
	CDH80	2	0	0	0	0	0	0	1	1	0	0	0	0
Wind	WSAvg	9.3	10.7	10.4	10.3	9.2	8.6	8.4	8.1	8.1	8.5	8.9	9.8	10.4
Precipitation	PrecAvg	72.0	8.3	6.2	5.7	3.9	4.3	3.7	4.0	4.9	6.4	7.9	8.1	8.4
	PrecMax	86.4	11.5	15.0	8.9	7.8	10.4	6.7	7.8	9.2	11.2	13.7	11.4	14.2
	PrecMin	46.4	3.3	1.1	1.3	1.6	0.8	1.3	1.6	2.0	1.9	2.3	4.4	1.3
	PrecStd	10.3	2.4	3.3	2.1	1.5	2.2	1.3	1.4	2.0	2.9	3.1	2.1	3.8
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	52.1	52.8	59.0	65.9	71.7	72.7	74.5	75.4	69.5	63.6	58.1	55.7
		MCWB	49.1	48.0	50.8	54.1	57.5	60.9	64.5	65.7	59.9	56.3	53.6	52.4
	2%	DB	50.8	50.4	53.5	59.2	65.1	66.7	69.3	68.5	65.6	60.4	54.9	53.2
		MCWB	48.8	48.0	48.2	50.1	55.0	58.0	61.7	61.1	58.5	55.1	51.5	51.1
	5%	DB	49.5	49.1	51.0	55.9	60.7	63.0	65.8	64.8	62.8	58.0	53.4	51.4
		MCWB	47.9	47.0	47.5	49.4	53.1	56.6	59.8	59.1	57.4	53.9	50.9	49.6
	10%	DB	48.1	47.7	49.5	53.1	57.2	60.5	62.8	62.4	60.6	56.3	51.9	49.9
		MCWB	46.4	45.5	46.6	48.2	51.4	55.3	57.8	58.0	56.4	52.9	49.6	48.0
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	50.8	50.3	51.9	54.8	59.5	61.8	65.9	66.1	62.5	58.3	56.0	53.5
		MCDB	51.4	50.9	55.8	62.8	68.5	69.6	73.7	71.8	66.8	60.7	57.7	54.4
	2%	WB	49.6	49.0	49.8	52.1	56.1	59.2	62.8	62.4	60.1	56.5	52.9	51.5
		MCDB	50.5	49.9	51.8	56.5	62.9	64.7	67.9	66.7	63.2	59.0	54.1	52.6
	5%	WB	48.2	47.6	48.4	50.4	54.0	57.6	60.6	60.3	58.5	55.0	51.2	50.1
		MCDB	49.3	48.9	50.5	54.2	59.2	61.9	64.5	63.5	61.3	57.3	52.9	51.3
	10%	WB	46.6	45.9	47.1	48.9	52.2	56.2	58.8	58.7	57.1	53.5	49.8	48.1
		MCDB	47.9	47.5	49.3	52.5	56.2	59.7	61.8	61.6	59.8	55.8	51.8	49.9
Mean Daily Temperature Range	5% DB	MDBR	7.8	9.0	10.5	12.3	12.4	11.1	10.1	10.6	10.4	9.8	8.6	8.4
		MCDBR	7.9	9.4	12.1	16.7	18.6	15.5	15.6	15.3	13.7	11.5	9.2	9.2
		MCWBR	7.9	8.2	8.6	9.8	10.7	8.8	9.2	9.2	8.5	8.3	8.2	9.1
	5% WB	MCDBR	7.4	7.9	10.7	14.0	15.8	13.6	14.2	13.7	11.5	10.0	9.0	9.3
		MCWBR	7.9	7.8	8.6	9.0	9.8	8.6	9.2	9.5	8.4	8.5	8.8	9.6
Clear-Sky Solar Irradiance	taub	0.345	0.353	0.372	0.385	0.389	0.379	0.382	0.368	0.365	0.348	0.332	0.329	
	taud	2.136	2.238	2.265	2.285	2.326	2.396	2.400	2.447	2.436	2.375	2.222	2.108	
	Ebn at Noon	153	214	245	262	268	273	269	266	248	216	159	121	
	Edh at Noon	18	25	31	36	36	35	34	30	27	22	16	14	
All-Sky Solar Radiation	RadAvg	121	315	651	1106	1472	1454	1361	1083	740	389	162	86	
	RadStd	17	38	54	82	118	149	125	76	52	44	15	10	

Historical Trends

		Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (32 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page