

BEALACH NA BA, United Kingdom

WMO: 030390

Lat: 57.4181N

Lon: 5.6886W

Elev: 2536

StdP: 13.40

Time Zone: 0.00 (EUW)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	21.6	23.1	9.1	9.6	32.2	15.3	13.1	28.6	103.7	33.7	94.3	34.4	23.6	100	1.157

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	6.1	62.8	54.9	59.8	53.3	56.7	51.3	57.3	60.5	55.1	57.8	53.1	55.6	10.7	110

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
56.1	73.6	58.2	54.0	68.0	55.9	52.0	63.3	53.6	25.7	60.5	24.2	58.1	23.0	55.9	65.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
86.9	71.0	58.3	DB	20.4	67.9	2.8	3.3	18.4	70.3	16.8	72.3	15.3	74.2	13.3	76.6
			WB	18.2	59.9	2.8	4.3	16.2	62.9	14.5	65.4	13.0	67.8	10.9	70.9

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	39.4	32.0	31.8	33.6	37.2	41.1	45.4	48.5	47.6	45.3	40.5	35.9	33.6
	DBStd	7.79	4.43	4.83	5.48	5.81	6.31	5.42	5.24	4.03	4.41	4.73	4.76	4.94
	HDD50	3988	557	510	509	388	289	162	94	98	153	295	423	510
	HDD65	9342	1022	930	973	835	741	589	513	540	592	759	873	975
	CDD50	122	0	0	1	3	13	24	46	23	11	1	0	0
	CDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH74	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	24.4	30.9	27.5	28.1	22.6	19.6	18.7	18.3	20.6	22.8	23.7	28.8	31.6
Precipitation	PrecAvg	77.6	9.1	7.4	6.9	4.6	4.4	3.9	4.2	5.1	6.4	8.1	8.3	9.1
	PrecMax	103.9	14.8	15.9	17.3	8.1	11.3	6.9	7.8	10.0	11.5	14.8	13.0	15.7
	PrecMin	48.0	2.8	1.2	1.2	1.8	0.6	1.4	1.9	2.0	1.5	2.3	3.6	1.7
	PrecStd	12.3	3.1	3.9	3.1	1.7	2.1	1.3	1.3	2.2	2.8	3.2	2.6	4.1
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	44.0	46.2	53.2	58.5	63.7	65.6	67.2	65.6	61.0	55.2	50.0	48.1
		MCWB	43.2	43.6	49.0	45.3	54.5	52.7	56.4	60.3	52.9	49.8	47.6	43.6
	2%	DB	42.3	42.2	48.0	52.3	58.7	60.8	62.8	59.0	56.5	51.7	46.6	45.1
		MCWB	41.4	40.7	40.9	44.2	49.9	52.7	56.7	54.9	51.1	49.4	45.4	43.0
	5%	DB	40.8	40.5	43.3	47.6	54.2	56.6	59.6	55.8	53.2	49.4	44.5	43.3
		MCWB	39.8	39.3	41.1	42.8	46.4	50.0	55.2	53.2	50.4	47.4	43.8	42.3
	10%	DB	39.1	38.7	40.7	44.6	50.3	53.1	56.2	53.3	51.3	47.3	42.7	41.3
		MCWB	38.6	37.2	39.4	42.0	45.1	48.3	52.7	51.1	49.6	45.8	41.9	40.9
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	43.4	44.1	52.0	48.1	58.6	55.7	60.2	61.3	56.5	52.1	48.7	45.9
		MCDB	43.4	44.9	54.0	52.4	62.3	60.8	62.0	64.3	59.2	52.8	49.5	46.0
	2%	WB	42.0	41.5	44.1	46.2	51.8	53.7	57.7	56.4	53.0	50.1	46.2	43.8
		MCDB	42.1	42.4	45.5	49.4	57.2	59.0	60.8	58.1	54.0	51.2	46.6	44.0
	5%	WB	40.3	40.0	41.7	44.2	48.6	51.5	55.5	54.1	51.3	48.1	44.1	42.0
		MCDB	40.5	40.5	42.7	46.8	52.4	56.2	58.6	55.4	52.4	48.8	44.4	42.5
	10%	WB	38.5	37.8	39.4	42.1	46.4	49.3	53.3	51.8	49.8	46.0	42.2	40.1
		MCDB	38.7	38.3	40.3	44.3	50.0	52.4	55.8	53.1	50.9	46.9	42.6	40.8
Mean Daily Temperature Range	5% DB	MDBR	5.8	5.4	5.8	6.7	7.4	6.8	6.1	5.6	5.9	5.8	5.6	6.2
		MCDBR	8.2	7.5	8.5	10.6	11.6	10.5	9.7	8.5	8.0	8.7	8.6	9.5
		MCWBR	8.0	6.9	6.8	6.8	7.9	7.6	7.8	7.1	7.1	8.1	8.6	8.9
	5% WB	MCDBR	8.0	7.6	7.9	9.4	10.5	9.4	8.4	7.8	7.6	9.1	8.8	9.1
		MCWBR	8.1	7.3	7.4	6.9	8.5	7.7	7.4	7.2	7.4	8.6	8.7	9.1
Clear-Sky Solar Irradiance	taub	0.294	0.310	0.326	0.337	0.340	0.333	0.336	0.325	0.321	0.309	0.286	0.274	
	taud	2.203	2.350	2.400	2.417	2.445	2.487	2.485	2.524	2.533	2.479	2.284	2.132	
	Ebn at Noon	177	235	264	279	285	288	284	281	265	235	182	145	
	Edh at Noon	16	22	27	31	32	31	31	28	24	19	15	13	
All-Sky Solar Radiation	RadAvg	119	311	639	1084	1452	1427	1338	1065	734	385	161	84	
	RadStd	17	38	54	81	115	144	128	71	53	43	15	10	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (34 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page