

AONACH MOR, United Kingdom

WMO: 030410

Lat: 56.822N

Lon: 4.969W

Elev: 3707

StdP: 12.83

Time Zone: 0.00 (EUW)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	15.6	17.2	1.5	6.8	32.2	9.3	10.2	29.1	66.7	32.5	62.0	31.6	20.0	30	1.243

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	7.0	60.9	53.5	57.2	50.7	54.5	50.0	55.5	57.9	53.1	55.1	51.5	53.4	15.8	210

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
54.4	72.3	56.0	52.4	67.0	53.8	50.5	62.6	52.1	25.0	57.9	23.5	55.1	22.4	53.6	74.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
72.9	58.5	49.9	DB	13.0	63.9	2.2	3.9	11.4	66.6	10.1	68.9	8.9	71.1	7.2	73.9	
			WB	12.3	56.9	2.3	2.9	10.7	58.9	9.4	60.6	8.1	62.3	6.5	64.4	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	35.6	28.2	27.2	29.5	32.5	36.7	41.5	45.7	45.3	42.1	37.0	31.8	29.3
	DBStd	8.72	5.43	5.60	6.32	6.23	7.21	5.86	5.92	4.97	5.10	5.24	5.47	6.32
	HDD50	5318	674	638	635	526	420	264	163	165	242	403	547	641
	HDD65	10720	1139	1058	1100	975	878	705	597	611	686	868	997	1106
	CDD50	73	0	0	0	1	7	9	31	19	6	0	0	0
	CDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH74	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	24.3	28.9	27.0	25.5	22.4	21.4	21.4	20.8	20.7	22.5	25.9	26.7	28.1
Precipitation	PrecAvg	79.1	10.6	7.6	7.2	4.4	4.0	3.8	4.3	4.8	6.1	8.1	8.4	9.7
	PrecMax	102.5	19.5	17.0	17.7	7.7	10.3	7.0	7.1	11.1	12.2	14.5	15.3	21.7
	PrecMin	52.6	3.5	2.2	1.4	2.2	0.8	1.4	1.9	0.9	1.6	2.5	3.8	1.1
	PrecStd	12.8	4.1	4.4	3.8	1.5	2.2	1.4	1.3	2.1	2.7	3.5	3.0	5.4
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	46.1	44.4	50.2	54.4	61.0	61.7	67.0	64.0	58.9	52.4	47.3	47.8
		MCWB	44.4	43.6	41.5	47.1	49.6	55.1	56.5	54.3	47.8	47.1	40.8	42.0
	2%	DB	41.5	40.9	45.7	48.6	54.9	56.3	61.4	58.9	54.8	49.1	44.0	43.2
		MCWB	39.7	39.1	38.8	41.2	47.4	50.3	54.3	51.3	48.5	46.6	42.0	41.1
	5%	DB	38.6	38.2	41.0	44.1	50.9	52.8	57.4	55.1	52.0	46.8	41.9	40.9
		MCWB	37.2	36.7	37.8	40.1	44.2	48.7	52.4	51.5	48.7	45.5	41.1	39.9
	10%	DB	36.5	35.5	37.9	40.9	46.8	50.2	54.3	52.5	49.5	44.5	39.7	38.5
		MCWB	35.2	34.7	36.7	38.0	42.2	47.3	50.9	50.2	47.0	43.6	39.2	37.3
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	45.7	44.5	44.0	49.5	53.1	58.2	59.8	57.0	54.4	50.6	45.7	44.4
		MCDB	45.8	44.5	44.5	53.6	57.0	59.8	63.1	61.2	55.5	50.7	46.1	44.4
	2%	WB	40.3	40.6	40.8	44.2	49.6	52.1	56.1	53.9	51.6	47.6	43.0	41.8
		MCDB	40.9	40.6	44.2	46.0	54.5	54.2	59.0	55.6	52.7	48.1	43.2	41.9
	5%	WB	37.8	37.6	38.7	41.2	45.9	50.1	53.7	52.2	49.6	45.6	40.9	39.7
		MCDB	38.1	37.7	40.5	43.2	49.3	51.9	56.0	54.0	50.6	46.2	41.1	40.1
	10%	WB	35.3	34.9	36.5	38.7	43.0	47.7	51.7	50.4	47.3	43.6	38.9	37.2
		MCDB	35.6	35.0	38.0	40.0	46.2	49.5	53.8	51.9	48.5	44.1	39.2	37.6
Mean Daily Temperature Range	5% DB	MDBR	7.3	6.9	7.2	7.6	8.1	7.5	7.0	6.4	6.7	6.5	6.5	7.3
		MCDBR	11.6	9.6	11.1	10.8	11.4	9.7	10.4	9.2	9.4	10.2	10.6	10.6
		MCWBR	11.0	9.3	9.2	8.4	8.5	8.3	8.8	7.9	8.7	9.1	10.2	10.7
	5% WB	MCDBR	11.3	9.5	10.2	9.1	10.1	8.4	8.6	7.9	9.1	9.6	10.0	11.1
		MCWBR	11.1	9.6	9.3	8.3	8.4	8.4	8.5	8.1	9.1	9.4	9.9	11.0
Clear-Sky Solar Irradiance	taub	0.273	0.290	0.308	0.320	0.324	0.321	0.322	0.310	0.303	0.293	0.270	0.255	
	taud	2.258	2.403	2.426	2.430	2.450	2.480	2.476	2.522	2.549	2.522	2.347	2.182	
	Ebn at Noon	196	248	273	286	291	292	289	287	273	246	199	166	
	Edh at Noon	16	21	27	31	32	32	31	28	23	19	14	13	
All-Sky Solar Radiation	RadAvg	127	324	648	1085	1433	1392	1324	1051	726	386	168	95	
	RadStd	20	44	56	86	128	152	136	88	59	50	15	13	

Historical Trends

		Heating		Cooling			Degree-Days				
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
Station Only	DBAvg	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (42 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page