

TULLOCH BRIDGE, United Kingdom

WMO: 030470

Lat: 56.8669N

Lon: 4.7081W

Elev: 817

StdP: 14.27

Time Zone: 0.00 (EUW)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	16.8	22.1	15.0	12.1	19.8	19.8	15.3	27.6	29.8	42.9	26.5	42.7	0.9	0	0.644

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	13.7	71.8	60.3	68.0	58.2	64.9	57.2	62.1	68.7	60.3	65.8	58.6	63.2	8.5	190

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
59.5	78.3	64.3	57.9	73.7	62.6	56.3	69.5	61.2	28.3	69.0	26.9	66.0	25.8	63.4	77.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
22.5	19.3	16.9	12.1	77.5	5.1	3.4	8.4	79.9	5.5	81.8	2.6	83.7	-1.1	86.2
			11.5	66.0	5.9	3.5	7.2	68.5	3.8	70.6	0.4	72.5	-3.9	75.0
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	45.5	37.1	37.3	39.2	43.3	48.3	52.7	55.7	54.7	51.9	46.5	41.4	37.0
	DBStd	8.76	6.02	5.98	5.48	5.21	5.58	4.67	4.18	4.15	4.56	5.35	5.98	7.63
	HDD50	2257	400	356	337	207	100	22	2	7	32	131	260	403
	HDD65	7134	865	776	801	650	519	371	290	321	394	573	707	867
	CDD50	603	0	0	1	8	46	102	179	152	88	23	3	1
	CDD65	3	0	0	0	0	0	1	1	1	0	0	0	0
	CDH74	54	0	0	0	0	5	22	18	9	0	0	0	0
	CDH80	3	0	0	0	0	0	3	0	0	0	0	0	0
Wind	WSAvg	7.2	8.4	8.5	8.2	7.2	6.9	6.6	5.9	5.9	6.5	7.3	7.2	7.5
Precipitation	PrecAvg	65.0	8.6	6.2	5.6	3.7	3.5	3.1	3.4	4.0	4.8	6.8	7.1	8.1
	PrecMax	85.6	17.6	13.9	14.6	6.2	8.4	5.4	6.1	8.8	9.5	12.0	13.6	20.6
	PrecMin	43.3	2.5	1.3	0.7	1.5	0.8	1.1	1.5	0.6	1.1	2.0	2.8	0.8
	PrecStd	11.1	3.7	3.8	3.1	1.3	1.9	1.1	1.2	1.8	2.2	3.0	2.7	4.9
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	52.0	52.7	56.7	64.9	73.6	77.1	76.4	74.0	68.2	60.2	56.0	53.6
		MCWB	48.6	49.0	47.3	52.8	58.9	62.0	63.9	65.0	59.3	55.1	52.5	50.2
	2%	DB	49.4	50.2	51.5	59.0	68.3	69.3	71.8	67.3	64.3	57.9	53.3	51.4
		MCWB	46.7	47.0	47.2	49.4	55.3	58.5	61.4	59.7	58.0	54.0	50.1	48.6
	5%	DB	47.5	48.2	49.2	55.0	63.5	65.1	67.7	64.3	61.4	55.9	51.6	49.4
		MCWB	45.0	45.4	45.6	48.1	53.2	56.4	59.4	58.1	56.6	52.4	48.8	46.8
	10%	DB	45.5	45.9	47.4	52.0	58.8	61.4	64.1	62.0	59.2	54.3	49.9	47.1
		MCWB	42.9	43.1	44.1	46.6	50.9	54.4	58.0	56.8	54.9	51.0	47.2	44.5
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	49.2	50.0	50.3	53.5	60.7	63.0	65.4	65.2	61.9	56.3	53.6	50.9
		MCDB	51.3	52.1	53.8	60.1	71.2	73.2	73.6	71.0	65.5	58.9	55.3	53.0
	2%	WB	47.3	47.5	47.7	51.1	56.9	60.0	62.7	61.1	59.1	54.7	51.1	49.0
		MCDB	49.2	49.8	50.7	57.0	65.4	68.1	69.5	65.4	62.5	57.2	52.8	51.2
	5%	WB	45.3	45.7	46.0	49.2	54.1	57.5	60.6	59.3	57.3	53.2	49.1	47.2
		MCDB	47.4	48.1	48.9	54.1	61.2	63.7	66.3	63.2	60.6	55.6	51.1	49.3
	10%	WB	43.3	43.5	44.3	47.3	51.9	55.3	58.7	57.6	55.5	51.4	47.3	44.8
		MCDB	45.5	45.9	47.4	51.4	57.9	60.1	63.1	61.3	58.8	53.9	49.6	47.1
Mean Daily Temperature Range	5% DB	MDBR	8.8	9.7	11.4	13.8	15.6	14.1	13.7	13.1	12.5	10.7	9.5	9.9
		MCDBR	9.6	9.9	13.9	19.6	25.5	22.2	21.5	17.0	15.7	11.5	10.2	10.7
		MCWBR	8.7	8.3	10.0	12.2	14.4	12.6	12.6	10.6	10.6	9.1	9.0	9.8
	5% WB	MCDBR	9.6	9.2	12.9	16.1	21.2	19.2	17.9	14.3	13.9	10.1	10.5	10.7
		MCWBR	8.9	8.2	10.1	10.6	12.6	11.7	11.1	10.0	10.6	8.9	9.7	10.1
Clear-Sky Solar Irradiance	taub	0.321	0.336	0.361	0.380	0.384	0.378	0.379	0.362	0.352	0.337	0.315	0.307	
	taud	2.157	2.248	2.247	2.254	2.296	2.350	2.358	2.412	2.437	2.390	2.254	2.120	
	Ebn at Noon	167	223	249	264	270	274	271	268	253	223	172	136	
	Edh at Noon	18	25	32	37	38	36	35	31	27	22	16	14	
All-Sky Solar Radiation	RadAvg	127	323	647	1083	1432	1391	1323	1051	726	386	167	94	
	RadStd	20	44	56	86	127	151	136	87	58	49	15	12	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	-1.80	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (45 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page