

AVIEMORE, United Kingdom

WMO: 030630

Lat: 57.2064N

Lon: 3.8283W

Elev: 228

StdP: 98.62

Time Zone: 0.00 (EUW)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-8.7	-5.8	-10.1	1.6	-7.9	-7.4	2.1	-4.6	13.2	5.6	11.7	5.3	0.8	230	0.621

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	8.7	23.7	16.3	21.5	15.4	19.6	14.5	17.3	21.9	16.3	20.3	15.3	18.7	3.5	210

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
15.5	11.3	19.2	14.4	10.6	18.1	13.5	9.9	17.0	49.4	22.1	46.3	20.3	43.4	18.9	22.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
10.0	8.4	7.3	-12.4	26.9	4.0	2.3	-15.2	28.6	-17.6	29.9	-19.8	31.2	-22.7	32.9		
			-12.7	19.1	4.0	1.2	-15.5	20.0	-17.9	20.7	-20.1	21.4	-23.0	22.3		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
Temperatures, Degree-Days and Degree-Hours	DBAvg	7.5	2.4	2.7	4.1	6.4	9.0	11.8	13.9	13.4	11.3	8.0	4.7	2.3	
	DBStd	5.23	3.37	3.32	3.18	3.13	3.22	2.78	2.70	2.50	2.62	3.03	3.37	4.28	
	HDD10.0	1305	237	206	183	114	58	13	1	2	15	76	161	239	
	HDD18.3	3952	496	438	440	358	289	198	140	155	212	321	409	497	
	CDD10.0	399	0	1	1	7	27	66	122	107	54	13	2	0	
	CDD18.3	5	0	0	0	0	0	1	3	2	0	0	0	0	
	CDH23.3	78	0	0	0	0	6	13	37	21	1	0	0	0	
	CDH26.7	7	0	0	0	0	0	2	3	2	0	0	0	0	
Wind	WSAvg	2.9	3.4	3.5	3.4	3.0	2.6	2.5	2.3	2.2	2.5	2.9	2.9	3.0	
Precipitation	PrecAvg	977	113	72	72	58	65	64	68	80	72	99	104	108	
	PrecMax	1351	287	234	218	130	107	144	140	160	210	164	187	266	
	PrecMin	673	7	8	13	9	17	19	25	29	21	21	26	20	
	PrecStd	145	59	53	46	27	26	29	31	33	39	39	36	61	
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	11.0	11.9	15.5	19.6	23.8	25.0	26.7	26.2	21.5	16.7	13.8	12.0	
		MCWB	9.1	9.2	9.6	11.7	15.2	16.1	17.7	17.9	15.8	12.9	11.5	10.1	
	2%	DB	9.5	10.5	12.0	16.0	20.4	21.5	24.1	22.2	19.1	15.1	12.0	10.7	
		MCWB	7.9	8.4	8.7	10.3	13.2	15.0	16.8	16.3	14.7	12.2	10.0	9.1	
	5%	DB	8.4	9.1	10.3	13.7	17.6	19.0	21.7	19.8	17.4	14.0	11.0	9.5	
		MCWB	6.9	7.2	7.7	9.4	11.7	13.9	15.9	15.3	13.8	11.4	9.1	8.0	
	10%	DB	7.2	7.8	9.0	12.0	15.2	17.1	19.4	18.1	15.9	12.8	9.9	8.3	
		MCWB	5.8	6.0	6.9	8.5	10.8	12.9	14.9	14.3	12.8	10.6	8.1	6.8	
	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	9.4	10.2	10.5	12.5	16.3	17.3	18.9	18.9	16.7	13.7	11.9	10.5
			MCDB	10.6	11.7	13.8	17.2	22.7	22.9	24.9	23.1	20.2	15.8	13.4	11.6
2%		WB	8.1	8.6	9.0	11.0	13.9	15.6	17.6	17.0	15.3	12.7	10.4	9.3	
		MCDB	9.3	10.2	11.4	14.9	18.8	20.4	22.3	20.7	18.2	14.7	11.8	10.5	
5%		WB	7.0	7.4	8.0	9.8	12.5	14.4	16.5	15.9	14.2	11.8	9.2	8.1	
		MCDB	8.4	9.0	10.1	13.4	16.7	18.2	20.6	19.3	16.8	13.6	10.8	9.5	
10%		WB	5.9	6.0	6.9	8.7	11.2	13.2	15.3	14.8	13.2	10.8	8.2	6.8	
		MCDB	7.2	7.6	9.0	11.7	14.8	16.5	18.9	17.7	15.5	12.5	9.7	8.3	
Mean Daily Temperature Range		5% DB	MDBR	5.0	5.8	7.0	8.6	9.6	8.6	8.7	8.5	8.0	6.9	5.7	5.5
			MCDBR	5.4	6.5	9.0	12.0	14.4	12.5	13.2	11.4	10.3	8.2	6.5	6.1
	MCWBR		4.8	5.1	6.1	7.2	8.1	6.7	6.9	6.4	6.5	5.9	5.6	5.6	
	5% WB	MCDBR	5.5	5.7	8.6	10.7	12.7	11.1	11.5	10.3	9.3	7.4	6.5	6.3	
		MCWBR	5.0	4.9	6.2	6.7	7.4	6.4	6.5	6.2	6.3	5.9	5.8	5.9	
Clear-Sky Solar Irradiance	taub	0.295	0.318	0.343	0.363	0.366	0.363	0.365	0.352	0.338	0.324	0.297	0.280		
	taud	2.244	2.335	2.327	2.330	2.367	2.399	2.399	2.443	2.488	2.462	2.323	2.184		
	Ebn at Noon	571	732	809	850	870	876	866	855	815	722	572	469		
	Edh at Noon	51	71	93	108	111	109	106	95	79	62	47	40		
All-Sky Solar Radiation	RadAvg	0.43	1.06	2.09	3.44	4.61	4.52	4.35	3.44	2.41	1.28	0.56	0.30		
	RadStd	0.06	0.11	0.23	0.32	0.29	0.41	0.39	0.23	0.20	0.13	0.05	0.04		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(47) Regional (38 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Nomenclature: See separate page