

INVERBERVIE, United Kingdom

WMO: 030880

Lat: 56.8519N

Lon: 2.2658W

Elev: 440

StdP: 14.46

Time Zone: 0.00 (EUW)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	27.7	29.8	22.7	17.3	32.6	24.5	18.9	33.4	49.8	43.1	45.3	42.0	13.8	310	0.811

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	9.9	66.6	59.8	64.2	58.4	62.2	57.4	61.8	64.8	60.2	62.6	58.8	61.0	15.2	250

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
60.5	80.1	62.9	59.1	76.0	61.3	57.7	72.1	59.9	27.8	65.1	26.7	62.7	25.8	61.1	69.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
39.5	34.0	30.3	DB	25.2	73.8	1.7	2.4	24.0	75.5	23.0	76.9	22.1	78.3	20.9	80.0
			WB	24.0	65.9	2.0	2.1	22.6	67.4	21.4	68.6	20.3	69.7	18.8	71.2

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	46.7	38.7	38.9	40.9	43.9	47.7	52.6	56.4	56.6	53.5	48.7	43.0	39.6
	DBStd	7.74	4.03	4.57	4.81	4.22	4.38	3.78	3.59	3.16	3.52	4.29	4.79	4.94
	HDD50	1865	351	311	283	188	97	16	1	1	8	75	213	321
	HDD65	6662	816	730	746	633	536	373	268	261	346	507	660	786
	CDD50	677	0	0	2	5	26	93	198	204	113	33	3	0
	CDD65	1	0	0	0	0	0	0	1	0	0	0	0	0
	CDH74	2	0	0	0	0	0	0	2	0	0	0	0	0
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0
(14) Wind	WSAvg	14.6	18.0	17.4	15.8	13.6	12.8	12.1	10.6	11.4	13.7	16.0	16.4	17.4
(15) Precipitation	PrecAvg	32.9	3.3	2.2	2.2	2.2	2.3	2.2	2.8	2.7	2.6	3.7	3.4	3.3
	PrecMax	40.7	8.7	4.7	5.9	5.7	5.0	5.4	5.6	5.7	9.4	8.8	7.7	7.9
	PrecMin	20.6	0.6	0.2	0.6	0.0	0.4	0.6	0.8	0.4	0.6	0.3	1.0	0.7
	PrecStd	4.8	1.9	1.5	1.1	1.6	1.1	1.3	1.5	1.3	1.8	2.0	1.9	1.7
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	51.9	53.9	57.6	59.8	63.3	67.3	71.5	69.3	67.7	60.5	55.2	53.1
		MCWB	48.5	49.9	50.2	52.2	56.0	58.6	62.9	61.8	60.9	55.4	52.4	50.6
	2%	DB	49.0	50.8	53.3	55.3	59.7	63.4	66.8	65.7	63.0	57.5	52.8	50.4
		MCWB	46.6	47.6	47.5	49.8	54.1	56.5	60.7	59.1	57.2	54.0	50.8	48.5
	5%	DB	46.6	47.8	50.3	52.5	56.5	60.7	64.1	63.5	60.5	55.7	51.2	48.4
		MCWB	44.7	44.9	45.7	47.7	51.7	55.5	59.1	58.4	56.0	53.1	49.7	47.0
	10%	DB	44.8	45.5	47.6	50.3	54.1	58.3	61.9	61.5	58.6	54.4	49.9	46.8
		MCWB	43.3	42.9	44.2	46.6	50.2	54.2	58.0	57.6	55.1	52.2	48.5	45.5
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	49.4	50.7	51.3	53.8	57.8	61.4	64.9	63.5	61.7	57.1	53.1	51.2
		MCDB	51.0	53.3	55.9	57.9	61.5	64.7	68.8	66.9	66.2	59.1	54.0	52.4
	2%	WB	47.2	47.8	48.6	50.9	54.9	58.5	62.3	61.2	59.0	55.2	51.5	49.0
		MCDB	48.6	50.5	51.9	54.2	58.3	61.5	65.3	63.7	61.5	56.5	52.3	50.1
	5%	WB	45.0	45.6	46.5	48.6	52.9	56.7	60.5	59.9	57.4	54.0	50.1	47.3
		MCDB	46.2	47.4	49.5	51.5	55.6	59.3	62.8	62.0	59.3	55.1	50.8	48.3
	10%	WB	43.5	43.5	44.6	46.9	51.0	55.0	58.9	58.6	56.0	52.9	48.8	45.7
		MCDB	44.6	45.1	47.2	49.3	53.5	57.4	61.1	60.5	57.6	54.0	49.7	46.7
(35) Mean Daily Temperature Range	5% DB	MDBR	6.9	8.0	9.3	9.6	10.1	9.8	9.8	9.9	9.5	8.4	7.7	7.1
		MCDBR	9.8	10.2	13.5	13.4	13.5	13.2	13.3	12.7	12.3	9.7	8.5	8.8
		MCWBR	9.3	8.4	9.6	9.3	9.1	8.9	8.4	8.0	8.4	8.0	8.2	8.5
	5% WB	MCDBR	9.1	10.0	12.7	12.2	12.3	11.6	11.8	10.5	10.4	8.9	7.9	8.7
		MCWBR	8.9	8.5	9.6	9.1	9.2	8.6	8.4	7.5	8.1	8.0	8.1	8.7
(40) Clear-Sky Solar Irradiance	taub	0.304	0.325	0.353	0.374	0.370	0.371	0.373	0.362	0.347	0.334	0.305	0.286	
	taud	2.289	2.387	2.359	2.329	2.393	2.414	2.411	2.449	2.498	2.463	2.341	2.230	
	Ebn at Noon	183	233	255	266	275	276	273	268	256	227	182	154	
	Edh at Noon	16	22	29	34	34	34	34	30	25	20	15	13	
(44) All-Sky Solar Radiation	RadAvg	147	352	692	1147	1544	1522	1470	1172	812	428	192	104	
(45)	RadStd	20	33	81	112	85	122	115	78	59	42	18	13	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (32 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page