

INVERBERVIE, United Kingdom

WMO: 030880

Lat: 56.8519N

Lon: 2.2658W

Elev: 134

StdP: 99.73

Time Zone: 0.00 (EUW)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -2.4	(c) -1.2	(d) -5.2	(e) 2.5	(f) 0.3	(g) -4.2	(h) 2.7	(i) 0.8	(j) 22.2	(k) 6.2	(l) 20.2	(m) 5.6	(n) 6.2	(o) 310	(p) 0.811

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 8	(b) 5.5	(c) 19.2	(d) 15.4	(e) 17.9	(f) 14.7	(g) 16.8	(h) 14.1	(i) 16.6	(j) 18.2	(k) 15.7	(l) 17.0	(m) 14.9	(n) 16.1	(o) 6.8	(p) 250

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
15.9	11.4	17.2	15.1	10.9	16.3	14.3	10.3	15.5	46.9	18.4	44.3	17.0	42.2	16.2	20.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
17.7	15.2	13.5	-3.8	23.2	0.9	1.3	-4.4	24.2	-5.0	25.0	-5.5	25.7	-6.2	26.7
			-4.4	18.8	1.1	1.1	-5.2	19.6	-5.9	20.3	-6.5	20.9	-7.3	21.8
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	8.2	3.7	3.8	5.0	6.6	8.7	11.4	13.5	13.6	11.9	9.3	6.1	4.2	(6)
(7)		DBStd	4.30	2.24	2.54	2.67	2.35	2.43	2.10	2.00	1.76	1.95	2.38	2.66	2.74	(7)
(8)		HDD10.0	1036	195	173	157	104	54	9	1	1	4	42	118	178	(8)
(9)		HDD18.3	3701	453	406	414	352	298	207	149	145	192	282	367	437	(9)
(10)		CDD10.0	376	0	0	1	3	14	52	110	113	63	18	2	0	(10)
(11)		CDD18.3	1	0	0	0	0	0	0	1	0	0	0	0	0	(11)
(12)		CDH23.3	1	0	0	0	0	0	0	1	0	0	0	0	0	(12)
(13)		CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0	(13)
(14)	Wind	WSAvg	6.5	8.1	7.8	7.1	6.1	5.7	5.4	4.7	5.1	6.1	7.2	7.3	7.8	(14)
(15)	Precipitation	PrecAvg	836	83	57	55	56	58	57	71	68	66	94	87	83	(15)
(16)		PrecMax	1034	221	119	149	145	126	136	141	146	240	224	195	201	(16)
(17)		PrecMin	522	15	6	15	0	10	15	20	11	15	7	25	19	(17)
(18)		PrecStd	122	47	37	28	40	27	34	38	34	46	51	49	44	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	11.0	12.1	14.2	15.4	17.4	19.6	21.9	20.7	19.9	15.8	12.9	11.7	(19)
(20)			MCWB	9.2	10.0	10.1	11.2	13.4	14.8	17.2	16.6	16.1	13.0	11.3	10.3	(20)
(21)		2%	DB	9.4	10.5	11.8	12.9	15.4	17.4	19.3	18.7	17.2	14.2	11.5	10.2	(21)
(22)			MCWB	8.1	8.7	8.6	9.9	12.3	13.6	15.9	15.1	14.0	12.2	10.4	9.2	(22)
(23)		5%	DB	8.1	8.8	10.1	11.4	13.6	16.0	17.9	17.5	15.8	13.1	10.7	9.1	(23)
(24)			MCWB	7.0	7.2	7.6	8.7	10.9	13.0	15.0	14.7	13.4	11.7	9.8	8.3	(24)
(25)		10%	DB	7.1	7.5	8.7	10.1	12.3	14.6	16.6	16.4	14.8	12.4	9.9	8.2	(25)
(26)			MCWB	6.3	6.0	6.8	8.1	10.1	12.4	14.5	14.2	12.9	11.2	9.2	7.5	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	9.7	10.4	10.7	12.1	14.3	16.3	18.3	17.5	16.5	13.9	11.7	10.7	(27)
(28)			MCDWB	10.6	11.9	13.3	14.4	16.4	18.2	20.4	19.4	19.0	15.1	12.2	11.3	(28)
(29)		2%	WB	8.4	8.8	9.2	10.5	12.7	14.7	16.8	16.2	15.0	12.9	10.8	9.5	(29)
(30)			MCDWB	9.2	10.3	11.1	12.3	14.6	16.4	18.5	17.6	16.4	13.6	11.3	10.1	(30)
(31)		5%	WB	7.2	7.5	8.0	9.2	11.6	13.7	15.8	15.5	14.1	12.2	10.1	8.5	(31)
(32)			MCDWB	7.9	8.6	9.7	10.8	13.1	15.2	17.1	16.7	15.2	12.8	10.5	9.1	(32)
(33)		10%	WB	6.4	6.4	7.0	8.3	10.6	12.8	15.0	14.8	13.4	11.6	9.3	7.6	(33)
(34)			MCDWB	7.0	7.3	8.5	9.6	11.9	14.1	16.2	15.8	14.2	12.2	9.9	8.2	(34)
(35)	Mean Daily Temperature Range			MDBR	3.8	4.4	5.2	5.3	5.6	5.5	5.5	5.3	4.7	4.3	3.9	(35)
(36)		5% DB	MCDBR	5.4	5.7	7.5	7.5	7.5	7.3	7.4	7.1	6.8	5.4	4.7	4.9	(36)
(37)			MCWBR	5.2	4.7	5.4	5.2	5.1	4.9	4.7	4.4	4.7	4.5	4.6	4.7	(37)
(38)		5% WB	MCDWB	5.0	5.5	7.0	6.8	6.8	6.4	6.5	5.8	5.8	4.9	4.4	4.8	(38)
(39)			MCWBR	4.9	4.7	5.3	5.1	5.1	4.8	4.7	4.2	4.5	4.5	4.5	4.9	(39)
(40)	Clear-Sky Solar Irradiance	taub		0.304	0.325	0.353	0.374	0.370	0.371	0.373	0.362	0.347	0.334	0.305	0.286	(40)
(41)		taud		2.289	2.387	2.359	2.329	2.393	2.414	2.411	2.449	2.498	2.463	2.341	2.230	(41)
(42)		Ebn at Noon		577	733	803	840	868	870	860	846	808	715	573	485	(42)
(43)		Edh at Noon		51	69	91	108	108	107	106	95	79	64	47	40	(43)
(44)	All-Sky Solar Radiation	RadAvg		0.46	1.11	2.18	3.62	4.87	4.80	4.63	3.70	2.56	1.35	0.60	0.33	(44)
(45)		RadStd		0.06	0.10	0.26	0.35	0.27	0.38	0.36	0.25	0.19	0.13	0.06	0.04	(45)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (32 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page