

RINNS OF ISLAY LH, United Kingdom

WMO: 031020

Lat: 55.673N

Lon: 6.513W

Elev: 23

StdP: 101.05

Time Zone: 0.00 (EUW)

Period: 86-98

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	0.4	1.6	-4.2	2.7	2.5	-2.9	3.0	2.9	24.8	5.5	22.9	6.2	5.9	50	0.885

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	3.0	18.1	15.0	16.7	14.3	15.7	13.9	15.7	17.3	15.0	16.1	14.4	15.3	5.4	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
15.0	10.7	16.3	14.5	10.3	15.6	13.9	9.9	14.9	44.0	17.5	42.0	16.1	40.3	15.5	19.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 20.8	18.5	15.9	DB	-1.6	20.0	1.7	2.2	-2.8	21.6	-3.8	22.9	-4.7	24.1	-5.9	25.7	(4)
(5)			WB	-2.5	17.2	1.6	1.1	-3.7	18.0	-4.6	18.7	-5.5	19.3	-6.7	20.1	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	9.4	6.3	5.6	6.4	7.4	9.7	11.6	13.3	13.7	12.6	10.8	8.6	7.0		
	DBStd	3.35	2.16	2.17	1.74	1.63	2.05	1.69	1.43	1.38	1.46	1.98	2.10	2.25		
	HDD10.0	619	116	122	111	78	29	3	0	0	1	16	49	94		
	HDD18.3	3248	373	356	369	328	268	203	157	144	173	235	291	351		
	CDD10.0	414	1	0	0	1	19	51	102	114	78	39	8	2		
	CDD18.3	1	0	0	0	0	0	1	0	0	0	0	0	0		
	CDH23.3	0	0	0	0	0	0	0	0	0	0	0	0	0		
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0		
(14) Wind	WSAvg	8.2	10.3	10.6	9.5	7.2	6.6	5.8	5.8	6.0	7.5	8.9	9.7	10.2		
(15) Precipitation	PrecAvg	1215	125	96	89	76	72	81	85	95	98	131	133	132		
	PrecMax	1491	197	207	185	135	138	157	142	200	193	253	228	261		
	PrecMin	926	28	36	34	33	19	29	30	19	17	38	67	61		
	PrecStd	139	40	43	36	28	33	32	28	41	39	54	38	47		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	11.3	10.9	10.4	12.6	18.2	19.7	20.7	19.7	17.2	15.5	13.6	12.2		
		MCWB	10.2	10.2	9.4	9.7	13.5	15.6	17.0	16.4	14.9	14.0	12.5	11.4		
	2%	DB	10.5	9.9	9.7	11.0	15.6	16.9	17.6	17.8	15.9	14.5	12.7	11.3		
		MCWB	9.7	9.1	8.8	9.3	12.1	13.8	15.0	15.4	14.0	13.3	11.8	10.6		
	5%	DB	9.9	9.1	9.2	10.2	13.5	15.2	16.2	16.4	15.2	13.9	12.1	10.6		
		MCWB	9.2	8.3	8.4	8.9	11.0	12.7	14.3	14.6	13.4	12.8	11.2	9.9		
	10%	DB	9.2	8.5	8.8	9.6	12.3	13.8	15.2	15.5	14.6	13.4	11.5	10.1		
		MCWB	8.5	7.6	8.0	8.5	10.5	12.0	13.6	14.1	13.1	12.3	10.4	9.3		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	10.6	10.4	10.0	10.5	14.1	15.8	17.4	16.8	15.7	14.5	13.0	11.9		
		MCDB	10.9	10.6	10.4	11.4	17.9	19.0	20.4	18.9	16.7	15.1	13.5	12.0		
	2%	WB	10.0	9.4	9.2	9.8	12.3	14.2	15.7	15.7	14.7	13.7	12.1	10.7		
		MCDB	10.4	9.7	9.5	10.5	14.6	16.5	17.2	17.1	15.4	14.2	12.5	11.0		
	5%	WB	9.4	8.5	8.8	9.3	11.5	13.1	14.7	15.1	14.1	13.1	11.4	10.1		
		MCDB	9.8	9.0	9.1	9.9	13.2	14.6	15.7	16.0	14.7	13.7	11.9	10.5		
	10%	WB	8.6	7.9	8.2	8.8	10.7	12.4	13.9	14.5	13.5	12.6	10.7	9.5		
		MCDB	9.1	8.4	8.6	9.4	12.0	13.5	14.9	15.3	14.3	13.2	11.3	10.0		
(35) Mean Daily Temperature Range	5% DB	MDBR	2.8	2.8	2.8	3.2	3.8	3.4	3.1	3.0	3.1	2.8	2.6	2.7		
		MCDBR	3.0	3.0	2.8	3.7	5.3	5.6	4.8	4.1	3.7	3.2	2.6	2.7		
	5% WB	MCWBR	3.2	3.3	2.7	2.9	3.5	3.8	3.2	2.7	2.9	3.2	3.1	3.1		
		MCWBR	3.0	2.8	2.7	3.2	4.6	4.5	4.4	3.5	3.1	2.9	2.6	2.7		
(40) Clear-Sky Solar Irradiance	taub		0.344	0.353	0.372	0.383	0.387	0.378	0.381	0.367	0.365	0.349	0.334	0.331		
		taud	2.198	2.292	2.311	2.328	2.367	2.430	2.428	2.479	2.468	2.417	2.272	2.171		
	Ebn at Noon		537	704	788	837	855	867	856	847	795	707	552	451		
		Edh at Noon	61	79	97	110	112	107	105	94	83	69	55	49		
(44) All-Sky Solar Radiation	RadAvg		0.47	1.16	2.28	3.85	4.99	5.08	4.72	3.82	2.56	1.39	0.60	0.33		
	RadStd		0.05	0.10	0.17	0.25	0.42	0.48	0.31	0.30	0.15	0.13	0.05	0.03		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (38 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page