

GLASGOW AP, United Kingdom

WMO: 031400

Lat: 55.872N

Lon: 4.433W

Elev: 8

StdP: 101.23

Time Zone: 0.00 (EUW)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-6.0	-3.9	-7.2	2.1	-3.9	-5.8	2.3	-2.2	16.6	7.9	14.6	8.6	0.7	230	0.643

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	7.9	23.2	17.2	21.2	16.2	19.9	15.6	18.2	21.9	17.2	20.2	16.3	19.0	4.2	60

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
16.9	12.1	19.8	16.0	11.4	18.9	15.1	10.7	17.8	51.4	21.7	48.5	20.0	45.8	18.8	22.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 12.3	10.7	9.4	DB	-8.8	26.6	3.0	1.7	-10.9	27.8	-12.7	28.8	-14.4	29.8	-16.5	31.0	(4)
(5)			WB	-9.1	20.0	3.0	1.1	-11.2	20.8	-13.0	21.4	-14.6	22.0	-16.8	22.8	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	9.2	4.1	4.5	5.8	8.0	10.8	13.4	15.2	14.8	12.8	9.7	6.5	4.1	(6)	
	DBStd	4.94	3.28	2.98	2.73	2.59	2.74	2.24	2.16	2.18	2.27	2.89	3.32	4.18	(7)	
	HDD10.0	901	182	156	133	68	23	1	0	0	4	40	111	183	(8)	
	HDD18.3	3352	440	388	390	309	234	148	102	113	167	266	356	440	(9)	
	CDD10.0	597	1	1	2	9	47	104	161	148	87	32	6	1	(10)	
	CDD18.3	7	0	0	0	0	0	1	4	3	0	0	0	0	(11)	
	CDH23.3	56	0	0	0	0	3	10	27	16	1	0	0	0	(12)	
	CDH26.7	4	0	0	0	0	0	1	2	1	0	0	0	0	(13)	
(14) Wind	WSAvg	4.2	4.6	4.8	4.7	4.4	4.3	4.0	3.6	3.6	3.9	4.1	4.0	4.3	(14)	
(15) Precipitation	PrecAvg	1170	130	93	102	64	70	65	68	88	117	129	125	124	(15)	
	PrecMax	1533	278	250	218	129	166	118	165	186	288	280	205	278	(16)	
	PrecMin	882	18	9	20	5	7	13	12	9	11	33	19	30	(17)	
	PrecStd	155	62	57	49	29	38	27	32	44	56	64	49	57	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	12.2	12.2	14.2	19.0	23.1	24.8	26.2	25.4	21.1	17.2	14.7	13.1	(19)	
		MCWB	10.7	10.5	10.2	12.7	15.6	17.2	19.0	19.0	16.4	14.7	13.1	11.8	(20)	
	2%	DB	11.0	11.1	12.2	15.9	20.0	21.9	23.2	22.1	19.1	16.0	13.2	11.9	(21)	
		MCWB	9.7	9.6	9.5	11.2	14.5	15.9	17.6	17.2	15.3	13.9	11.7	10.7	(22)	
	5%	DB	10.0	10.1	11.1	14.0	17.8	19.8	21.2	20.1	17.9	15.0	12.2	10.9	(23)	
		MCWB	9.0	8.8	8.8	10.2	13.0	15.0	16.5	16.0	14.9	13.2	10.7	9.7	(24)	
	10%	DB	9.0	9.1	10.1	12.8	15.8	18.0	19.8	19.0	16.9	14.1	11.2	9.9	(25)	
		MCWB	8.2	7.9	8.3	9.6	11.7	13.9	15.8	15.6	14.3	12.3	9.8	8.9	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	11.1	11.1	11.4	13.5	17.1	18.3	19.8	19.5	17.7	15.4	13.4	12.1	(27)	
		MCDB	12.3	12.1	13.7	17.3	21.8	23.1	24.6	23.9	20.1	16.8	14.4	13.1	(28)	
	2%	WB	10.0	10.0	10.3	11.9	14.9	16.7	18.4	17.9	16.4	14.3	12.2	11.0	(29)	
		MCDB	10.7	10.7	11.6	14.9	19.2	20.6	22.3	20.9	18.2	15.7	13.3	12.0	(30)	
	5%	WB	9.1	9.0	9.4	10.9	13.5	15.4	17.3	17.0	15.4	13.5	11.2	10.0	(31)	
		MCDB	9.7	10.0	10.7	13.4	16.8	18.7	20.4	19.4	17.2	14.8	12.4	10.7	(32)	
	10%	WB	8.0	8.0	8.5	10.0	12.3	14.4	16.3	16.1	14.6	12.7	10.2	8.8	(33)	
		MCDB	9.0	9.1	9.9	12.0	15.3	17.3	19.0	18.4	16.4	14.0	11.2	9.6	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	5.2	6.0	6.9	7.9	8.5	8.0	7.9	8.1	7.3	6.6	6.0	5.6	(35)	
		MCDBR	5.3	5.8	7.7	10.0	11.9	11.5	11.2	10.3	8.9	6.7	5.8	5.5	(36)	
	5% WB	MCWBR	5.0	5.0	5.5	6.4	7.0	6.6	6.2	6.0	5.8	5.3	5.2	5.3	(37)	
		MCWBR	5.2	5.5	6.6	8.8	10.3	9.8	9.5	8.8	7.3	6.0	5.6	5.7	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.333	0.344	0.369	0.387	0.390	0.385	0.386	0.370	0.362	0.345	0.324	0.317	(40)	
		taud	2.205	2.307	2.280	2.270	2.308	2.353	2.356	2.411	2.437	2.415	2.297	2.185	(41)	
	Ebn at Noon		548	714	787	830	851	859	849	841	795	710	566	466	(42)	
		Edh at Noon	59	77	100	116	119	115	112	100	85	69	53	47	(43)	
(44) All-Sky Solar Radiation	RadAvg		0.47	1.13	2.22	3.63	4.69	4.59	4.39	3.53	2.45	1.32	0.62	0.35	(44)	
	RadStd		0.07	0.14	0.18	0.29	0.43	0.50	0.44	0.28	0.19	0.18	0.06	0.04	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (57 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page