

GLEN OGLE, United Kingdom

WMO: 031480

Lat: 56.4249N

Lon: 4.3232W

Elev: 564

StdP: 94.73

Time Zone: 0.00 (EUW)

Period: 96-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-4.9	-4.1	-9.9	1.7	-1.0	-8.1	2.0	-2.0	38.2	3.1	32.8	1.2	6.9	320	0.963

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	5.0	18.4	13.1	16.7	12.4	15.2	12.1	14.7	16.4	13.8	15.4	13.0	14.4	5.8	160

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
14.1	10.8	15.1	13.2	10.1	14.3	12.3	9.5	13.4	43.1	16.5	40.6	15.6	38.2	14.4	21.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 27.6	21.8	18.0	DB	-6.2	21.7	1.4	1.8	-7.1	23.0	-7.9	24.1	-8.7	25.1	-9.7	26.4	(4)
(5)			WB	-6.9	16.7	1.3	1.5	-7.8	17.8	-8.6	18.7	-9.3	19.6	-10.2	20.7	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
Temperatures, Degree-Days and Degree-Hours	DBAvg	5.7	1.0	1.1	2.0	4.2	7.0	9.4	11.2	11.0	9.4	6.3	3.3	1.7	
	DBStd	4.58	2.57	2.79	2.91	2.84	3.15	2.55	2.43	2.10	2.22	2.40	2.73	2.92	
	HDD10.0	1733	279	248	248	176	105	41	12	11	37	117	202	258	
	HDD18.3	4629	537	482	506	424	351	269	221	229	269	374	452	516	
	CDD10.0	146	0	0	1	1	12	22	50	41	17	1	0	0	
	CDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0	
	CDH23.3	1	0	0	0	0	0	1	0	0	0	0	0	0	
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0	
Wind	WSAvg	8.1	9.7	9.4	8.6	7.6	7.1	6.5	6.4	6.9	7.4	8.4	9.4	9.7	
Precipitation	PrecAvg	1637	220	163	145	101	88	97	89	96	132	176	162	166	
	PrecMax	1956	409	361	329	156	156	185	159	247	220	305	236	327	
	PrecMin	1208	63	31	63	36	15	20	24	22	49	27	77	47	
	PrecStd	229	87	97	65	29	45	39	32	57	56	79	48	83	
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	8.6	9.4	11.8	14.5	19.1	19.4	20.9	20.1	16.8	12.7	10.9	10.0	
		MCWB	8.0	7.9	7.4	8.7	12.2	13.1	14.6	14.8	13.0	11.8	10.0	9.0	
	2%	DB	7.2	7.9	8.6	11.7	16.3	17.0	18.5	17.0	14.8	11.6	9.4	8.4	
		MCWB	6.8	7.0	6.2	7.6	10.8	11.7	13.5	13.2	12.7	11.0	8.9	7.7	
	5%	DB	6.1	6.5	7.1	9.8	13.8	15.0	16.7	15.2	13.6	10.6	8.2	7.2	
		MCWB	5.7	5.9	5.8	6.9	9.5	11.5	12.7	12.7	11.9	9.9	7.7	6.6	
	10%	DB	5.0	5.3	5.9	8.1	11.7	13.2	15.0	13.9	12.4	9.6	7.2	6.0	
		MCWB	4.6	4.7	4.9	6.1	8.2	10.2	12.4	12.1	11.0	9.0	6.7	5.4	
	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	8.2	8.6	8.6	10.2	13.8	14.7	16.2	16.0	14.7	12.2	10.3	9.4
			MCDB	8.4	8.8	10.5	12.4	17.1	17.2	18.6	17.9	15.4	12.4	10.6	9.6
2%		WB	7.0	7.2	7.2	8.7	11.7	13.3	14.7	14.5	13.5	11.2	9.1	8.0	
		MCDB	7.2	7.5	8.1	10.5	14.9	16.0	16.6	15.9	14.1	11.5	9.3	8.3	
5%		WB	5.9	6.0	6.1	7.5	10.1	11.9	13.8	13.6	12.3	10.2	7.8	6.8	
		MCDB	6.1	6.4	6.7	9.0	12.7	13.7	15.6	14.7	13.0	10.4	8.1	7.1	
10%		WB	4.7	4.8	5.0	6.5	9.0	10.9	12.9	12.6	11.4	9.2	6.8	5.5	
		MCDB	5.0	5.3	5.8	7.8	11.2	12.5	14.4	13.6	12.1	9.5	7.1	5.8	
Mean Daily Temperature Range	5% DB	MDBR	3.4	3.6	4.0	5.0	5.8	5.4	5.0	4.5	4.2	3.5	3.5	3.5	
		MCDBR	5.0	5.0	5.5	7.3	8.6	8.1	7.3	6.1	5.5	4.5	5.0	5.4	
		MCWBR	5.0	4.8	4.2	4.5	4.9	5.0	4.2	3.8	3.9	4.2	5.1	5.4	
	5% WB	MCDBR	4.9	4.8	5.1	6.1	7.5	6.5	5.9	5.2	4.8	4.4	4.9	5.3	
		MCWBR	5.1	4.8	4.6	4.3	4.7	4.6	4.1	4.0	4.2	4.4	5.1	5.4	
Clear-Sky Solar Irradiance	taub	0.291	0.308	0.330	0.347	0.350	0.348	0.349	0.335	0.326	0.313	0.288	0.274		
	taud	2.252	2.377	2.368	2.364	2.391	2.418	2.416	2.465	2.503	2.486	2.346	2.201		
	Ebn at Noon	600	760	833	872	889	894	885	877	836	751	610	512		
	Edh at Noon	53	70	90	105	108	107	105	94	78	62	48	42		
All-Sky Solar Radiation	RadAvg	0.43	1.07	2.10	3.49	4.58	4.46	4.27	3.40	2.34	1.25	0.56	0.33		
	RadStd	0.07	0.14	0.20	0.30	0.40	0.48	0.42	0.29	0.18	0.17	0.05	0.04		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days				
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only		N/A	N/A	+1.12	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (49 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page