

EDINBURGH AP, United Kingdom

WMO: 031600

Lat: 55.950N

Lon: 3.373W

Elev: 135

StdP: 14.62

Time Zone: 0.00 (EUW)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 22.7	(c) 26.2	(d) 19.3	(e) 14.6	(f) 26.0	(g) 22.5	(h) 17.0	(i) 29.7	(j) 35.3	(k) 46.5	(l) 31.9	(m) 46.5	(n) 2.9	(o) 250	(p) 0.659

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	14.6	71.9	62.2	69.5	61.2	66.6	59.3	64.0	69.7	62.4	67.3	60.9	65.1	10.7	260

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
61.7	82.6	66.5	60.5	79.2	65.1	58.9	74.7	63.6	29.3	70.0	28.1	67.6	27.1	64.8	77.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
27.6	23.9	21.0	17.1	78.0	4.7	3.8	13.7	80.7	11.0	82.9	8.3	85.1	4.9	87.8
			16.6	67.7	4.7	2.4	13.2	69.4	10.5	70.9	7.9	72.2	4.5	74.0
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	48.2	39.2	40.0	42.1	45.9	50.5	55.5	58.9	58.6	55.0	49.5	43.5	39.3	(6)
	DBStd	8.78	5.65	5.37	5.18	4.78	4.68	3.81	3.59	3.67	4.18	5.24	5.80	7.03	(7)
	HDD50	1678	334	283	249	139	49	3	0	0	7	73	206	335	(8)
	HDD65	6138	798	701	710	574	449	284	194	202	300	482	646	798	(9)
	CDD50	1026	1	2	4	15	65	169	275	267	158	57	10	3	(10)
	CDD65	7	0	0	0	0	0	0	3	3	1	0	0	0	(11)
	CDH74	48	0	0	0	0	1	4	28	13	2	0	0	0	(12)
	CDH80	4	0	0	0	0	0	0	2	2	0	0	0	0	(13)
(14) Wind	WSAvg	9.7	10.7	11.0	11.0	10.0	9.8	9.1	8.3	8.4	9.1	9.4	9.3	10.0	(14)
(15) Precipitation	PrecAvg	26.0	2.4	1.7	1.9	1.6	2.0	2.0	2.2	2.3	2.5	2.7	2.4	2.3	(15)
	PrecMax	33.4	4.7	4.4	3.6	3.7	5.4	5.2	6.1	4.7	5.9	5.2	7.8	5.1	(16)
	PrecMin	17.2	0.7	0.1	0.6	0.2	0.4	0.2	0.2	0.2	0.3	0.6	0.4	0.4	(17)
	PrecStd	4.0	1.1	1.1	0.9	0.8	1.1	1.2	1.3	1.2	1.5	1.3	1.5	1.1	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	54.6	55.8	58.8	64.2	70.2	73.4	78.0	75.2	71.8	64.4	59.1	56.2	(19)
		MCWB	51.1	52.0	51.3	55.1	59.1	61.3	64.5	64.7	62.2	58.2	55.5	53.2	(20)
	2%	DB	51.9	53.1	55.2	59.3	64.8	68.5	73.0	70.5	67.6	61.3	56.6	53.8	(21)
		MCWB	49.2	49.8	49.6	52.1	55.9	59.4	63.2	62.1	60.3	56.7	53.5	50.9	(22)
	5%	DB	50.0	50.7	52.5	57.1	61.3	66.1	69.6	68.0	64.6	59.4	54.0	51.8	(23)
		MCWB	47.4	47.6	47.8	50.6	54.3	57.8	61.7	60.6	58.0	55.4	50.9	49.0	(24)
	10%	DB	48.2	48.5	50.4	54.6	59.0	63.4	66.4	66.1	62.6	57.5	52.1	49.7	(25)
		MCWB	46.0	45.7	46.4	48.8	52.5	56.5	59.5	59.5	57.1	53.7	49.1	47.4	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	51.8	53.0	52.8	55.9	60.7	64.1	66.9	65.9	64.0	59.4	55.8	53.8	(27)
		MCDB	54.4	55.3	57.3	61.6	67.6	70.4	74.9	72.2	69.8	62.6	58.3	56.4	(28)
	2%	WB	49.7	50.1	50.5	53.2	57.4	60.8	64.4	63.6	61.5	57.6	53.8	51.5	(29)
		MCDB	51.5	52.3	54.0	58.6	63.3	66.7	70.5	68.6	65.8	60.9	56.5	54.0	(30)
	5%	WB	47.6	48.1	48.8	51.2	55.3	59.0	62.6	62.1	59.4	55.9	51.7	49.5	(31)
		MCDB	49.7	50.9	52.1	55.9	60.5	64.1	67.6	66.3	63.1	59.0	54.2	51.6	(32)
	10%	WB	45.7	45.9	46.9	49.6	53.2	57.3	60.8	60.7	57.7	54.5	49.9	47.2	(33)
		MCDB	47.9	48.4	50.3	53.7	58.1	62.3	65.3	64.2	61.4	57.6	52.0	49.4	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	9.5	11.0	12.4	13.8	14.5	13.9	14.6	14.4	13.7	12.5	11.2	10.3	(35)
		MCDBR	10.2	11.1	14.6	17.5	18.2	18.4	19.7	17.1	16.8	13.4	11.2	11.1	(36)
	5% WB	MCWBR	9.4	9.4	10.4	11.1	10.9	10.8	11.3	9.8	10.6	10.1	9.7	10.3	(37)
		MCWBR	10.2	10.9	12.8	16.3	16.6	16.2	16.8	14.8	14.7	12.2	11.2	11.0	(38)
(40) Clear-Sky Solar Irradiance	taub		0.325	0.339	0.370	0.390	0.390	0.389	0.389	0.374	0.360	0.343	0.319	0.308	(40)
		taud	2.236	2.331	2.277	2.249	2.298	2.332	2.338	2.388	2.434	2.417	2.317	2.213	(41)
	Ebn at Noon		178	229	249	262	270	271	268	265	252	225	182	153	(42)
		Edh at Noon	18	24	32	37	38	37	36	32	27	22	16	15	(43)
(44) All-Sky Solar Radiation	RadAvg		165	368	693	1132	1496	1460	1407	1130	803	438	213	121	(44)
	RadStd		24	35	80	122	103	133	140	84	59	52	21	12	(45)

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (52 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page