

DISHFORTH, United Kingdom

WMO: 032610

Lat: 54.137N

Lon: 1.420W

Elev: 117

StdP: 14.63

Time Zone: 0.00 (EUW)

Period: 94-16

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	24.7	27.4	21.0	15.8	29.6	23.3	17.6	31.2	34.2	47.4	30.0	47.3	3.9	340	0.624

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	16.4	77.1	64.5	73.7	62.9	70.6	61.1	65.7	73.5	64.1	71.6	62.5	68.8	9.4	150

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
62.7	85.5	69.1	61.1	80.7	66.9	59.7	76.7	65.3	30.5	73.4	29.3	72.0	28.1	69.0	79.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 27.2	23.4	20.6	DB	19.8	83.2	4.2	2.7	16.7	85.1	14.3	86.7	11.9	88.3	8.8	90.2	(4)
(5)			WB	19.2	69.6	4.1	2.8	16.2	71.6	13.8	73.2	11.4	74.8	8.4	76.8	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	49.2	39.6	40.1	42.7	46.7	51.7	56.8	61.0	60.4	56.2	50.6	44.2	39.3	(6)	
	DBStd	9.34	5.52	5.62	5.11	5.15	5.04	4.69	4.34	4.33	4.11	5.11	5.66	6.68	(7)	
	HDD50	1579	324	281	230	124	40	3	0	0	3	54	186	334	(8)	
	HDD65	5817	789	699	690	549	412	250	140	155	266	446	625	796	(9)	
	CDD50	1271	1	2	5	25	93	206	340	324	188	73	11	3	(10)	
	CDD65	34	0	0	0	0	0	4	15	14	1	0	0	0	(11)	
	CDH74	269	0	0	0	0	4	32	128	93	11	1	0	0	(12)	
	CDH80	31	0	0	0	0	0	3	12	16	0	0	0	0	(13)	
(14) Wind	WSAvg	9.1	10.6	10.7	10.1	9.2	9.2	8.0	7.6	7.8	8.0	8.9	9.3	9.6	(14)	
(15) Precipitation	PrecAvg	27.0	2.4	1.9	1.6	2.0	1.9	2.4	2.2	2.7	2.2	2.5	2.7	2.6	(15)	
	PrecMax	37.8	5.0	3.5	3.5	5.5	3.8	6.4	5.0	6.1	4.5	5.8	5.4	5.1	(16)	
	PrecMin	20.4	0.3	0.4	0.4	0.2	0.4	0.3	0.7	0.6	0.6	0.8	0.9	0.8	(17)	
	PrecStd	4.3	1.1	0.9	0.9	1.4	0.8	1.5	1.0	1.3	1.2	1.1	1.1	1.1	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	54.9	56.1	60.3	67.2	73.2	78.3	81.5	82.4	75.4	66.2	59.5	56.6	(19)	
		MCWB	51.6	51.7	51.4	56.3	61.7	65.7	64.9	65.3	63.5	59.6	55.9	53.2	(20)	
	2%	DB	52.4	53.2	56.6	62.1	68.7	72.9	77.5	76.3	69.9	62.8	56.9	53.9	(21)	
		MCWB	49.3	49.3	50.1	53.2	58.3	61.9	64.6	64.5	60.6	57.7	53.4	51.1	(22)	
	5%	DB	50.1	51.0	53.9	59.1	64.6	69.7	74.2	72.0	66.8	60.6	54.9	51.7	(23)	
		MCWB	47.1	47.2	48.7	51.3	55.9	59.9	63.3	62.4	58.9	56.4	51.7	49.3	(24)	
	10%	DB	48.2	49.0	51.7	56.4	61.4	66.4	70.5	69.1	64.1	58.7	52.8	49.2	(25)	
		MCWB	45.5	45.4	46.8	49.9	53.8	58.2	61.4	60.8	57.3	54.9	50.0	46.8	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	52.0	52.1	53.3	57.4	62.5	67.4	67.8	67.8	65.2	61.0	56.6	53.6	(27)	
		MCDB	54.4	55.3	57.9	64.2	71.7	76.5	76.8	76.2	72.8	64.3	59.0	55.7	(28)	
	2%	WB	49.6	49.8	51.2	54.6	59.2	63.1	65.6	65.5	62.5	59.0	54.2	51.6	(29)	
		MCDB	52.0	52.8	55.4	60.2	67.0	70.3	74.1	72.8	68.1	61.9	56.4	53.6	(30)	
	5%	WB	47.6	47.7	49.3	52.4	56.8	60.9	64.1	63.8	60.3	57.2	52.1	49.4	(31)	
		MCDB	49.8	50.7	53.4	57.8	63.1	67.5	72.1	70.8	64.6	59.9	54.2	51.5	(32)	
	10%	WB	45.6	45.8	47.4	50.4	54.8	59.1	62.4	62.2	58.5	55.4	50.3	47.0	(33)	
		MCDB	47.9	48.6	51.2	55.4	60.2	65.2	69.2	67.6	62.6	58.1	52.4	49.0	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	9.0	10.8	13.1	15.2	15.7	15.8	16.4	15.6	14.7	12.2	10.5	9.5	(35)	
		MCDBR	11.2	12.1	16.5	19.3	21.1	21.7	22.7	20.1	19.1	13.6	11.7	10.9	(36)	
	5% WB	MCWBR	10.2	9.7	11.2	11.7	12.3	12.0	11.1	10.1	10.8	9.6	9.9	10.0	(37)	
		MCWBR	11.0	11.6	15.5	17.3	19.7	19.2	20.2	17.4	16.7	12.7	11.3	10.6	(38)	
(40) Clear-Sky Solar Irradiance	taub	taub	0.321	0.337	0.368	0.395	0.394	0.398	0.398	0.386	0.365	0.347	0.321	0.307	(40)	
		taud	2.317	2.367	2.287	2.230	2.275	2.292	2.296	2.348	2.410	2.431	2.379	2.295	(41)	
	Ebn at Noon	Ebn at Noon	198	239	255	263	270	270	267	264	254	232	198	177	(42)	
		Edh at Noon	18	24	32	39	39	39	38	34	29	23	17	16	(43)	
(44) All-Sky Solar Radiation	RadAvg	RadAvg	197	402	745	1173	1492	1525	1474	1217	884	495	244	153	(44)	
	RadStd	RadStd	23	46	95	131	88	135	137	79	80	43	25	15	(45)	

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (58 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page