

LINTON ON OUSE, United Kingdom

WMO: 032660

Lat: 54.0453N

Lon: 1.2511W

Elev: 16

StdP: 101.13

Time Zone: 0.00 (EUW)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-4.1	-2.6	-6.2	2.2	-1.0	-4.9	2.5	-0.2	14.6	8.7	13.0	8.4	1.7	310	0.605

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	8.9	25.6	18.0	23.6	17.1	21.9	16.2	18.9	23.5	17.9	22.2	17.0	20.8	4.2	100

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
17.1	12.3	20.8	16.2	11.6	19.7	15.4	11.0	18.7	53.6	23.4	50.5	22.2	47.8	20.8	26.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
11.3	9.8	8.7	-7.3	29.0	2.6	1.5	-9.2	30.1	-10.7	31.0	-12.2	31.9	-14.1	33.0	
			DB												
			WB	-7.7	21.1	2.6	1.8	-9.6	22.3	-11.1	23.4	-12.6	24.4	-14.5	25.7

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	9.9	4.3	4.7	6.2	8.5	11.5	14.4	16.6	16.2	13.8	10.6	6.9	4.4
	DBStd	5.32	3.16	3.24	2.93	2.92	2.92	2.54	2.41	2.38	2.34	2.92	3.21	3.82
	HDD10.0	836	177	151	121	62	18	1	0	0	1	28	101	176
	HDD18.3	3117	434	383	375	295	213	121	67	74	138	241	344	432
	CDD10.0	787	1	2	4	17	64	133	203	194	114	46	7	2
	CDD18.3	25	0	0	0	0	0	3	12	9	1	0	0	0
	CDH23.3	192	0	0	0	1	5	28	88	60	9	1	0	0
	CDH26.7	24	0	0	0	0	0	3	9	11	1	0	0	0
Wind	WSAvg	3.8	4.4	4.4	4.3	3.9	3.8	3.4	3.3	3.4	3.5	3.8	3.9	4.0
Precipitation	PrecAvg	685	60	47	41	51	48	60	56	69	56	63	68	65
	PrecMax	959	127	88	90	140	97	162	128	155	115	147	137	129
	PrecMin	518	8	10	9	5	11	8	18	14	15	21	22	20
	PrecStd	109	28	22	22	35	21	37	25	32	30	28	29	28
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	13.2	13.9	15.9	20.8	23.7	26.8	27.9	28.3	24.6	19.7	15.6	14.2
		MCWB	10.9	11.2	10.6	13.5	16.8	18.9	18.5	18.9	17.6	16.1	13.1	12.0
	2%	DB	11.6	12.1	14.0	17.3	21.2	23.4	25.8	24.8	21.5	17.5	14.1	12.6
		MCWB	9.6	9.7	10.3	11.8	14.9	16.8	18.2	18.0	16.1	14.3	11.8	10.8
	5%	DB	10.2	10.8	12.5	15.4	18.8	21.4	23.8	22.6	19.7	16.2	12.8	11.3
		MCWB	8.4	8.5	9.4	10.8	13.6	15.6	17.2	16.9	15.0	13.5	10.9	9.6
	10%	DB	9.1	9.7	11.2	13.8	16.9	19.6	21.8	20.9	18.2	15.1	11.6	9.9
		MCWB	7.5	7.6	8.4	10.0	12.3	14.7	16.4	15.8	14.1	12.7	10.0	8.5
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	11.2	11.3	12.0	14.3	17.6	20.2	20.2	19.9	18.6	16.5	13.6	12.2
		MCDB	12.9	13.3	14.3	18.4	22.8	24.5	25.7	25.1	23.2	18.9	15.1	13.5
	2%	WB	9.9	10.0	10.8	12.7	15.5	17.6	18.9	18.6	17.0	15.1	12.3	11.0
		MCDB	11.5	11.9	13.3	16.4	19.8	21.4	23.7	23.0	20.2	17.0	13.7	12.4
	5%	WB	8.7	8.9	9.7	11.4	14.2	16.3	17.9	17.7	15.8	14.0	11.2	9.8
		MCDB	10.1	10.6	12.0	14.7	18.0	20.2	22.5	21.6	18.3	15.7	12.5	11.1
	10%	WB	7.6	7.8	8.7	10.3	13.0	15.2	16.9	16.8	14.9	13.0	10.1	8.5
		MCDB	8.9	9.5	11.0	13.3	16.3	18.8	21.0	20.0	17.3	14.7	11.4	9.8
Mean Daily Temperature Range	5% DB	MDBR	5.0	6.1	7.2	8.5	8.7	8.5	8.9	8.5	8.1	6.9	5.8	5.3
		MCDBR	6.1	6.8	9.1	11.1	11.9	12.1	12.4	11.1	10.5	7.7	6.3	6.0
		MCWBR	5.5	5.4	6.1	6.5	6.7	6.5	5.9	5.4	5.9	5.2	5.3	5.3
	5% WB	MCDBR	6.1	6.5	8.2	10.2	11.2	10.6	11.2	9.8	8.8	7.1	6.0	5.8
		MCWBR	5.6	5.5	6.0	6.5	6.7	6.7	5.8	5.2	5.6	5.4	5.3	5.4
Clear-Sky Solar Irradiance	taub	0.320	0.337	0.368	0.395	0.394	0.399	0.399	0.387	0.366	0.348	0.322	0.307	
	taud	2.331	2.378	2.296	2.233	2.276	2.289	2.293	2.347	2.411	2.437	2.390	2.307	
	Ebn at Noon	631	754	804	829	852	850	841	830	802	732	628	563	
	Edh at Noon	58	76	101	123	124	124	121	108	90	71	54	49	
All-Sky Solar Radiation	RadAvg	0.63	1.28	2.36	3.70	4.70	4.81	4.66	3.85	2.80	1.57	0.78	0.49	
	RadStd	0.07	0.15	0.30	0.42	0.28	0.43	0.44	0.25	0.25	0.14	0.08	0.05	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (60 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page