

FYLINGDALES, United Kingdom

WMO: 032810

Lat: 54.359N

Lon: 0.672W

Elev: 860

StdP: 14.25

Time Zone: 0.00 (EUW)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	25.8	27.7	21.8	16.9	29.7	24.1	18.8	30.8	39.3	45.7	35.3	43.3	9.6	220	0.749

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	12.7	72.5	62.6	69.4	61.1	66.7	59.4	64.3	69.9	62.5	67.5	60.8	64.9	11.9	210

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
62.0	85.9	66.2	60.4	81.0	64.4	58.9	76.6	62.7	29.8	70.0	28.5	67.6	27.3	65.0	74.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
Min		Max		Min	Max		Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
32.0	28.4	25.2	DB	22.6	78.2	2.9	2.8	20.5	80.2	18.8	81.9	17.1	83.4	15.0	85.5
			WB	22.2	67.9	2.6	2.6	20.3	69.8	18.7	71.3	17.2	72.8	15.3	74.7

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	46.6	37.1	37.6	40.0	43.9	48.7	53.5	58.1	57.6	53.7	48.3	41.9	37.7
	DBStd	9.04	4.61	5.16	5.30	5.68	5.48	4.89	4.66	4.36	4.26	4.66	5.03	5.50
	HDD50	2092	401	348	312	196	91	18	1	0	12	86	247	380
	HDD65	6742	866	768	774	632	506	346	220	234	340	517	694	845
	CDD50	835	0	0	2	14	50	123	251	236	122	34	3	0
	CDD65	11	0	0	0	0	0	1	5	4	1	0	0	0
	CDH74	44	0	0	0	0	0	9	19	14	2	0	0	0
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0
(14) Wind	WSAvg	12.6	14.3	14.2	13.1	12.0	12.1	10.9	10.5	11.3	11.9	13.4	13.5	14.2
(15) Precipitation	PrecAvg	28.0	2.5	2.0	1.6	2.0	1.8	2.5	2.1	2.6	2.3	2.6	3.2	2.8
	PrecMax	38.7	5.7	3.5	4.7	5.6	4.1	7.4	3.9	6.0	4.6	5.2	6.5	4.7
	PrecMin	20.0	0.6	0.2	0.0	0.1	0.3	0.4	0.5	0.3	0.6	0.7	1.0	1.1
	PrecStd	4.5	1.3	0.9	1.1	1.6	0.9	1.5	1.0	1.4	1.3	1.0	1.3	0.9
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	51.4	53.1	58.0	65.5	69.8	74.7	76.5	75.7	71.8	63.6	56.4	52.8
		MCWB	49.5	49.2	49.8	54.1	58.9	63.5	64.3	64.2	62.0	58.7	55.0	51.2
	2%	DB	48.6	49.9	53.3	59.3	65.2	69.0	72.6	71.1	66.5	59.4	53.5	50.5
		MCWB	46.8	47.5	48.2	51.1	56.0	59.8	62.8	62.7	60.4	56.5	52.2	49.4
	5%	DB	46.4	47.4	50.6	55.8	61.6	65.3	69.7	67.9	63.1	57.2	51.3	48.5
		MCWB	44.8	45.1	46.6	49.8	53.6	57.8	61.4	60.9	58.1	55.1	50.0	47.3
	10%	DB	44.4	45.4	48.2	53.0	58.0	62.3	66.7	65.0	60.4	55.3	49.3	46.0
		MCWB	43.1	43.4	44.8	48.0	51.9	55.8	59.8	59.1	56.4	53.3	48.2	44.8
	0.4%	WB	50.0	50.4	51.5	55.9	60.9	65.1	66.8	67.4	64.5	59.9	55.3	51.7
		MCDB	50.9	51.8	55.1	60.8	67.5	71.9	73.8	71.6	68.9	62.2	56.0	52.3
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	47.3	47.9	49.4	52.8	57.4	61.4	64.3	63.9	61.6	57.3	52.6	49.6
		MCDB	48.4	49.5	52.4	57.7	63.0	67.1	70.2	68.8	65.3	58.8	53.4	50.4
	5%	WB	45.1	45.7	47.4	50.5	54.8	58.7	62.5	62.0	59.2	55.5	50.3	47.5
		MCDB	46.0	47.1	50.1	54.7	59.7	63.5	67.9	66.2	61.9	56.8	51.0	48.4
	10%	WB	43.2	43.9	45.3	48.4	52.5	56.8	60.7	60.3	57.3	53.6	48.4	45.1
		MCDB	44.2	45.3	47.9	52.5	56.8	60.9	65.1	63.8	59.6	54.9	49.1	46.0
(35) Mean Daily Temperature Range	5% DB	MDBR	7.0	8.1	10.0	11.7	12.2	12.2	12.7	12.2	11.1	9.3	7.6	7.1
		MCDBR	10.0	10.2	13.6	16.3	17.8	17.6	16.8	15.5	15.0	11.1	9.3	9.6
		MCWBR	9.8	8.7	9.4	10.2	10.9	10.7	9.4	8.9	9.8	8.7	8.7	9.4
	5% WB	MCDBR	10.1	10.0	12.7	14.9	16.4	16.3	15.4	13.6	13.8	10.7	9.0	9.4
		MCWBR	10.0	9.1	9.8	10.4	11.1	11.0	9.9	9.1	10.3	9.2	8.7	9.4
(40) Clear-Sky Solar Irradiance	taub		0.309	0.327	0.355	0.379	0.376	0.381	0.383	0.373	0.354	0.337	0.312	0.295
	taud		2.358	2.422	2.353	2.305	2.362	2.365	2.365	2.408	2.464	2.480	2.412	2.323
	Ebn at Noon		204	243	260	268	276	275	272	268	259	237	202	182
	Edh at Noon		17	23	30	36	36	36	36	32	27	21	16	15
	RadAvg		193	393	738	1169	1493	1519	1465	1211	876	486	238	148
(45) All-Sky Solar Radiation	RadStd		24	46	96	127	84	132	130	79	79	42	23	15

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (51 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page