

FYLINGDALES, United Kingdom

WMO: 032810

Lat: 54.359N

Lon: 0.672W

Elev: 262

StdP: 98.22

Time Zone: 0.00 (EUW)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-3.4	-2.4	-5.7	2.4	-1.3	-4.4	2.7	-0.7	17.6	7.6	15.8	6.3	4.3	220	0.749

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	7.1	22.5	17.0	20.8	16.2	19.3	15.2	17.9	21.0	16.9	19.7	16.0	18.3	5.3	210

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
16.7	12.3	19.0	15.8	11.6	18.0	14.9	10.9	17.0	51.5	21.1	48.4	19.8	45.7	18.3	23.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
14.3	12.7	11.3	-5.2	25.7	1.6	1.6	-6.4	26.8	-7.4	27.7	-8.3	28.6	-9.4	29.7
			DB											
			WB											
					-5.5	20.0	1.5	1.4	-6.5	21.0	-7.4	21.8	-8.2	22.7
													-9.3	23.7

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	8.1	2.8	3.1	4.5	6.6	9.3	11.9	14.5	14.2	12.1	9.1	5.5	3.2
	DBStd	5.02	2.56	2.87	2.94	3.15	3.05	2.72	2.59	2.42	2.37	2.59	2.79	3.06
	HDD10.0	1162	223	193	173	109	51	10	1	0	7	48	137	211
	HDD18.3	3746	481	427	430	351	281	192	122	130	189	287	386	469
	CDD10.0	464	0	0	1	8	28	68	139	131	68	19	2	0
	CDD18.3	6	0	0	0	0	0	1	3	2	1	0	0	0
	CDH23.3	24	0	0	0	0	0	5	11	8	1	0	0	0
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	5.6	6.4	6.4	5.9	5.4	5.4	4.9	4.7	5.0	5.3	6.0	6.0	6.4
Precipitation	PrecAvg	712	63	51	40	51	45	64	54	67	58	67	81	71
	PrecMax	983	146	90	119	142	104	187	100	152	117	131	165	119
	PrecMin	509	16	6	1	2	8	9	13	8	14	19	25	27
	PrecStd	114	33	22	27	41	24	39	26	36	32	26	33	24
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	10.8	11.7	14.4	18.6	21.0	23.7	24.7	24.3	22.1	17.5	13.6	11.6
		MCWB	9.7	9.6	9.9	12.3	15.0	17.5	17.9	17.9	16.7	14.8	12.8	10.6
	2%	DB	9.2	10.0	11.8	15.2	18.4	20.6	22.6	21.7	19.1	15.2	12.0	10.3
		MCWB	8.2	8.6	9.0	10.6	13.3	15.5	17.1	17.0	15.8	13.6	11.2	9.7
	5%	DB	8.0	8.5	10.3	13.2	16.4	18.5	20.9	19.9	17.3	14.0	10.7	9.1
		MCWB	7.1	7.3	8.1	9.9	12.0	14.3	16.3	16.1	14.5	12.8	10.0	8.5
	10%	DB	6.9	7.4	9.0	11.6	14.5	16.9	19.3	18.4	15.8	12.9	9.6	7.8
		MCWB	6.2	6.4	7.1	8.9	11.0	13.2	15.4	15.0	13.6	11.8	9.0	7.1
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	10.0	10.2	10.8	13.3	16.0	18.4	19.4	19.7	18.1	15.5	13.0	11.0
		MCDB	10.5	11.0	12.8	16.0	19.7	22.2	23.2	22.0	20.5	16.8	13.3	11.3
	2%	WB	8.5	8.8	9.6	11.6	14.1	16.3	17.9	17.7	16.4	14.1	11.5	9.8
		MCDB	9.1	9.7	11.3	14.3	17.2	19.5	21.2	20.5	18.5	14.9	11.9	10.2
	5%	WB	7.3	7.6	8.5	10.3	12.7	14.8	16.9	16.6	15.1	13.0	10.2	8.6
		MCDB	7.8	8.4	10.0	12.6	15.4	17.5	19.9	19.0	16.6	13.8	10.6	9.1
	10%	WB	6.2	6.6	7.4	9.1	11.4	13.8	15.9	15.7	14.1	12.0	9.1	7.3
		MCDB	6.8	7.4	8.8	11.4	13.8	16.1	18.4	17.6	15.3	12.7	9.5	7.8
Mean Daily Temperature Range	5% DB	MDBR	3.9	4.5	5.5	6.5	6.8	6.8	7.1	6.8	6.1	5.1	4.2	4.0
		MCDBR	5.6	5.7	7.5	9.1	9.9	9.8	9.4	8.6	8.3	6.2	5.2	5.4
		MCWBR	5.4	4.8	5.2	5.7	6.0	5.9	5.2	4.9	5.4	4.8	4.9	5.2
	5% WB	MCDBR	5.6	5.6	7.0	8.3	9.1	9.0	8.5	7.5	7.7	5.9	5.0	5.2
		MCWBR	5.6	5.1	5.5	5.8	6.1	6.1	5.5	5.0	5.7	5.1	4.9	5.2
Clear-Sky Solar Irradiance	taub		0.309	0.327	0.355	0.379	0.376	0.381	0.383	0.373	0.354	0.337	0.312	0.295
	taud		2.358	2.422	2.353	2.305	2.362	2.365	2.365	2.408	2.464	2.480	2.412	2.323
	Ebn at Noon		643	767	820	846	870	867	857	845	815	746	638	574
	Edh at Noon		55	72	95	114	113	114	112	102	85	67	52	46
All-Sky Solar Radiation	RadAvg		0.61	1.24	2.33	3.68	4.71	4.79	4.62	3.82	2.76	1.53	0.75	0.47
	RadStd		0.07	0.14	0.30	0.40	0.27	0.41	0.41	0.25	0.25	0.13	0.07	0.05

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (51 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page