

BRIDLINGTON MRSC, United Kingdom

WMO: 032920

Lat: 54.0939N

Lon: 0.1758W

Elev: 49

StdP: 14.67

Time Zone: 0.00 (EUW)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	29.2	31.2	22.9	17.3	33.6	25.1	19.2	34.4	39.6	42.1	34.9	41.0	8.7	300	0.669

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	11.8	72.4	62.3	69.8	61.1	67.6	60.3	64.5	69.5	63.0	67.2	61.8	65.6	13.0	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
62.6	84.9	66.2	61.2	81.0	64.9	60.1	77.7	63.8	29.6	69.9	28.6	67.4	27.7	65.6	82.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 32.1	27.8	24.0	DB	24.7	79.1	4.1	3.1	21.7	81.4	19.3	83.2	17.0	84.9	14.0	87.2	(4)
(5)			WB	23.7	69.1	3.9	3.8	20.9	71.8	18.6	74.0	16.4	76.1	13.6	78.9	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	49.9	40.7	41.3	43.5	46.8	51.6	56.4	60.5	60.7	57.3	52.2	45.7	41.4		
	DBStd	8.47	4.32	4.80	4.67	4.33	4.24	4.05	3.67	3.50	3.67	4.43	4.77	5.25		
	HDD50	1333	290	247	208	114	31	1	0	0	1	28	142	271		
	HDD65	5535	754	664	667	545	417	260	147	139	233	397	579	733		
	CDD50	1286	0	2	6	18	79	193	325	333	218	96	13	3		
	CDD65	17	0	0	0	0	0	2	7	7	1	0	0	0		
	CDH74	41	0	0	0	0	0	7	20	11	3	0	0	0		
	CDH80	4	0	0	0	0	0	1	2	1	0	0	0	0		
	WSAvg	11.3	13.3	13.0	12.1	11.1	10.7	9.6	8.9	9.3	10.4	12.3	12.4	12.4		
	PrecAvg	25.9	2.3	1.9	1.6	2.0	2.0	2.3	2.0	2.5	1.9	2.3	2.8	2.4		
(15) Precipitation	PrecMax	33.0	4.3	3.0	4.1	5.6	3.9	7.4	3.8	4.9	3.7	4.3	5.4	4.3		
	PrecMin	18.0	0.4	0.2	0.1	0.1	0.5	0.2	0.4	0.2	0.5	0.5	0.7	0.9		
	PrecStd	4.0	1.1	0.7	1.0	1.6	0.9	1.7	0.9	1.2	1.1	1.0	1.1	0.9		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	54.9	57.2	60.2	64.3	68.2	73.7	76.5	75.3	72.7	67.1	59.5	56.1		
		MCWB	51.2	52.4	52.7	54.6	60.6	62.3	64.3	64.8	63.1	60.1	55.8	52.9		
	2%	DB	51.9	53.3	56.1	59.7	64.0	69.0	72.0	72.1	68.6	62.7	56.5	53.5		
		MCWB	48.8	49.2	50.2	52.3	56.0	59.7	62.2	62.0	60.7	57.4	53.5	50.8		
	5%	DB	49.4	50.8	53.3	56.5	61.0	66.0	69.3	69.3	65.6	60.3	54.2	51.1		
		MCWB	46.5	47.0	48.1	50.3	54.2	58.1	61.2	60.9	59.2	55.8	51.7	48.8		
	10%	DB	47.3	48.6	50.9	53.7	58.5	63.4	67.1	67.0	63.5	58.4	52.4	48.9		
		MCWB	44.7	45.0	46.4	48.7	52.8	57.0	60.4	60.5	58.2	55.0	50.2	46.8		
	0.4%	WB	51.9	52.6	53.8	57.0	61.4	64.3	66.3	66.5	64.7	61.2	56.8	53.5		
		MCDB	54.2	56.2	58.2	61.8	66.8	70.8	73.7	71.7	69.6	66.1	58.9	55.4		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	49.4	49.9	51.2	53.4	57.6	61.6	64.2	64.5	62.3	58.5	54.2	51.2		
		MCDB	51.6	52.8	55.4	58.3	62.2	66.9	69.3	69.1	66.3	61.0	55.9	53.2		
	5%	WB	47.0	47.5	48.8	50.9	55.4	59.6	62.7	63.1	60.7	57.1	52.2	49.0		
		MCDB	49.0	50.2	52.4	55.4	59.8	64.0	67.0	66.7	63.8	59.0	53.8	50.7		
	10%	WB	45.1	45.6	46.8	49.2	53.6	58.1	61.4	61.9	59.4	55.8	50.6	47.0		
		MCDB	46.9	48.0	50.0	52.9	57.3	62.0	65.4	65.1	62.2	57.9	52.2	48.8		
	5% DB	MDBR	7.9	9.1	10.4	11.1	11.3	11.3	11.6	11.8	11.3	9.9	8.7	8.2		
		MCDBR	10.8	11.6	14.4	15.6	15.2	15.9	15.4	15.2	14.6	11.9	9.8	10.0		
		MCWBR	9.8	9.0	9.8	9.7	9.2	9.1	8.3	8.0	8.9	8.2	8.2	9.0		
		MCWBR	10.4	11.3	13.6	14.1	13.7	13.9	13.1	11.9	12.6	10.4	9.0	9.7		
(35) Mean Daily Temperature Range	5% WB	MCWBR	9.8	9.3	10.0	9.5	9.5	9.3	8.3	7.6	8.6	8.1	8.1	9.1		
(40) Clear-Sky Solar Irradiance	taub		0.324	0.342	0.372	0.397	0.394	0.401	0.403	0.393	0.373	0.353	0.326	0.311		
	taud		2.336	2.385	2.309	2.262	2.330	2.331	2.335	2.381	2.434	2.451	2.391	2.313		
	Ebn at Noon		198	237	254	263	271	269	266	262	252	231	197	177		
	Edh at Noon		18	24	32	38	37	38	37	33	28	22	17	15		
(44) All-Sky Solar Radiation	RadAvg		195	407	770	1223	1558	1594	1543	1283	921	512	244	151		
	RadStd		22	50	89	125	101	131	138	85	83	39	24	15		

Historical Trends

		Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+77	N/A
(47) Regional (54 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page