

LEEDS WEATHER CENTRE, United Kingdom

WMO: 033470

Lat: 53.800N

Lon: 1.550W

Elev: 47

StdP: 100.76

Time Zone: 0.00 (EUW)

Period: 94-03

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	-2.1	-1.1	-6.3	2.2	1.8	-4.9	2.5	1.7	15.5	7.5	12.8	7.5	2.5	300	0.585

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	7.9	26.5	18.2	24.3	17.1	22.6	16.2	18.9	24.4	18.0	23.1	17.1	21.4	3.8	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
16.9	12.1	21.1	16.0	11.4	20.0	15.2	10.8	19.0	53.7	24.3	50.7	23.2	48.1	21.5	21.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
(a)	(b)	(c)	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
12.5	10.6	9.1	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
			-4.6	29.6	1.8	1.6	-5.9	30.8	-6.9	31.7	-7.9	32.6	-9.2	33.7
			-5.1	20.3	1.7	0.8	-6.3	20.9	-7.3	21.4	-8.3	21.8	-9.5	22.4
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	10.5	5.0	5.7	7.0	8.8	12.0	14.7	17.1	17.3	14.1	11.1	7.8	4.9	(6)
(7)		DBStd	5.24	2.84	3.02	2.83	3.10	3.11	2.70	2.52	2.75	2.19	2.90	2.85	3.24	(7)
(8)		HDD10.0	716	157	124	98	59	16	1	0	0	1	22	78	160	(8)
(9)		HDD18.3	2916	414	355	351	286	198	115	56	54	128	226	317	416	(9)
(10)		CDD10.0	888	1	3	6	24	77	140	221	226	124	56	11	2	(10)
(11)		CDD18.3	47	0	0	0	0	1	4	17	22	2	0	0	0	(11)
(12)		CDH23.3	288	0	0	0	1	8	35	96	136	12	0	0	0	(12)
(13)		CDH26.7	52	0	0	0	0	0	8	12	32	1	0	0	0	(13)
(14)	Wind	WSAvg	3.9	4.2	5.1	4.6	3.8	3.6	4.0	3.8	3.4	3.3	3.8	3.6	3.7	(14)
(15)	Precipitation	PrecAvg	734	67	49	59	55	60	56	50	70	67	63	71	68	(15)
(16)		PrecMax	918	150	162	112	126	147	301	120	132	217	154	136	192	(16)
(17)		PrecMin	493	20	5	8	8	7	9	11	20	11	13	26	27	(17)
(18)		PrecStd	119	34	33	29	33	34	56	25	29	47	36	34	39	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	13.2	14.8	15.7	20.2	24.7	27.5	28.4	29.8	25.4	20.4	15.3	14.2	(19)
(20)			MCWB	10.5	11.2	9.9	12.1	15.9	19.0	17.7	18.6	18.5	15.2	12.9	12.0	(20)
(21)		2%	DB	11.4	12.5	14.1	17.3	22.0	23.4	25.9	27.1	21.2	17.8	14.2	12.7	(21)
(22)			MCWB	9.2	10.0	9.9	11.4	14.7	15.8	17.7	18.5	15.9	14.0	11.9	10.7	(22)
(23)		5%	DB	10.4	11.2	12.7	15.5	19.3	21.5	24.1	24.2	19.3	16.5	13.0	10.7	(23)
(24)			MCWB	8.3	8.7	9.3	10.5	13.5	15.0	16.9	17.5	14.7	13.3	10.9	8.8	(24)
(25)		10%	DB	9.5	10.3	11.6	13.9	17.4	19.7	22.3	22.2	17.9	15.4	11.9	9.4	(25)
(26)			MCWB	7.6	7.9	8.5	9.7	12.4	14.2	16.3	16.6	13.9	12.7	10.2	7.8	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	10.7	11.3	11.9	13.6	17.1	19.0	19.7	20.3	19.0	15.8	13.5	12.2	(27)
(28)			MCDWB	12.5	13.7	14.2	18.5	22.6	25.6	25.1	26.3	23.0	18.3	14.8	14.0	(28)
(29)		2%	WB	9.5	10.2	10.7	12.2	15.3	17.0	18.6	19.0	17.1	14.8	12.4	11.0	(29)
(30)			MCDWB	11.2	12.3	13.1	16.2	20.1	22.0	23.8	24.7	20.5	17.1	13.9	12.6	(30)
(31)		5%	WB	8.6	9.1	9.7	11.1	14.1	15.8	17.7	18.1	15.7	13.9	11.3	9.1	(31)
(32)			MCDWB	10.1	11.0	12.0	14.7	18.7	19.9	22.5	23.5	17.9	15.9	12.6	10.3	(32)
(33)		10%	WB	7.8	8.0	8.8	10.1	12.9	14.8	16.8	17.3	14.7	13.0	10.4	8.0	(33)
(34)			MCDWB	9.3	10.0	11.3	13.3	16.8	18.7	21.2	21.6	16.8	15.1	11.7	9.4	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	4.3	5.4	6.3	7.2	7.8	7.6	7.9	6.7	6.1	4.6	4.3	(35)	
(36)			MCDBR	5.6	6.0	7.9	9.2	11.0	11.2	11.1	11.6	9.5	6.7	5.1	5.3	(36)
(37)			MCWBR	4.8	4.9	5.0	4.7	5.7	5.5	4.6	4.6	5.0	4.4	4.2	4.5	(37)
(38)		5% WB	MCDWR	5.4	5.8	6.6	8.4	10.7	9.6	9.7	9.9	7.7	6.6	4.9	5.2	(38)
(39)			MCWBR	4.9	5.2	5.0	4.7	6.1	5.5	4.6	4.4	5.0	5.0	4.4	4.8	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.322	0.337	0.367	0.395	0.395	0.398	0.398	0.385	0.366	0.348	0.322	0.310	(40)	
(41)		taud	2.325	2.374	2.293	2.236	2.275	2.294	2.296	2.351	2.412	2.435	2.388	2.305	(41)	
(42)		Ebn at Noon	633	756	806	831	852	851	843	834	804	735	633	565	(42)	
(43)		Edh at Noon	59	77	102	122	124	123	121	108	90	71	55	50	(43)	
(44)	All-Sky Solar Radiation	RadAvg	0.64	1.30	2.39	3.72	4.71	4.84	4.70	3.87	2.83	1.60	0.79	0.51	(44)	
(45)		RadStd	0.07	0.15	0.29	0.43	0.30	0.45	0.47	0.25	0.26	0.14	0.08	0.05	(45)	

Historical Trends

		Heating		Cooling			Degree-Days				
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (66 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page