

SCAMPTON, United Kingdom

WMO: 033730

Lat: 53.3069N

Lon: 0.5481W

Elev: 62

StdP: 100.59

Time Zone: 0.00 (EUW)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-4.1	-2.5	-5.9	2.3	-1.9	-4.6	2.6	-1.1	20.4	9.3	17.3	8.1	3.6	250	0.669

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.1	25.7	18.3	23.7	17.5	22.1	16.7	19.3	23.6	18.4	22.3	17.5	21.1	4.7	230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
17.7	12.8	20.9	16.8	12.1	19.9	16.0	11.5	19.1	55.2	23.7	52.2	22.4	49.4	21.0	27.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 15.1	12.2	10.5	DB	-7.4	29.5	2.9	1.8	-9.5	30.8	-11.2	31.8	-12.8	32.8	-14.9	34.1	(4)
(5)			WB	-7.7	21.8	2.9	2.0	-9.8	23.2	-11.5	24.4	-13.1	25.5	-15.2	26.9	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	9.8	4.1	4.3	6.1	8.7	11.5	14.5	16.6	16.4	14.0	10.6	6.6	4.3	(6)	
	DBStd	5.43	3.19	3.30	2.98	2.92	2.75	2.63	2.53	2.40	2.45	2.99	3.15	3.60	(7)	
	HDD10.0	859	183	162	126	59	15	1	0	0	1	27	107	178	(8)	
	HDD18.3	3131	441	394	381	291	211	119	66	71	133	239	351	434	(9)	
	CDD10.0	800	1	1	4	19	62	135	206	197	120	48	6	2	(10)	
	CDD18.3	29	0	0	0	0	0	4	13	10	2	1	0	0	(11)	
	CDH23.3	206	0	0	0	1	3	34	101	54	10	2	0	0	(12)	
	CDH26.7	28	0	0	0	0	0	4	12	11	1	0	0	0	(13)	
(14) Wind	WSAvg	5.2	5.9	5.7	5.6	5.2	5.2	4.8	4.3	4.7	5.0	5.0	5.4	5.5	(14)	
(15) Precipitation	PrecAvg	606	52	39	35	42	47	55	63	56	55	56	56	50	(15)	
	PrecMax	820	114	70	71	136	110	209	124	140	120	101	97	97	(16)	
	PrecMin	399	22	12	7	7	9	7	23	8	16	14	20	18	(17)	
	PrecStd	116	24	16	17	32	25	43	30	30	28	21	21	21	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	12.8	13.9	16.2	21.1	23.3	27.1	28.4	28.3	24.7	20.5	15.6	13.4	(19)	
		MCWB	11.1	11.4	11.6	13.9	16.9	19.8	19.4	19.6	17.6	16.4	13.9	11.7	(20)	
	2%	DB	11.4	12.0	14.2	18.0	20.8	23.7	26.0	24.5	21.9	17.9	13.8	12.2	(21)	
		MCWB	9.9	10.0	10.6	12.7	15.2	17.7	18.3	18.2	16.8	14.9	12.4	10.9	(22)	
	5%	DB	10.1	10.5	12.6	15.9	18.7	21.4	24.1	22.6	20.0	16.2	12.6	11.0	(23)	
		MCWB	8.8	8.9	9.8	11.4	13.8	16.5	17.7	17.1	15.7	14.1	11.3	9.7	(24)	
	10%	DB	8.9	9.3	11.2	14.1	16.9	19.7	22.1	21.2	18.5	15.1	11.4	9.7	(25)	
		MCWB	7.8	7.9	8.7	10.5	12.7	15.4	16.6	16.3	14.8	13.0	10.2	8.7	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	11.6	11.9	12.4	15.1	17.6	20.9	20.7	20.7	19.0	16.8	14.4	12.1	(27)	
		MCDB	12.6	13.2	14.8	20.2	22.2	25.9	27.4	25.2	22.1	19.9	15.3	13.0	(28)	
	2%	WB	10.2	10.3	11.2	13.4	15.9	18.7	19.2	19.0	17.5	15.6	12.7	11.1	(29)	
		MCDB	11.2	11.7	13.4	17.0	19.9	22.2	23.7	22.9	20.7	17.3	13.6	12.1	(30)	
	5%	WB	9.0	9.2	10.1	12.1	14.6	17.2	18.2	18.1	16.4	14.5	11.5	9.9	(31)	
		MCDB	9.9	10.4	12.3	15.3	17.7	20.5	22.6	21.7	19.0	16.0	12.5	10.9	(32)	
	10%	WB	7.9	8.1	9.0	10.8	13.4	16.0	17.3	17.1	15.5	13.4	10.4	8.7	(33)	
		MCDB	8.9	9.2	11.0	13.7	16.1	19.0	21.2	20.2	17.8	14.8	11.3	9.7	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	5.2	6.0	7.6	8.8	8.7	8.7	9.1	8.8	8.3	6.8	5.9	5.2	(35)	
		MCDBR	6.4	6.9	9.5	11.4	11.5	11.5	12.1	10.6	10.1	7.5	6.3	6.1	(36)	
	5% WB	MCWBR	6.0	5.5	6.6	6.8	6.7	6.7	5.7	5.2	5.7	5.2	5.6	5.6	(37)	
		MCWBR	6.3	6.7	9.0	10.9	10.3	10.6	10.7	9.5	9.0	7.1	6.2	6.0	(38)	
(40) Clear-Sky Solar Irradiance	taub	taub	0.322	0.338	0.370	0.396	0.397	0.403	0.404	0.391	0.370	0.351	0.325	0.310	(40)	
		taud	2.357	2.391	2.300	2.238	2.277	2.284	2.290	2.349	2.413	2.448	2.409	2.331	(41)	
	Ebn at Noon	Ebn at Noon	648	762	807	831	852	848	839	829	803	738	643	584	(42)	
		Edh at Noon	59	77	102	123	124	125	122	109	91	72	55	50	(43)	
(44) All-Sky Solar Radiation	RadAvg	RadAvg	0.68	1.36	2.44	3.76	4.71	4.90	4.76	3.92	2.90	1.66	0.84	0.55	(44)	
	RadStd	RadStd	0.07	0.16	0.29	0.45	0.31	0.47	0.50	0.26	0.26	0.14	0.09	0.06	(45)	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (71 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page