

LECONFIELD, United Kingdom

WMO: 033820

Lat: 53.8747N

Lon: 0.4417W

Elev: 23

StdP: 14.68

Time Zone: 0.00 (EUW)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	26.1	28.7	22.6	17.0	31.0	24.7	18.8	32.3	32.0	48.5	29.4	48.7	3.9	270	0.620

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	16.2	77.2	65.2	73.9	63.6	71.0	61.9	66.5	74.1	64.8	71.8	63.3	69.4	10.2	200

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
63.6	88.2	69.6	62.1	83.3	67.7	60.6	79.2	66.1	31.1	74.2	29.8	72.1	28.7	69.4	81.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
Min		Max		Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
25.8	22.7	20.0		DB	20.0	83.7	4.9	3.0	16.5	85.9	13.7	87.6	11.0	89.3	7.4	91.5
				WB	19.3	70.6	5.3	2.6	15.5	72.5	12.5	74.1	9.5	75.5	5.7	77.5

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	49.8	40.1	40.9	43.3	46.8	51.8	57.1	61.3	61.1	57.0	51.7	44.9	40.5	(6)
	DBStd	9.19	5.26	5.63	5.23	5.08	4.98	4.46	4.23	4.17	4.21	5.01	5.44	6.41	(7)
	HDD50	1444	307	257	215	120	39	2	0	0	1	39	166	298	(8)
	HDD65	5592	771	674	672	545	411	241	129	134	242	413	602	758	(9)
	CDD50	1362	1	3	8	25	94	214	351	346	211	91	14	4	(10)
	CDD65	34	0	0	0	0	0	3	15	14	2	0	0	0	(11)
	CDH74	271	0	0	0	1	3	38	119	90	18	2	0	0	(12)
	CDH80	26	0	0	0	0	0	4	11	10	1	0	0	0	(13)
(14) Wind	WSAvg	9.4	10.8	11.1	10.4	9.3	8.9	8.2	7.8	8.2	8.7	9.2	9.7	10.1	(14)
(15) Precipitation	PrecAvg	26.8	2.1	1.8	1.7	2.0	2.1	2.7	2.2	2.7	2.0	2.6	2.6	2.3	(15)
	PrecMax	33.2	4.7	3.2	3.8	5.3	4.1	9.1	4.0	4.8	4.1	4.5	4.7	4.1	(16)
	PrecMin	18.6	0.4	0.2	0.3	0.2	0.6	0.4	0.7	0.8	0.6	1.0	0.7	0.9	(17)
	PrecStd	4.2	1.1	0.8	0.9	1.5	0.9	2.0	0.9	1.1	1.0	0.9	1.1	0.9	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	55.4	57.6	61.1	67.7	72.8	79.1	81.3	81.0	76.6	68.4	60.3	56.9	(19)
		MCWB	52.1	52.4	53.5	57.0	62.4	67.1	66.5	66.6	63.4	61.6	56.9	53.2	(20)
	2%	DB	52.6	54.3	57.2	62.1	67.9	73.2	77.3	76.2	71.4	63.9	57.4	54.6	(21)
		MCWB	49.3	50.2	51.1	53.8	59.2	62.9	65.1	65.2	62.2	58.6	54.4	51.7	(22)
	5%	DB	50.3	51.7	54.4	59.0	64.8	69.4	74.0	72.7	67.8	61.3	55.1	52.2	(23)
		MCWB	47.4	48.0	49.5	52.2	56.9	60.7	63.8	63.0	60.2	57.2	52.5	49.6	(24)
	10%	DB	48.2	49.6	52.0	56.3	61.5	66.5	70.8	69.8	64.9	59.3	52.9	49.8	(25)
		MCWB	45.6	46.2	47.5	50.3	54.8	58.9	62.1	61.3	58.1	55.7	50.7	47.4	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	52.5	53.1	54.6	58.9	63.6	68.6	69.1	68.6	66.1	62.5	57.5	54.0	(27)
		MCDB	55.1	56.5	58.9	65.0	71.1	77.3	78.6	76.3	73.9	67.9	59.6	56.3	(28)
	2%	WB	49.8	50.6	52.2	55.5	60.3	64.4	66.6	66.1	63.5	60.1	55.0	52.0	(29)
		MCDB	52.0	53.8	56.3	60.3	66.8	71.5	74.3	73.4	69.3	63.0	56.8	54.3	(30)
	5%	WB	47.9	48.6	50.2	53.3	57.7	61.9	64.8	64.4	61.4	58.1	52.9	49.9	(31)
		MCDB	50.1	51.4	53.8	58.1	63.2	67.9	72.0	71.0	65.9	60.6	54.7	51.9	(32)
	10%	WB	45.9	46.6	48.1	50.9	55.6	59.9	63.1	62.8	59.6	56.2	51.1	47.6	(33)
		MCDB	47.9	49.2	51.6	55.4	60.6	65.2	69.4	68.1	63.4	58.8	52.7	49.7	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	8.8	10.7	12.3	14.8	15.3	15.7	16.2	15.7	14.6	11.9	10.0	9.1	(35)
		MCDBR	10.9	12.2	15.7	19.3	20.6	21.7	22.1	20.1	19.3	13.3	10.7	10.6	(36)
		MCWBR	10.0	9.7	10.7	12.0	12.9	12.6	11.4	10.5	11.2	9.4	9.3	9.5	(37)
	5% WB	MCDBR	10.7	12.1	15.1	18.8	19.3	19.9	19.9	17.7	16.5	12.8	10.3	10.5	(38)
		MCWBR	10.0	10.1	11.2	12.7	13.0	12.7	11.5	10.2	11.0	9.9	9.4	9.7	(39)
(40) Clear-Sky Solar Irradiance	taub		0.324	0.341	0.372	0.399	0.396	0.404	0.406	0.394	0.373	0.353	0.326	0.311	(40)
	taud		2.337	2.380	2.296	2.241	2.295	2.298	2.305	2.357	2.417	2.443	2.391	2.315	(41)
	Ebn at Noon		200	238	254	262	270	268	265	262	252	231	199	179	(42)
	Edh at Noon		18	24	32	39	39	39	38	34	29	23	17	16	(43)
(44) All-Sky Solar Radiation	RadAvg		202	412	758	1186	1502	1542	1495	1235	901	507	250	159	(44)
	RadStd		22	48	93	135	95	138	144	81	82	43	26	16	(45)

Historical Trends

		Heating		Cooling			Degree-Days				
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (64 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page