

LECONFIELD, United Kingdom

WMO: 033820

Lat: 53.8747N

Lon: 0.4417W

Elev: 7

StdP: 101.24

Time Zone: 0.00 (EUW)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -3.3	(c) -1.9	(d) -5.2	(e) 2.4	(f) -0.6	(g) -4.0	(h) 2.7	(i) 0.2	(j) 14.3	(k) 9.2	(l) 13.1	(m) 9.3	(n) 1.7	(o) 270	(p) 0.620

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 7	(b) 9.0	(c) 25.1	(d) 18.5	(e) 23.3	(f) 17.6	(g) 21.7	(h) 16.6	(i) 19.2	(j) 23.4	(k) 18.2	(l) 22.1	(m) 17.4	(n) 20.8	(o) 4.6	(p) 200

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
17.6	12.6	20.9	16.7	11.9	19.9	15.9	11.3	18.9	54.5	23.4	51.5	22.3	48.8	20.8	27.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 11.5	(b) 10.1	(c) 9.0	(e) -6.6	(f) 28.7	(g) 2.7	(h) 1.7	(i) -8.6	(j) 29.9	(k) -10.2	(l) 30.9	(m) -11.7	(n) 31.8	(o) -13.6	(p) 33.0		
(a) 11.5	(b) 10.1	(c) 9.0	(e) -7.0	(f) 21.4	(g) 2.9	(h) 1.5	(i) -9.1	(j) 22.5	(k) -10.9	(l) 23.4	(m) -12.5	(n) 24.2	(o) -14.6	(p) 25.3		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	9.9	4.5	5.0	6.3	8.2	11.0	13.9	16.3	16.2	13.9	10.9	7.2	4.7
	DBStd	5.10	2.92	3.13	2.90	2.82	2.77	2.48	2.35	2.32	2.34	2.78	3.02	3.56
	HDD10.0	802	171	143	119	67	22	1	0	0	1	22	92	166
	HDD18.3	3107	428	374	373	303	228	134	72	74	134	229	334	421
	CDD10.0	757	1	2	4	14	52	119	195	192	117	51	8	2
	CDD18.3	19	0	0	0	0	0	2	8	8	1	0	0	0
	CDH23.3	151	0	0	0	1	2	21	66	50	10	1	0	0
	CDH26.7	14	0	0	0	0	0	2	6	6	1	0	0	0
Wind	WSAvg	4.2	4.8	5.0	4.7	4.1	4.0	3.7	3.5	3.7	3.9	4.1	4.3	4.5
Precipitation	PrecAvg	680	54	46	43	51	53	68	56	68	50	66	66	58
	PrecMax	844	119	82	96	134	104	230	101	122	103	115	120	105
	PrecMin	472	10	5	8	5	14	10	19	20	15	25	17	22
	PrecStd	106	28	20	24	39	24	51	23	27	25	24	27	23
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	13.0	14.2	16.2	19.8	22.7	26.2	27.4	27.2	24.8	20.2	15.7	13.9
		MCWB	11.2	11.3	12.0	13.9	16.9	19.5	19.2	19.2	17.5	16.4	13.9	11.8
	2%	DB	11.4	12.4	14.0	16.7	20.0	22.9	25.2	24.6	21.9	17.7	14.1	12.5
		MCWB	9.6	10.1	10.6	12.1	15.1	17.2	18.4	18.5	16.8	14.8	12.4	11.0
	5%	DB	10.2	11.0	12.4	15.0	18.2	20.8	23.3	22.6	19.9	16.3	12.8	11.2
		MCWB	8.6	8.9	9.7	11.2	13.9	16.0	17.7	17.2	15.6	14.0	11.4	9.8
	10%	DB	9.0	9.8	11.1	13.5	16.4	19.2	21.6	21.0	18.3	15.2	11.6	9.9
		MCWB	7.6	7.9	8.6	10.2	12.6	14.9	16.7	16.3	14.5	13.2	10.4	8.6
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	11.4	11.7	12.5	14.9	17.5	20.3	20.6	20.3	18.9	17.0	14.2	12.2
		MCDB	12.8	13.6	15.0	18.3	21.7	25.2	25.9	24.6	23.3	19.9	15.3	13.5
	2%	WB	9.9	10.3	11.2	13.1	15.7	18.0	19.2	18.9	17.5	15.6	12.8	11.1
		MCDB	11.1	12.1	13.5	15.7	19.3	22.0	23.5	23.0	20.7	17.2	13.8	12.4
	5%	WB	8.8	9.2	10.1	11.8	14.3	16.6	18.2	18.0	16.3	14.5	11.6	10.0
		MCDB	10.0	10.8	12.1	14.5	17.3	19.9	22.2	21.7	18.8	15.9	12.6	11.1
	10%	WB	7.7	8.1	9.0	10.5	13.1	15.5	17.3	17.1	15.4	13.5	10.6	8.7
		MCDB	8.9	9.6	10.9	13.0	15.9	18.4	20.8	20.0	17.5	14.9	11.5	9.8
Mean Daily Temperature Range	5% DB	MDBR	4.9	6.0	6.8	8.2	8.5	8.7	9.0	8.7	8.1	6.6	5.6	5.1
		MCDBR	6.1	6.8	8.7	10.7	11.4	12.0	12.3	11.2	10.7	7.4	5.9	5.9
		MCWBR	5.5	5.4	6.0	6.7	7.2	7.0	6.3	5.8	6.2	5.2	5.2	5.3
	5% WB	MCDBR	5.9	6.7	8.4	10.5	10.7	11.1	11.1	9.9	9.2	7.1	5.7	5.8
		MCWBR	5.6	5.6	6.2	7.0	7.2	7.1	6.4	5.6	6.1	5.5	5.2	5.4
Clear-Sky Solar Irradiance	taub	0.324	0.341	0.372	0.399	0.396	0.404	0.406	0.394	0.373	0.353	0.326	0.311	
	taud	2.337	2.380	2.296	2.241	2.295	2.298	2.305	2.357	2.417	2.443	2.391	2.315	
	Ebn at Noon	630	751	800	827	850	846	836	825	796	728	626	563	
	Edh at Noon	58	76	102	122	122	123	120	108	90	71	55	49	
All-Sky Solar Radiation	RadAvg	0.64	1.30	2.39	3.74	4.74	4.86	4.71	3.89	2.84	1.60	0.79	0.50	
	RadStd	0.07	0.15	0.29	0.43	0.30	0.44	0.46	0.25	0.26	0.14	0.08	0.05	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (64 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page