

ABERDARON, United Kingdom

WMO: 034050

Lat: 52.7889N

Lon: 4.7414W

Elev: 308

StdP: 14.53

Time Zone: 0.00 (EUW)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	31.7	33.8	23.6	18.0	35.2	26.1	20.3	36.7	54.2	48.1	50.0	47.5	13.6	50	0.820

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	7.1	70.5	62.8	67.3	61.2	64.6	59.8	64.0	68.3	62.1	65.3	60.9	63.3	9.1	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
62.3	84.9	65.7	60.9	80.7	63.2	59.9	77.8	62.0	29.3	68.5	28.0	65.6	27.2	63.4	77.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
46.9	41.0	35.6	DB	29.2	75.9	3.4	3.5	26.8	78.4	24.8	80.4	22.9	82.4	20.5	84.9
			WB	27.6	67.8	3.1	3.3	25.4	70.2	23.6	72.1	21.8	74.0	19.6	76.4

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	50.8	43.4	43.1	44.4	47.5	51.9	56.1	58.9	59.6	57.4	53.4	48.4	45.0
	DBStd	7.09	4.41	4.06	3.93	3.87	4.00	3.55	3.28	2.70	2.86	3.64	4.24	4.67
	HDD50	938	205	195	177	92	20	0	0	0	0	13	76	160
	HDD65	5189	669	614	639	526	406	268	193	171	227	359	497	620
	CDD50	1234	0	0	3	16	80	184	277	298	224	118	29	5
	CDD65	12	0	0	0	0	0	2	6	4	0	0	0	0
	CDH74	24	0	0	0	0	0	5	12	7	0	0	0	0
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0
(14) Wind	WSAvg	17.3	21.7	20.3	17.1	14.8	14.9	13.8	13.4	14.3	16.0	19.5	20.5	21.7
(15) Precipitation	PrecAvg	38.9	3.9	2.8	2.6	2.5	2.4	2.2	2.5	3.1	3.3	4.2	4.8	4.6
	PrecMax	50.2	7.1	5.5	5.2	4.8	5.7	6.7	5.2	5.4	5.4	8.6	9.4	12.4
	PrecMin	30.3	0.2	0.4	0.4	0.7	0.6	0.6	0.4	0.2	0.5	0.8	2.0	0.9
	PrecStd	5.2	1.7	1.3	1.2	1.2	1.2	1.5	1.2	1.1	1.3	2.1	1.8	2.3
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	52.2	52.0	57.5	64.4	69.5	73.3	75.6	74.6	68.5	62.6	57.5	54.5
		MCWB	51.1	48.5	49.7	54.5	60.7	63.0	65.8	67.6	61.8	58.5	55.4	53.0
	2%	DB	51.1	50.3	52.2	58.3	64.5	68.4	70.5	69.0	64.9	60.2	56.3	53.3
		MCWB	50.0	48.4	48.1	51.8	57.9	61.0	63.0	62.9	60.3	57.5	54.7	51.9
	5%	DB	50.1	49.2	50.2	54.3	60.9	64.5	66.5	65.5	62.8	59.2	55.2	52.2
		MCWB	48.8	47.6	47.7	49.8	55.7	58.8	61.0	61.1	59.2	57.2	53.7	50.9
	10%	DB	49.2	48.2	49.0	52.0	57.6	61.5	63.7	63.2	61.3	58.2	54.2	51.2
		MCWB	47.9	46.8	46.9	48.8	53.3	57.3	59.6	59.9	58.4	56.4	52.6	49.8
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	51.7	50.4	51.0	55.3	62.0	65.0	67.8	68.0	63.7	60.1	56.6	53.6
		MCDB	51.8	50.7	54.2	62.3	67.8	71.0	72.1	73.8	65.8	61.4	57.0	53.9
	2%	WB	50.5	49.1	49.4	52.5	58.8	61.8	63.8	63.8	61.4	58.8	55.3	52.5
		MCDB	50.8	49.6	51.0	56.7	63.5	66.7	68.6	67.3	63.2	59.5	55.9	53.0
	5%	WB	49.4	48.1	48.4	50.8	56.3	59.5	61.8	62.0	60.3	57.8	54.2	51.4
		MCDB	49.8	48.7	49.7	53.4	60.1	63.2	65.3	64.3	61.8	58.7	54.9	52.1
	10%	WB	48.3	47.1	47.5	49.5	54.2	58.0	60.3	60.8	59.3	56.8	52.9	50.2
		MCDB	48.9	47.9	48.7	51.5	56.7	60.7	62.9	62.4	60.7	57.9	54.0	51.1
(35) Mean Daily Temperature Range	5% DB	MDBR	5.4	5.7	6.7	7.7	8.1	8.1	7.5	7.1	6.8	5.9	5.6	5.4
		MCDBR	5.4	5.5	7.4	10.8	12.7	13.4	12.8	10.0	8.2	6.1	5.3	5.8
	5% WB	MCWBR	6.6	5.8	5.9	7.2	8.4	8.8	7.5	6.1	5.9	5.7	6.2	7.2
		MCWBR	5.5	5.3	6.7	8.9	11.3	11.4	10.6	8.3	7.2	5.7	5.3	5.7
(40) Clear-Sky Solar Irradiance	taub		0.329	0.340	0.366	0.381	0.387	0.378	0.382	0.366	0.361	0.348	0.326	0.318
		taud	2.333	2.398	2.360	2.347	2.382	2.432	2.424	2.482	2.490	2.469	2.395	2.307
	Ebn at Noon		205	243	260	270	274	277	274	273	260	238	206	185
		Edh at Noon	20	24	31	35	36	34	34	30	27	23	18	17
(44) All-Sky Solar Radiation	RadAvg		217	446	839	1325	1667	1796	1624	1363	982	545	266	160
	RadStd		21	40	61	90	114	151	144	90	62	48	24	17

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (44 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page