

WEYBOURNE, United Kingdom

WMO: 034880

Lat: 52.9494N

Lon: 1.1225E

Elev: 20

StdP: 101.08

Time Zone: 0.00 (EUW)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -1.5	(c) -0.4	(d) -4.8	(e) 2.5	(f) 1.1	(g) -3.5	(h) 2.8	(i) 1.5	(j) 17.3	(k) 6.7	(l) 15.7	(m) 5.8	(n) 5.2	(o) 210	(p) 0.730

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 8	(b) 6.8	(c) 24.6	(d) 18.1	(e) 22.7	(f) 17.5	(g) 21.3	(h) 16.9	(i) 19.4	(j) 22.8	(k) 18.4	(l) 21.3	(m) 17.6	(n) 20.3	(o) 6.1	(p) 210

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
18.1	13.1	20.8	17.2	12.3	19.9	16.5	11.8	19.1	55.4	23.1	52.2	21.3	49.7	20.4	29.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 14.5	(b) 13.0	(c) 11.8	(e) -4.3	(f) 29.7	(g) 2.2	(h) 1.2	(i) -5.9	(j) 30.6	(k) -7.1	(l) 31.3	(m) -8.4	(n) 32.0	(o) -9.9	(p) 32.9		
(4) 14.5	(5) 13.0	(6) 11.8	(7) -4.3	(8) 29.7	(9) 2.2	(10) 1.2	(11) -5.9	(12) 30.6	(13) -7.1	(14) 31.3	(15) -8.4	(16) 32.0	(17) -9.9	(18) 32.9		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	10.5	5.0	5.2	6.6	8.9	11.5	14.4	16.7	17.0	14.7	12.0	8.1	5.7		
	DBStd	5.08	2.76	3.04	2.88	2.85	2.70	2.67	2.35	2.31	2.33	2.71	2.64	2.97		
	HDD10.0	691	157	137	112	54	14	1	0	0	0	11	68	137		
	HDD18.3	2891	414	368	365	283	211	122	63	56	112	198	306	393		
	CDD10.0	874	1	2	6	21	61	133	207	216	142	72	11	3		
	CDD18.3	33	0	0	0	0	1	4	12	13	3	1	0	0		
	CDH23.3	123	0	0	0	0	1	23	40	46	9	3	0	0		
	CDH26.7	18	0	0	0	0	0	5	6	7	1	0	0	0		
(14) Wind	WSAvg	6.2	7.3	7.2	6.6	5.9	5.8	5.4	5.1	5.5	6.0	6.4	6.7	7.1		
(15) Precipitation	PrecAvg	650	55	44	40	41	46	54	58	62	55	66	73	59		
	PrecMax	833	94	81	86	126	133	155	114	151	116	133	125	95		
	PrecMin	427	11	12	9	3	11	11	14	5	13	12	23	25		
	PrecStd	105	25	18	23	30	26	35	26	34	26	25	23	20		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	13.2	14.5	16.1	20.6	22.6	26.6	27.2	27.4	24.6	21.3	16.0	14.0		
		MCWB	11.2	11.3	11.5	14.4	16.2	18.5	19.0	19.9	18.3	16.4	14.1	12.0		
	2%	DB	11.8	12.3	13.9	17.1	19.6	22.6	24.1	24.3	21.9	18.5	14.4	12.7		
		MCWB	10.1	10.0	10.7	12.3	14.4	17.4	18.0	18.2	16.8	15.5	12.7	11.1		
	5%	DB	10.4	10.9	12.3	15.0	17.5	20.5	22.2	22.3	19.9	16.9	13.2	11.4		
		MCWB	8.9	8.9	9.8	11.0	13.4	16.0	17.6	17.4	16.1	14.4	11.7	10.0		
	10%	DB	9.2	9.6	11.0	13.3	15.8	18.8	20.7	20.8	18.4	15.8	12.1	10.1		
		MCWB	7.8	7.9	8.7	10.2	12.4	15.0	16.9	17.0	15.2	13.7	10.8	8.8		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	11.6	11.9	12.6	14.7	17.4	20.0	21.8	20.8	19.3	17.3	14.4	12.2		
		MCDB	12.9	13.9	14.6	19.2	20.8	24.8	23.9	24.4	22.5	20.6	15.6	13.4		
	2%	WB	10.3	10.3	11.3	12.8	15.2	17.8	19.3	19.2	17.8	15.9	13.1	11.3		
		MCDB	11.6	11.9	13.3	16.4	18.4	21.2	22.2	22.6	20.6	18.1	14.1	12.5		
	5%	WB	9.1	9.2	10.0	11.5	13.9	16.6	18.2	18.4	16.8	14.9	12.0	10.1		
		MCDB	10.3	10.7	12.0	14.2	16.7	19.7	21.0	21.1	19.0	16.4	13.0	11.2		
	10%	WB	7.9	8.0	9.0	10.5	12.9	15.6	17.4	17.6	15.9	14.1	10.9	9.0		
		MCDB	9.0	9.5	10.8	12.9	15.3	18.2	20.0	20.0	17.8	15.5	12.0	10.1		
(35) Mean Daily Temperature Range	5% DB	MDBR	4.2	4.6	5.5	6.3	6.2	6.6	6.9	6.8	6.3	5.5	4.7	4.2		
		MCDBR	5.8	6.1	7.4	9.3	9.2	9.5	9.6	9.3	8.7	6.6	5.3	5.3		
		MCWBR	5.5	4.7	5.2	5.6	5.4	5.5	5.0	4.8	4.8	4.5	4.6	4.9		
	5% WB	MCDBR	5.7	5.9	7.0	8.7	8.3	8.7	8.3	7.9	7.5	6.3	5.2	5.4		
		MCWBR	5.5	4.9	5.3	5.6	5.5	5.6	5.2	4.9	4.9	4.8	4.8	5.0		
(40) Clear-Sky Solar Irradiance	taub		0.328	0.345	0.378	0.402	0.402	0.408	0.409	0.398	0.379	0.358	0.332	0.316		
	taud		2.350	2.379	2.294	2.253	2.314	2.315	2.322	2.369	2.417	2.440	2.401	2.335		
	Ebn at Noon		646	758	801	828	848	845	836	825	796	733	639	585		
	Edh at Noon		60	78	103	121	120	121	119	107	91	73	57	51		
(44) All-Sky Solar Radiation	RadAvg		0.69	1.37	2.55	4.03	4.98	5.21	5.00	4.24	3.11	1.77	0.86	0.54		
	RadStd		0.07	0.20	0.25	0.41	0.38	0.38	0.47	0.29	0.26	0.14	0.09	0.06		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Regional (61 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+67	N/A
	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page