

COLTISHALL, United Kingdom

WMO: 034950

Lat: 52.755N

Lon: 1.358E

Elev: 20

StdP: 101.08

Time Zone: 0.00 (EUW)

Period: 94-06

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -2.7	(c) -1.5	(d) -5.7	(e) 2.3	(f) -0.5	(g) -4.4	(h) 2.6	(i) 0.6	(j) 14.9	(k) 9.3	(l) 13.5	(m) 9.0	(n) 2.1	(o) 90	(p) 0.615

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 8	(b) 8.6	(c) 26.0	(d) 18.7	(e) 24.0	(f) 17.9	(g) 22.4	(h) 17.1	(i) 19.5	(j) 24.1	(k) 18.6	(l) 22.7	(m) 17.8	(n) 21.3	(o) 4.7	(p) 90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a) 17.8	(b) 12.8	(c) 21.2	(d) 17.1	(e) 12.2	(f) 20.2	(g) 16.3	(h) 11.6	(i) 19.4	(j) 55.7	(k) 24.4	(l) 52.7	(m) 22.9	(n) 50.1	(o) 21.5	(p) 23.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
Min		Max		Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12.0	10.6	9.4	DB	-6.1	30.3	1.8	1.3	-7.4	31.2	-8.4	32.0	-9.5	32.7	-10.8	33.7
			WB	-6.4	21.5	1.7	0.8	-7.6	22.1	-8.7	22.5	-9.6	23.0	-10.9	23.6

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	10.3	4.6	5.0	6.5	8.6	11.6	14.5	16.7	17.1	14.5	11.2	7.5	4.9
	DBStd	5.28	2.84	3.20	3.08	2.88	2.89	2.75	2.42	2.58	2.25	2.72	2.89	3.16
	HDD10.0	763	167	141	116	61	17	1	0	0	0	18	83	161
	HDD18.3	2986	424	372	367	292	209	121	63	56	118	221	324	417
	CDD10.0	857	1	2	6	18	66	134	208	221	134	55	9	2
	CDD18.3	38	0	0	0	0	1	4	12	19	2	0	0	0
	CDH23.3	236	0	0	0	0	3	41	78	104	9	0	0	0
	CDH26.7	34	0	0	0	0	0	9	9	15	1	0	0	0
Wind	WSAvg	4.3	5.2	5.4	4.8	4.3	4.1	3.9	3.6	3.4	3.9	4.5	4.3	4.7
Precipitation	PrecAvg	630	53	38	47	47	44	54	56	54	54	59	67	60
	PrecMax	818	109	93	87	138	93	140	167	124	148	144	150	120
	PrecMin	483	9	2	13	4	8	7	4	4	8	10	21	24
	PrecStd	83	26	21	22	28	22	34	34	31	35	38	26	25
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	12.9	14.5	16.1	20.0	23.5	27.7	27.9	28.6	24.6	20.2	16.0	13.9
		MCWB	10.5	11.6	11.9	13.6	16.8	18.4	19.2	19.5	17.5	16.1	14.1	12.0
	2%	DB	11.5	12.6	14.4	17.1	20.9	23.8	25.7	26.1	22.3	17.9	14.4	12.5
		MCWB	9.7	10.1	10.8	12.2	15.1	17.8	18.4	19.3	16.5	14.8	12.7	10.9
	5%	DB	10.2	11.2	13.0	15.3	18.8	21.6	23.5	24.1	20.2	16.6	13.1	11.0
		MCWB	8.6	9.0	10.1	10.9	14.3	16.3	17.5	18.3	15.5	14.1	11.4	9.5
	10%	DB	9.0	10.0	11.6	13.8	17.0	19.7	21.8	22.2	18.6	15.6	11.9	9.6
		MCWB	7.6	8.1	9.2	10.2	13.0	15.0	16.9	17.4	14.8	13.5	10.4	8.3
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	11.1	11.9	12.9	14.3	18.6	20.0	20.4	20.9	18.7	17.0	14.3	12.2
		MCDB	12.2	13.8	15.3	18.8	21.9	25.2	25.2	26.2	22.9	19.6	15.6	13.4
	2%	WB	9.9	10.4	11.5	12.8	16.0	18.1	19.2	19.7	17.4	15.6	13.0	11.2
		MCDB	11.1	12.3	13.6	16.1	19.7	22.7	23.9	24.3	20.5	17.2	14.1	12.4
	5%	WB	8.8	9.2	10.5	11.5	14.5	16.9	18.2	18.9	16.5	14.7	11.7	9.8
		MCDB	10.0	10.8	12.5	14.5	18.4	20.5	22.3	22.9	18.9	16.1	12.8	10.9
	10%	WB	7.8	8.2	9.4	10.4	13.3	15.9	17.4	18.0	15.6	13.9	10.7	8.5
		MCDB	8.9	9.8	11.3	13.2	16.6	19.0	20.9	21.4	17.7	15.4	11.7	9.5
Mean Daily Temperature Range	5% DB	MDBR	4.8	5.6	6.5	7.6	7.8	8.2	8.2	8.6	7.6	6.8	5.8	4.8
		MCDBR	6.1	6.4	8.3	10.1	11.2	11.3	11.6	11.5	10.4	7.8	6.2	5.5
		MCWBR	5.6	5.0	5.6	5.8	6.6	6.3	5.4	5.3	5.6	5.4	5.1	5.0
	5% WB	MCDBR	6.0	6.3	7.5	9.6	10.9	10.3	10.4	10.5	9.1	7.3	5.7	5.6
		MCWBR	5.7	5.2	5.6	5.8	6.8	6.2	5.4	5.1	5.4	5.6	5.1	5.2
Clear-Sky Solar Irradiance	taub	0.327	0.344	0.378	0.401	0.403	0.408	0.409	0.398	0.378	0.358	0.331	0.316	
	taud	2.349	2.375	2.285	2.245	2.297	2.300	2.309	2.355	2.407	2.431	2.398	2.336	
	Ebn at Noon	651	760	802	830	848	845	836	825	797	735	643	590	
	Edh at Noon	61	79	105	123	122	123	120	109	92	74	58	52	
All-Sky Solar Radiation	RadAvg	0.70	1.39	2.53	3.99	4.90	5.15	4.94	4.17	3.09	1.78	0.88	0.56	
	RadStd	0.07	0.20	0.26	0.41	0.37	0.39	0.49	0.29	0.26	0.15	0.09	0.06	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (61 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page