

HEMSBY, United Kingdom

WMO: 034960

Lat: 52.683N

Lon: 1.683E

Elev: 46

StdP: 14.67

Time Zone: 0.00 (EUW)

Period: 90-01

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	28.2	30.3	22.6	17.0	32.1	24.9	19.0	33.8	36.1	45.3	33.2	44.2	10.9	80	0.669

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	13.4	75.2	64.7	72.4	63.6	69.9	62.2	66.3	72.4	64.8	70.3	63.5	68.4	11.8	240

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
63.7	88.6	69.1	62.5	84.8	67.5	61.2	80.9	66.2	30.9	72.1	29.8	70.6	28.8	68.5	73.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 29.8	26.5	23.5	DB	23.6	82.4	3.1	3.2	21.4	84.6	19.6	86.5	17.8	88.2	15.5	90.5	(4)
(5)			WB	22.9	69.6	2.9	2.1	20.8	71.0	19.2	72.2	17.6	73.4	15.5	74.9	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	50.2	40.7	41.0	44.2	47.1	52.3	56.9	61.3	62.4	57.9	51.8	45.4	41.2	(6)	
	DBStd	9.05	4.76	5.64	4.86	4.86	4.82	4.51	4.11	4.18	3.82	4.91	5.20	5.36	(7)	
	HDD50	1346	288	255	189	114	30	2	0	0	0	36	155	277	(8)	
	HDD65	5425	752	672	645	537	393	245	128	103	215	408	588	739	(9)	
	CDD50	1439	1	3	9	27	102	210	351	385	237	93	17	4	(10)	
	CDD65	43	0	0	0	0	0	4	14	23	2	0	0	0	(11)	
	CDH74	145	0	0	0	0	1	21	59	61	3	0	0	0	(12)	
	CDH80	11	0	0	0	0	0	4	3	4	0	0	0	0	(13)	
(14) Wind	WSAvg	11.7	13.7	13.7	12.9	11.8	11.0	10.2	9.6	9.7	10.5	12.0	12.0	13.3	(14)	
(15) Precipitation	PrecAvg	23.2	1.9	1.4	1.5	1.7	1.8	1.7	2.0	2.2	2.2	2.4	2.5	2.2	(15)	
	PrecMax	31.7	3.9	2.8	3.1	4.0	3.8	3.9	4.3	4.8	5.0	6.4	5.1	4.1	(16)	
	PrecMin	16.5	0.4	0.5	0.3	0.2	0.2	0.2	0.3	0.2	0.3	0.3	0.9	1.0	(17)	
	PrecStd	3.3	0.7	0.7	0.8	0.9	0.9	1.1	1.1	1.2	1.4	1.7	0.9	0.9	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	54.4	57.6	60.2	65.8	71.6	76.7	79.3	79.4	72.8	67.0	60.1	57.0	(19)	
		MCWB	50.5	52.4	53.0	55.9	60.8	64.6	65.6	65.8	63.8	60.4	56.5	53.5	(20)	
	2%	DB	52.3	53.8	56.9	60.1	66.5	71.3	75.2	75.2	69.1	63.4	57.4	54.4	(21)	
		MCWB	49.1	49.5	51.0	52.9	57.6	62.9	64.9	65.1	61.3	58.6	54.6	51.5	(22)	
	5%	DB	50.4	51.4	54.4	57.3	63.4	67.8	71.6	72.6	66.2	61.2	54.9	52.2	(23)	
		MCWB	47.6	47.8	49.6	51.2	56.3	60.1	63.3	64.0	59.8	57.0	52.3	49.7	(24)	
	10%	DB	48.2	49.4	52.1	55.0	60.3	64.9	69.0	70.2	64.2	59.3	53.1	49.4	(25)	
		MCWB	45.7	46.3	48.2	49.9	54.6	58.3	62.2	62.5	58.9	55.5	51.0	47.1	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	51.3	53.0	54.5	56.6	61.7	66.5	68.3	68.3	65.2	61.7	57.3	53.9	(27)	
		MCDB	53.5	56.6	59.7	63.0	69.1	74.2	75.6	75.1	70.0	66.3	59.5	56.2	(28)	
	2%	WB	49.9	50.5	52.1	53.9	58.9	63.8	66.0	66.4	63.1	59.5	54.8	52.1	(29)	
		MCDB	52.0	53.5	55.9	58.6	65.1	69.4	71.9	72.6	66.9	62.4	56.6	54.1	(30)	
	5%	WB	47.8	48.3	50.3	52.0	56.9	61.1	64.3	65.1	61.6	58.0	53.0	49.9	(31)	
		MCDB	50.2	50.9	53.5	56.2	62.4	66.7	69.9	70.8	64.7	60.5	54.5	52.1	(32)	
	10%	WB	45.9	46.5	48.6	50.3	55.0	59.2	62.9	63.8	60.2	56.4	51.3	47.2	(33)	
		MCDB	48.0	49.1	51.9	54.2	59.4	63.9	68.0	68.8	63.1	58.8	52.8	49.0	(34)	
(35) Mean Daily Temperature Range	MDBR		8.0	9.4	10.2	11.3	11.6	12.5	12.9	13.4	11.5	10.5	8.9	7.6	(35)	
	5% DB	MCDBR	10.7	11.2	13.5	14.9	17.2	17.1	17.6	16.7	13.8	12.4	8.7	10.1	(36)	
		MCWBR	9.8	9.1	9.3	9.1	10.1	10.0	9.2	8.3	8.3	8.7	7.4	9.4	(37)	
	5% WB	MCDBR	10.6	11.1	12.6	13.1	16.2	16.2	15.8	15.0	11.8	11.5	8.7	10.2	(38)	
		MCWBR	10.0	9.5	9.5	8.8	10.1	10.3	9.0	8.1	7.9	8.8	7.7	9.7	(39)	
(40) Clear-Sky Solar Irradiance	taub		0.329	0.345	0.379	0.402	0.404	0.409	0.410	0.400	0.381	0.360	0.333	0.318	(40)	
	taud		2.350	2.378	2.291	2.259	2.313	2.317	2.326	2.368	2.416	2.432	2.397	2.340	(41)	
	Ebn at Noon		207	241	254	263	269	268	265	261	252	233	204	187	(42)	
	Edh at Noon		19	25	33	38	38	38	37	34	29	23	18	16	(43)	
(44) All-Sky Solar Radiation	RadAvg		223	442	813	1293	1581	1668	1597	1348	992	566	277	175	(44)	
	RadStd		21	67	84	130	116	118	162	94	80	49	28	20	(45)	

Historical Trends

		DBAvg		Heating		Cooling		Degree-Days				
				99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(46)
(47)	Regional (66 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(47)

Nomenclature: See separate page