

HEREFORD CREDENHILL, United Kingdom

WMO: 035220

Lat: 52.0800N

Lon: 2.8025W

Elev: 249

StdP: 14.56

Time Zone: 0.00 (EUW)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	23.7	26.8	20.9	15.8	27.9	23.5	17.9	30.0	38.1	48.3	30.5	47.5	2.8	50	0.518

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	17.3	78.8	65.9	75.2	64.2	72.2	62.7	67.4	75.5	65.4	72.6	63.9	70.3	5.8	170

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
64.4	91.4	70.4	62.7	85.9	68.8	61.2	81.5	66.9	31.9	75.9	30.4	72.3	29.2	70.3	77.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 20.8	16.8	14.2	DB	17.5	84.5	4.2	4.0	14.4	87.4	12.0	89.8	9.6	92.0	6.5	95.0	(4)
(5)			WB	17.0	71.8	4.2	3.5	14.0	74.3	11.5	76.4	9.1	78.4	6.1	80.9	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	50.3	40.6	40.9	43.7	48.2	53.3	58.9	62.1	61.0	57.0	51.6	45.1	41.1	(6)
(7)		DBStd	9.42	6.37	5.88	5.37	4.83	4.96	4.40	4.42	3.97	4.26	5.42	6.03	6.98	(7)
(8)		HDD50	1362	295	259	203	89	21	0	0	0	3	45	165	282	(8)
(9)		HDD65	5393	757	675	660	505	362	189	114	136	242	416	597	740	(9)
(10)		CDD50	1488	3	4	8	34	124	268	374	341	212	95	18	7	(10)
(11)		CDD65	42	0	0	0	0	0	6	24	11	1	0	0	0	(11)
(12)		CDH74	425	0	0	0	1	15	81	236	76	12	4	0	0	(12)
(13)		CDH80	62	0	0	0	0	0	10	41	11	0	0	0	0	(13)
(14)	Wind	WSAvg	5.8	6.9	7.0	7.0	6.3	6.1	5.3	4.9	4.7	4.3	5.3	5.8	6.2	(14)
(15)	Precipitation	PrecAvg	31.8	3.5	2.6	2.0	2.2	2.4	2.1	2.2	2.3	2.4	3.5	3.2	3.4	(15)
(16)		PrecMax	41.3	7.2	6.9	3.8	6.2	4.2	5.8	6.5	5.9	5.8	6.9	6.2	6.6	(16)
(17)		PrecMin	20.8	0.3	0.2	0.4	0.2	0.2	0.4	0.3	0.4	0.4	0.6	1.5	0.9	(17)
(18)		PrecStd	5.0	1.5	1.6	1.0	1.5	0.9	1.4	1.4	1.4	1.4	1.6	1.2	1.6	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	56.5	56.9	62.5	71.0	76.1	81.3	84.6	80.8	76.0	67.8	60.6	57.3	(19)
(20)			MCWB	53.2	53.0	52.5	59.0	64.1	66.8	67.8	69.4	65.6	61.3	57.0	53.6	(20)
(21)		2%	DB	54.4	54.4	57.9	65.0	71.3	75.8	80.0	75.5	71.0	64.1	58.1	55.4	(21)
(22)			MCWB	51.4	50.9	51.4	55.6	60.8	64.3	65.7	65.3	63.6	59.2	55.0	52.7	(22)
(23)		5%	DB	52.2	52.4	55.0	61.0	66.9	72.3	76.2	72.2	68.4	61.9	56.4	53.6	(23)
(24)			MCWB	49.4	49.1	49.9	53.3	58.3	62.5	64.3	63.5	61.4	57.7	53.6	51.0	(24)
(25)		10%	DB	50.2	50.2	53.0	57.7	63.2	69.0	72.4	69.7	66.0	60.0	54.4	51.6	(25)
(26)			MCWB	47.8	47.3	48.6	51.2	55.8	60.5	62.3	62.2	59.6	56.3	51.9	49.0	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	53.8	54.1	54.0	60.3	65.1	70.0	69.2	70.9	67.4	62.6	57.9	54.8	(27)
(28)			MCDW	55.8	56.4	58.5	67.6	73.4	79.6	81.4	77.8	71.6	66.4	59.5	56.2	(28)
(29)		2%	WB	52.0	51.4	52.5	56.6	62.0	65.5	66.8	67.3	64.7	60.4	55.8	53.1	(29)
(30)			MCDW	54.1	53.9	56.5	63.1	69.7	73.1	76.9	73.7	69.7	63.0	57.4	54.9	(30)
(31)		5%	WB	49.9	49.7	50.8	54.3	59.2	63.1	65.0	65.0	62.7	58.7	54.1	51.4	(31)
(32)			MCDW	51.8	52.1	54.6	59.4	65.0	70.4	73.7	70.0	67.2	61.0	55.9	53.5	(32)
(33)		10%	WB	48.0	47.7	49.1	52.2	57.2	61.4	63.4	63.2	60.8	57.0	52.1	49.3	(33)
(34)			MCDW	50.0	49.9	52.5	56.8	62.1	67.7	70.7	68.0	64.6	59.3	54.2	51.3	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	10.8	11.6	14.5	16.8	16.9	17.1	17.3	16.7	17.1	13.4	11.8	10.6	(35)
(36)			MCDBR	12.0	13.0	17.8	22.8	22.9	23.3	24.2	20.6	20.9	14.4	12.3	10.9	(36)
(37)			MCWBR	11.0	10.0	12.4	14.3	13.5	13.3	11.8	11.8	13.3	10.0	10.4	9.9	(37)
(38)		5% WB	MCDBR	11.4	12.6	17.1	20.6	20.3	20.8	21.2	18.5	19.3	13.5	12.3	11.0	(38)
(39)			MCWBR	11.0	10.4	12.5	13.9	12.7	12.7	11.4	12.0	13.6	10.5	10.9	10.4	(39)
(40)																
(41)	Clear-Sky Solar Irradiance	taub	0.321	0.337	0.369	0.393	0.399	0.392	0.389	0.375	0.364	0.348	0.322	0.311	(41)	
(42)		taud	2.345	2.374	2.283	2.232	2.252	2.302	2.313	2.372	2.402	2.419	2.397	2.321	(42)	
(43)		Ebn at Noon	213	246	259	266	271	273	272	270	259	239	212	194	(43)	
		Edh at Noon	20	25	33	40	41	39	38	34	30	24	19	17		
(44)	All-Sky Solar Radiation	RadAvg	238	448	805	1238	1530	1645	1536	1262	955	539	284	183	(44)	
(45)		RadStd	21	51	99	143	85	178	160	104	73	49	29	21	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (81 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page