

WYTON, United Kingdom

WMO: 035660

Lat: 52.357N

Lon: 0.108W

Elev: 135

StdP: 14.62

Time Zone: 0.00 (EUW)

Period: 86-95

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	23.3	26.7	19.4	14.7	26.0	22.7	17.1	29.7	33.6	46.4	30.1	44.6	7.6	50	0.639

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	16.4	79.5	64.3	76.3	62.6	73.2	61.4	66.0	76.3	64.2	72.7	62.8	70.5	9.5	220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
62.4	84.8	68.7	61.0	80.6	67.5	59.5	76.2	66.0	30.8	76.6	29.4	72.7	28.4	70.3	73.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 27.1	23.6	21.1	DB	18.9	85.3	6.4	4.9	14.3	88.8	10.6	91.7	7.0	94.5	2.3	98.0	(4)
(5)			WB	18.3	69.2	6.3	2.1	13.8	70.7	10.1	71.9	6.5	73.1	2.0	74.7	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	49.9	40.0	39.3	44.0	46.6	53.0	57.7	62.6	61.8	56.8	50.7	44.2	41.6
	DBStd	9.77	6.13	7.06	5.44	5.57	5.06	5.47	4.61	4.86	4.53	5.30	5.81	6.24
	HDD50	1482	310	301	196	134	23	4	0	0	3	57	187	267
	HDD65	5561	774	719	650	553	371	227	104	123	249	442	623	726
	CDD50	1463	1	3	10	31	118	235	391	367	206	80	14	7
	CDD65	65	0	0	0	0	1	8	29	25	2	0	0	0
	CDH74	555	0	0	0	0	23	83	248	182	19	0	0	0
	CDH80	89	0	0	0	0	1	4	44	38	2	0	0	0
Wind	WSAvg	10.5	12.0	12.0	12.4	11.0	9.9	9.0	9.4	9.5	9.5	9.9	9.8	11.5
Precipitation	PrecAvg	21.1	1.7	1.2	1.6	1.7	1.8	1.9	1.8	2.0	2.0	1.8	1.9	1.8
	PrecMax	28.7	3.5	2.9	3.2	3.7	4.2	4.8	4.8	4.2	4.8	5.2	3.9	3.9
	PrecMin	11.0	0.3	0.4	0.1	0.3	0.2	0.1	0.3	0.4	0.2	0.1	0.9	0.4
	PrecStd	3.5	0.7	0.6	0.9	0.9	1.0	1.1	1.0	1.0	1.3	1.3	0.8	1.0
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	54.6	56.8	62.3	68.9	76.9	80.3	84.9	85.4	76.8	68.2	59.2	57.1
		MCWB	51.2	52.0	52.9	56.7	61.5	65.4	65.6	66.0	61.8	59.7	56.1	53.4
	2%	DB	52.6	53.6	57.5	64.2	71.8	76.4	80.0	78.3	71.1	63.8	57.2	55.5
		MCWB	49.4	49.6	50.6	54.6	60.4	62.8	64.5	63.6	61.1	56.9	54.2	52.1
	5%	DB	51.0	51.3	54.6	59.4	67.5	72.7	76.4	75.0	67.8	61.0	55.2	53.5
		MCWB	47.9	47.9	49.2	51.9	57.3	61.3	63.3	62.0	58.3	55.5	52.6	50.5
	10%	DB	48.8	49.1	52.3	56.2	63.7	68.8	72.7	71.7	65.1	58.8	53.2	51.2
		MCWB	46.1	45.9	47.6	50.1	55.1	59.5	61.6	60.8	57.2	54.6	50.9	48.6
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	51.9	52.6	53.7	59.1	63.7	68.6	68.2	67.3	64.2	60.6	56.5	54.2
		MCDB	54.2	55.4	60.6	67.8	74.0	74.7	79.3	79.2	69.9	66.5	58.5	56.4
	2%	WB	50.2	50.1	51.8	55.5	61.0	64.4	66.2	65.5	62.1	58.3	54.7	52.5
		MCDB	52.4	52.9	55.9	61.9	70.1	74.1	76.7	75.7	68.4	61.8	56.7	55.2
	5%	WB	48.2	48.3	50.1	52.8	58.6	62.4	64.4	63.6	60.6	56.8	52.9	50.8
		MCDB	50.3	51.0	53.4	58.1	66.4	70.4	72.7	71.7	66.1	59.8	54.8	53.2
	10%	WB	46.4	46.3	48.6	50.6	56.0	60.3	62.8	62.1	58.9	55.3	51.2	48.6
		MCDB	48.6	48.8	51.8	55.8	62.7	68.0	70.4	69.7	63.1	58.3	52.9	50.9
Mean Daily Temperature Range	5% DB	MDBR	9.0	9.9	12.4	14.0	16.2	15.6	16.4	16.4	14.1	12.0	9.8	8.4
		MCDBR	11.1	11.3	14.5	18.5	23.9	22.2	23.1	21.4	18.4	14.5	10.0	10.1
		MCWBR	10.2	8.8	9.5	10.8	13.2	11.2	10.3	9.2	9.8	9.0	8.3	9.1
	5% WB	MCDBR	11.2	11.4	13.0	17.5	22.8	20.0	19.7	18.8	15.9	12.7	10.3	9.8
		MCWBR	10.7	9.5	9.8	11.1	13.4	11.1	9.9	9.0	9.9	9.2	9.0	9.0
Clear-Sky Solar Irradiance	taub	0.324	0.340	0.374	0.399	0.403	0.406	0.405	0.393	0.373	0.354	0.328	0.313	
	taud	2.369	2.385	2.282	2.225	2.253	2.267	2.281	2.335	2.396	2.434	2.415	2.351	
	Ebn at Noon	211	244	256	264	269	269	267	264	255	236	209	193	
	Edh at Noon	19	25	33	40	41	41	39	35	30	23	18	16	
All-Sky Solar Radiation	RadAvg	239	456	801	1242	1518	1627	1558	1296	973	566	294	192	
	RadStd	22	60	95	133	104	147	165	94	84	50	32	22	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (89 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page