

HONINGTON, United Kingdom

WMO: 035860

Lat: 52.333N

Lon: 0.767E

Elev: 174

StdP: 14.60

Time Zone: 0.00 (EUW)

Period: 86-03

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 23.9	(c) 26.8	(d) 19.3	(e) 14.6	(f) 25.8	(g) 22.7	(h) 17.2	(i) 29.5	(j) 31.5	(k) 47.0	(l) 28.8	(m) 46.0	(n) 5.7	(o) 50	(p) 0.608

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 8	(b) 16.7	(c) 79.3	(d) 64.4	(e) 76.0	(f) 63.0	(g) 73.0	(h) 61.7	(i) 66.5	(j) 75.6	(k) 64.6	(l) 72.8	(m) 63.0	(n) 70.0	(o) 9.5	(p) 250

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
63.1	87.1	69.1	61.6	82.3	67.4	60.1	78.2	65.9	31.1	75.8	29.7	73.0	28.6	69.9	79.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 26.8	(b) 22.9	(c) 20.3	(e) 19.7	(f) 86.1	(g) 5.1	(h) 4.2	(i) 16.0	(j) 89.1	(k) 13.0	(l) 91.5	(m) 10.1	(n) 93.8	(o) 6.4	(p) 96.9		
(a) 26.8	(b) 22.9	(c) 20.3	(e) 19.2	(f) 70.9	(g) 5.1	(h) 3.6	(i) 15.6	(j) 73.5	(k) 12.6	(l) 75.6	(m) 9.7	(n) 77.5	(o) 6.0	(p) 80.1		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	49.9	39.5	39.6	43.8	46.2	53.6	57.5	61.9	62.3	57.4	51.8	43.7	40.8
	DBStd	9.89	6.21	6.88	5.46	5.42	5.23	5.39	4.50	4.84	4.78	4.99	5.28	6.31
	HDD50	1523	328	295	202	140	24	4	0	0	3	39	197	291
	HDD65	5576	791	712	659	564	354	234	120	113	231	409	638	751
	CDD50	1484	1	3	8	26	135	228	368	381	225	95	9	5
	CDD65	63	0	0	0	0	0	8	23	29	3	0	0	0
	CDH74	526	0	0	0	0	17	72	192	220	25	0	0	0
	CDH80	84	0	0	0	0	0	8	28	46	2	0	0	0
Wind	WSAvg	9.4	10.8	11.3	11.1	9.9	8.5	7.9	8.0	7.8	8.2	9.6	9.2	10.4
Precipitation	PrecAvg	24.0	2.0	1.7	1.5	1.6	1.9	2.1	2.2	2.4	2.0	2.4	2.4	2.0
	PrecMax	30.4	3.9	3.3	3.5	4.4	4.5	5.6	4.2	5.2	4.3	4.6	4.4	3.9
	PrecMin	16.5	0.3	0.2	0.2	0.0	0.5	0.5	0.7	0.2	0.5	0.3	0.8	0.8
	PrecStd	4.0	0.9	0.8	0.8	1.1	1.1	1.3	0.9	1.3	1.1	1.0	0.9	0.9
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	54.8	56.6	61.3	67.7	76.2	80.0	83.4	85.3	77.0	68.1	58.3	56.2
		MCWB	51.2	51.1	52.1	56.1	61.3	64.7	66.3	65.5	63.8	59.6	54.5	53.2
	2%	DB	52.9	54.3	57.3	62.5	72.1	75.6	79.2	79.3	72.2	64.0	55.7	54.7
		MCWB	49.9	50.2	50.4	53.6	60.3	63.6	64.6	64.0	61.7	58.1	53.0	51.7
	5%	DB	50.7	51.9	54.8	59.0	68.3	71.5	75.4	75.5	68.8	61.8	54.0	52.8
		MCWB	47.9	48.2	49.5	51.3	57.7	61.4	62.8	62.8	60.2	56.8	51.4	50.1
	10%	DB	48.6	49.6	52.5	56.0	64.5	67.8	71.8	72.3	65.7	59.5	52.1	50.6
		MCWB	46.2	46.5	48.1	49.6	55.8	59.1	61.5	61.1	58.5	55.6	49.6	48.3
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	52.0	52.7	54.1	57.5	63.6	69.8	69.4	68.2	66.4	60.8	55.4	54.0
		MCDB	54.2	55.3	60.0	66.1	73.1	78.2	79.6	79.7	74.9	65.4	57.0	55.7
	2%	WB	50.2	50.5	52.0	54.6	60.8	64.7	66.2	66.0	63.1	59.1	53.6	52.1
		MCDB	52.5	53.5	55.5	60.3	70.7	71.6	75.0	75.8	68.9	62.4	55.1	54.3
	5%	WB	48.3	48.7	50.3	52.3	58.5	62.2	64.3	64.3	61.6	57.7	51.8	50.3
		MCDB	50.3	51.4	53.6	57.6	67.0	69.8	72.7	72.5	66.5	60.7	54.0	52.3
	10%	WB	46.3	46.6	48.7	50.3	56.2	59.9	62.7	62.7	60.1	56.3	49.7	48.5
		MCDB	48.5	49.4	51.9	55.3	63.5	66.6	69.7	69.1	64.3	59.2	51.7	50.6
Mean Daily Temperature Range	5% DB	MDBR	9.0	10.5	12.7	14.1	16.6	15.8	16.1	16.7	14.7	12.0	10.2	8.6
		MCDBR	10.2	11.8	15.5	18.1	23.7	21.6	22.6	21.9	18.7	13.8	10.8	9.3
		MCWBR	9.5	9.4	10.3	10.4	13.1	11.4	10.4	9.1	9.9	8.8	9.2	8.3
	5% WB	MCDBR	10.3	11.3	13.8	16.3	22.4	19.9	19.4	18.7	15.9	12.7	10.8	9.4
		MCWBR	9.8	9.8	10.1	10.3	13.0	12.0	10.0	9.1	9.6	9.3	9.8	8.8
Clear-Sky Solar Irradiance	taub	0.326	0.343	0.377	0.401	0.406	0.409	0.408	0.397	0.376	0.357	0.330	0.315	
	taud	2.356	2.370	2.268	2.219	2.251	2.261	2.276	2.327	2.385	2.420	2.404	2.344	
	Ebn at Noon	210	243	255	264	268	268	266	262	254	234	207	191	
	Edh at Noon	19	25	34	40	41	41	40	36	30	24	18	17	
All-Sky Solar Radiation	RadAvg	233	449	801	1263	1527	1631	1557	1310	984	572	289	185	
	RadStd	22	66	90	130	115	127	160	94	81	52	31	23	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (76 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page