

HONINGTON, United Kingdom

WMO: 035860

Lat: 52.333N

Lon: 0.767E

Elev: 53

StdP: 100.69

Time Zone: 0.00 (EUW)

Period: 86-03

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -4.5	(c) -2.9	(d) -7.0	(e) 2.1	(f) -3.4	(g) -5.2	(h) 2.5	(i) -1.4	(j) 14.1	(k) 8.3	(l) 12.9	(m) 7.8	(n) 2.5	(o) 50	(p) 0.608

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 8	(b) 9.3	(c) 26.3	(d) 18.0	(e) 24.4	(f) 17.2	(g) 22.8	(h) 16.5	(i) 19.1	(j) 24.2	(k) 18.1	(l) 22.7	(m) 17.2	(n) 21.1	(o) 4.2	(p) 250

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
17.3	12.4	20.6	16.4	11.8	19.7	15.6	11.2	18.9	54.5	24.4	51.2	22.8	48.6	21.0	26.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 12.0	(b) 10.3	(c) 9.1	(e) -6.8	(f) 30.0	(g) 2.9	(h) 2.3	(i) -8.9	(j) 31.7	(k) -10.5	(l) 33.1	(m) -12.1	(n) 34.4	(o) -14.2	(p) 36.0		
(a) 12.0	(b) 10.3	(c) 9.1	(e) -7.1	(f) 21.6	(g) 2.8	(h) 2.0	(i) -9.1	(j) 23.0	(k) -10.8	(l) 24.2	(m) -12.4	(n) 25.3	(o) -14.4	(p) 26.7		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	9.9	4.2	4.2	6.5	7.9	12.0	14.1	16.6	16.8	14.1	11.0	6.5	4.9
	DBStd	5.50	3.45	3.82	3.03	3.01	2.91	2.99	2.50	2.69	2.66	2.77	2.93	3.51
	HDD10.0	846	182	164	112	78	13	2	0	0	2	22	109	162
	HDD18.3	3098	439	396	366	313	197	130	67	63	128	227	354	417
	CDD10.0	824	1	2	4	14	75	127	204	212	125	53	5	3
	CDD18.3	35	0	0	0	0	0	4	13	16	2	0	0	0
	CDH23.3	292	0	0	0	0	9	40	107	122	14	0	0	0
	CDH26.7	47	0	0	0	0	0	4	16	26	1	0	0	0
Wind	WSAvg	4.2	4.8	5.1	4.9	4.4	3.8	3.5	3.6	3.5	3.6	4.3	4.1	4.7
Precipitation	PrecAvg	610	51	42	37	40	47	53	55	62	50	60	62	52
	PrecMax	773	100	85	90	112	114	143	106	132	110	118	111	98
	PrecMin	419	8	6	4	1	12	13	19	5	12	8	21	21
	PrecStd	102	22	21	21	28	27	33	24	34	27	26	24	23
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	12.7	13.7	16.3	19.8	24.6	26.7	28.6	29.6	25.0	20.1	14.6	13.5
		MCWB	10.7	10.6	11.2	13.4	16.3	18.1	19.1	18.6	17.7	15.3	12.5	11.8
	2%	DB	11.6	12.4	14.1	17.0	22.3	24.2	26.2	26.3	22.4	17.8	13.2	12.6
		MCWB	9.9	10.1	10.2	12.0	15.7	17.6	18.1	17.8	16.5	14.5	11.6	11.0
	5%	DB	10.4	11.1	12.7	15.0	20.2	22.0	24.1	24.2	20.4	16.5	12.2	11.6
		MCWB	8.8	9.0	9.7	10.7	14.3	16.3	17.1	17.1	15.6	13.8	10.8	10.1
	10%	DB	9.2	9.8	11.4	13.3	18.1	19.9	22.1	22.4	18.7	15.3	11.2	10.3
		MCWB	7.9	8.0	8.9	9.8	13.2	15.0	16.4	16.2	14.7	13.1	9.8	9.0
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	11.1	11.5	12.3	14.2	17.5	21.0	20.8	20.1	19.1	16.0	13.0	12.2
		MCDB	12.3	13.0	15.5	18.9	22.8	25.6	26.5	26.5	23.8	18.5	13.9	13.2
	2%	WB	10.1	10.3	11.1	12.5	16.0	18.1	19.0	18.9	17.3	15.1	12.0	11.2
		MCDB	11.4	11.9	13.1	15.7	21.5	22.0	23.9	24.3	20.5	16.9	12.9	12.4
	5%	WB	9.0	9.3	10.2	11.3	14.7	16.8	17.9	17.9	16.5	14.3	11.0	10.2
		MCDB	10.2	10.8	12.0	14.2	19.5	21.0	22.6	22.5	19.1	16.0	12.2	11.3
	10%	WB	7.9	8.1	9.3	10.2	13.5	15.5	17.0	17.1	15.6	13.5	9.8	9.2
		MCDB	9.2	9.7	11.1	12.9	17.5	19.2	20.9	20.6	17.9	15.1	10.9	10.3
Mean Daily Temperature Range	5% DB	MDBR	5.0	5.8	7.1	7.8	9.2	8.8	8.9	9.3	8.2	6.6	5.7	4.8
		MCDBR	5.7	6.6	8.6	10.0	13.2	12.0	12.6	12.2	10.4	7.7	6.0	5.2
		MCWBR	5.3	5.2	5.7	5.8	7.3	6.3	5.8	5.0	5.5	4.9	5.1	4.6
	5% WB	MCDBR	5.7	6.3	7.7	9.0	12.4	11.1	10.8	10.4	8.8	7.1	6.0	5.2
		MCWBR	5.4	5.4	5.6	5.7	7.2	6.6	5.6	5.1	5.3	5.2	5.4	4.9
Clear-Sky Solar Irradiance	taub	0.326	0.343	0.377	0.401	0.406	0.409	0.408	0.397	0.376	0.357	0.330	0.315	
	taud	2.356	2.370	2.268	2.219	2.251	2.261	2.276	2.327	2.385	2.420	2.404	2.344	
	Ebn at Noon	663	766	805	831	846	844	838	827	801	739	654	603	
	Edh at Noon	61	80	107	126	128	128	125	112	95	75	58	53	
All-Sky Solar Radiation	RadAvg	0.74	1.41	2.52	3.98	4.81	5.14	4.91	4.13	3.10	1.80	0.91	0.58	
	RadStd	0.07	0.21	0.28	0.41	0.36	0.40	0.50	0.30	0.26	0.16	0.10	0.07	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(47) Regional (76 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Nomenclature: See separate page