

BRAWDY, United KingdomWMO: **036030**Lat: **51.883N**Lon: **5.117W**Elev: **364**StdP: **14.50**Time Zone: **0.00 (EUW)**Period: **82-92**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	25.0	28.2	17.5	13.5	26.8	21.9	16.7	30.3	40.8	43.4	37.4	43.1	12.0	110	0.739

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.4	72.8	62.4	69.0	61.0	66.1	59.7	64.0	69.7	62.3	66.4	61.0	64.3	10.7	140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
62.1	84.4	64.9	60.8	80.5	63.5	59.5	77.0	62.0	29.3	70.2	28.2	66.3	27.2	64.5	71.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
33.4	29.7	26.6	DB	21.9	79.3	4.5	4.1	18.7	82.3	16.1	84.7	13.6	87.0	10.3	90.0
			WB	20.5	67.6	4.8	1.9	17.1	68.9	14.3	70.0	11.6	71.0	8.1	72.4

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	49.1	41.0	40.0	43.1	45.2	50.5	54.9	59.3	58.5	55.5	51.4	45.6	43.6
	DBStd	7.96	6.08	6.08	3.68	4.35	4.53	4.12	3.87	3.69	3.52	3.74	4.89	5.09
	HDD50	1355	280	281	215	154	44	6	0	0	2	28	145	200
	HDD65	5815	744	700	679	594	450	306	186	207	285	421	581	662
	CDD50	1030	0	1	1	10	60	152	288	262	167	72	13	4
	CDD65	13	0	0	0	0	0	1	8	4	0	0	0	0
	CDH74	69	0	0	0	0	2	5	34	28	0	0	0	0
	CDH80	7	0	0	0	0	0	0	1	6	0	0	0	0
	WSAvg	13.4	15.9	15.8	14.9	13.0	12.4	11.0	10.8	11.6	12.1	14.4	14.2	15.0
	PrecAvg	43.8	4.7	3.4	2.8	2.8	2.6	2.7	2.8	3.6	3.1	4.8	5.5	4.8
(15) Precipitation	PrecMax	52.2	7.8	8.2	5.6	5.9	5.7	5.8	7.7	7.8	5.7	8.1	10.7	8.9
	PrecMin	36.8	0.3	0.8	1.0	0.9	0.3	0.6	0.6	0.9	0.5	1.4	2.9	1.1
	PrecStd	4.9	1.9	1.7	1.3	1.3	1.3	1.4	1.5	1.8	1.3	1.9	2.1	1.9
	PrecStd	4.9	1.9	1.7	1.3	1.3	1.3	1.4	1.5	1.8	1.3	1.9	2.1	1.9
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4% DB	51.5	52.0	54.8	66.7	73.1	74.0	77.9	79.0	70.1	62.4	56.6	53.9	(19)
	0.4% MCWB	50.8	49.1	49.6	54.2	61.6	61.7	66.4	63.0	62.7	58.3	55.0	52.6	(20)
	2% DB	50.6	50.3	50.7	58.6	65.9	68.4	73.6	69.7	65.0	59.5	55.0	52.5	(21)
	2% MCWB	49.8	48.7	48.3	50.8	58.2	59.9	63.0	62.3	59.6	57.0	53.7	51.5	(22)
	5% DB	49.8	49.1	49.3	53.8	61.2	64.9	69.9	66.4	62.5	58.1	53.9	51.7	(23)
	5% MCWB	48.9	47.8	47.5	49.0	54.2	58.0	61.8	60.7	59.1	56.0	52.7	50.9	(24)
	10% DB	49.0	48.0	48.3	51.4	58.2	61.6	66.3	63.9	60.8	57.0	52.9	50.8	(25)
	10% MCWB	47.8	46.7	46.9	47.8	52.7	56.8	59.9	59.8	58.0	54.9	51.4	49.9	(26)
	0.4% WB	51.2	50.6	50.8	55.4	62.8	64.1	68.4	65.2	63.3	59.7	55.6	53.1	(27)
	0.4% MCDB	51.3	51.3	52.8	63.7	70.8	70.6	76.0	72.6	67.5	60.9	56.0	53.7	(28)
(28) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2% WB	50.3	49.2	49.2	52.1	58.4	60.9	64.9	63.2	61.4	58.0	54.3	52.0	(29)
	2% MCDB	50.4	49.9	50.2	56.5	65.4	66.5	71.0	67.3	63.5	58.9	54.8	52.3	(30)
	5% WB	49.4	48.2	48.3	50.2	55.4	58.8	62.3	62.1	60.1	56.6	53.1	51.2	(31)
	5% MCDB	49.7	48.8	48.9	52.5	59.9	63.0	67.7	65.0	61.7	57.5	53.8	51.5	(32)
	10% WB	48.2	47.1	47.4	48.9	53.4	57.5	60.5	60.9	58.9	55.6	51.8	50.2	(33)
	10% MCDB	48.9	47.9	48.0	50.7	56.6	60.6	64.6	63.4	60.3	56.6	52.7	50.6	(34)
(35) Mean Daily Temperature Range	MDBR	7.3	7.8	8.2	10.4	11.0	10.4	10.4	9.6	9.1	8.0	7.7	7.0	(35)
	5% DB	6.8	6.6	8.6	13.9	16.6	16.2	17.2	13.5	11.4	8.4	6.9	6.6	(36)
	5% WB	8.3	6.5	7.5	8.8	10.4	10.0	9.2	7.6	7.8	7.3	7.5	7.5	(37)
	MCDBR	7.0	6.3	7.3	11.2	15.1	13.2	14.8	11.6	9.7	7.9	6.8	6.3	(38)
	MCWBR	8.7	7.0	7.3	7.9	10.2	8.6	8.8	7.5	7.9	7.9	7.7	7.4	(39)
	MCWBR	8.7	7.0	7.3	7.9	10.2	8.6	8.8	7.5	7.9	7.9	7.7	7.4	(39)
(40) Clear-Sky Solar Irradiance	taub	0.330	0.342	0.368	0.380	0.389	0.375	0.381	0.364	0.359	0.351	0.328	0.319	(40)
	taud	2.335	2.390	2.342	2.341	2.362	2.426	2.414	2.477	2.480	2.453	2.393	2.312	(41)
	Ebn at Noon	210	246	260	272	274	279	275	274	262	239	210	191	(42)
	Edh at Noon	20	25	32	36	36	35	35	31	28	23	19	18	(43)
(44) All-Sky Solar Radiation	RadAvg	232	474	867	1382	1704	1852	1684	1408	1037	575	288	174	(44)
	RadStd	23	43	73	97	109	156	143	93	74	47	24	21	(45)

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (42 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page