

BRAWDY, United KingdomWMO: **036030**Lat: **51.883N**Lon: **5.117W**Elev: **111**StdP: **100.00**Time Zone: **0.00 (EUW)**Period: **82-92**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-3.9	-2.1	-8.0	1.9	-2.9	-5.6	2.4	-0.9	18.2	6.3	16.7	6.2	5.4	110	0.739

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	5.8	22.6	16.9	20.6	16.1	18.9	15.4	17.8	20.9	16.8	19.1	16.1	18.0	4.8	140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
16.7	12.1	18.3	16.0	11.5	17.5	15.3	11.0	16.7	50.3	21.2	47.6	19.0	45.4	18.1	22.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 14.9	13.3	11.9	-5.6	26.3	2.5	2.3	-7.4	27.9	-8.8	29.3	-10.2	30.5	-12.1	32.2		
(5)			-6.4	19.8	2.7	1.0	-8.3	20.5	-9.9	21.1	-11.4	21.7	-13.3	22.5		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
Temperatures, Degree-Days and Degree-Hours	DBAvg	9.5	5.0	4.4	6.2	7.3	10.3	12.7	15.2	14.7	13.1	10.8	7.6	6.5	
	DBStd	4.42	3.38	3.38	2.04	2.41	2.52	2.29	2.15	2.05	1.96	2.08	2.72	2.83	
	HDD10.0	753	156	156	119	86	24	3	0	0	1	16	81	111	
	HDD18.3	3231	413	389	377	330	250	170	103	115	158	234	323	368	
	CDD10.0	572	0	1	1	6	33	84	160	146	93	40	7	2	
	CDD18.3	7	0	0	0	0	0	1	4	2	0	0	0	0	
	CDH23.3	38	0	0	0	0	1	3	19	16	0	0	0	0	
	CDH26.7	4	0	0	0	0	0	0	1	3	0	0	0	0	
Wind	WSAvg	6.0	7.1	7.1	6.7	5.8	5.5	4.9	4.8	5.2	5.4	6.4	6.3	6.7	
Precipitation	PrecAvg	1112	120	87	72	70	67	69	72	91	80	123	139	121	
	PrecMax	1325	198	208	143	149	145	148	195	197	146	207	273	227	
	PrecMin	934	8	21	26	23	8	14	16	22	12	36	74	29	
	PrecStd	125	48	43	33	33	33	36	39	45	34	47	53	48	
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	10.8	11.1	12.7	19.3	22.8	23.3	25.5	26.1	21.2	16.9	13.7	12.2	
		MCWB	10.5	9.5	9.8	12.3	16.5	16.5	19.1	17.2	17.1	14.6	12.8	11.4	
	2%	DB	10.3	10.2	10.4	14.8	18.8	20.2	23.1	20.9	18.3	15.3	12.8	11.4	
		MCWB	9.9	9.3	9.1	10.5	14.6	15.5	17.2	16.8	15.4	13.9	12.0	10.9	
	5%	DB	9.9	9.5	9.6	12.1	16.2	18.3	21.0	19.1	16.9	14.5	12.2	10.9	
		MCWB	9.4	8.8	8.6	9.4	12.3	14.4	16.5	16.0	15.1	13.3	11.5	10.5	
	10%	DB	9.4	8.9	9.0	10.8	14.5	16.5	19.1	17.7	16.0	13.9	11.6	10.5	
		MCWB	8.8	8.2	8.3	8.8	11.5	13.8	15.5	15.5	14.5	12.7	10.8	9.9	
	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	10.7	10.3	10.4	13.0	17.1	17.8	20.2	18.4	17.4	15.4	13.1	11.7
			MCDB	10.7	10.7	11.5	17.6	21.6	21.4	24.4	22.6	19.7	16.0	13.3	12.0
2%		WB	10.2	9.6	9.6	11.1	14.6	16.0	18.3	17.3	16.3	14.4	12.4	11.1	
		MCDB	10.2	9.9	10.1	13.6	18.5	19.2	21.7	19.6	17.5	14.9	12.7	11.3	
5%		WB	9.6	9.0	9.0	10.1	13.0	14.9	16.8	16.7	15.6	13.7	11.7	10.6	
		MCDB	9.8	9.4	9.4	11.4	15.5	17.2	19.8	18.3	16.5	14.2	12.1	10.8	
10%		WB	9.0	8.4	8.5	9.4	11.9	14.2	15.8	16.1	15.0	13.1	11.0	10.1	
		MCDB	9.4	8.8	8.9	10.4	13.7	15.9	18.1	17.4	15.7	13.7	11.5	10.4	
Mean Daily Temperature Range		5% DB	MDBR	4.1	4.3	4.6	5.8	6.1	5.8	5.8	5.3	5.1	4.4	4.3	3.9
			MCDBR	3.8	3.7	4.8	7.7	9.2	9.0	9.6	7.5	6.3	4.6	3.8	3.7
	MCWBR		4.6	3.6	4.1	4.9	5.8	5.6	5.1	4.2	4.3	4.1	4.2	4.2	
	5% WB	MCDBR	3.9	3.5	4.0	6.2	8.4	7.3	8.2	6.4	5.4	4.4	3.8	3.5	
		MCWBR	4.8	3.9	4.1	4.4	5.7	4.8	4.9	4.2	4.4	4.4	4.3	4.1	
Clear-Sky Solar Irradiance	taub	0.330	0.342	0.368	0.380	0.389	0.375	0.381	0.364	0.359	0.351	0.328	0.319		
	taud	2.335	2.390	2.342	2.341	2.362	2.426	2.414	2.477	2.480	2.453	2.393	2.312		
	Ebn at Noon	662	774	821	857	865	879	867	865	827	755	663	603		
	Edh at Noon	64	79	100	112	115	109	109	97	87	74	60	56		
All-Sky Solar Radiation	RadAvg	0.73	1.50	2.73	4.36	5.37	5.84	5.31	4.44	3.27	1.81	0.91	0.55		
	RadStd	0.07	0.13	0.23	0.30	0.34	0.49	0.45	0.29	0.23	0.15	0.07	0.07		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
Station Only		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Regional (42 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A