

LITTLE RISSINGTON, United Kingdom

WMO: 036470

Lat: 51.8606N

Lon: 1.6931W

Elev: 689

StdP: 14.33

Time Zone: 0.00 (EUW)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	24.6	26.9	21.4	16.5	29.0	23.7	18.4	30.2	34.4	47.1	31.7	46.9	10.4	70	0.687

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	16.0	77.6	64.1	73.9	62.4	70.9	61.0	65.7	73.9	64.0	70.9	62.5	68.5	10.1	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
62.9	88.0	68.2	61.3	83.1	66.2	60.0	79.2	64.8	30.8	74.1	29.5	70.8	28.4	68.4	73.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 29.2	25.6	22.9	DB	21.1	84.2	3.4	3.9	18.7	86.9	16.7	89.2	14.8	91.4	12.4	94.2	(4)
(5)			WB	20.6	69.4	3.2	2.3	18.4	71.0	16.5	72.4	14.7	73.7	12.4	75.3	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	49.1	38.6	39.4	42.5	46.5	51.7	57.1	61.1	60.5	56.5	50.7	43.8	39.5	(6)
(7)		DBStd	9.56	5.77	5.70	5.33	5.23	5.25	4.65	4.63	4.20	4.19	4.95	5.25	6.32	(7)
(8)		HDD50	1630	354	296	236	128	39	2	0	0	2	50	195	328	(8)
(9)		HDD65	5861	819	716	697	555	411	243	141	153	256	442	637	791	(9)
(10)		CDD50	1285	0	1	4	23	93	215	344	325	198	73	7	2	(10)
(11)		CDD65	40	0	0	0	0	0	5	20	13	2	0	0	0	(11)
(12)		CDH74	311	0	0	0	1	3	52	167	76	10	2	0	0	(12)
(13)		CDH80	44	0	0	0	0	0	6	28	10	0	0	0	0	(13)
(14)	Wind	WSAvg	11.9	13.3	13.3	12.8	11.8	11.4	10.6	10.2	10.3	10.8	12.6	12.5	13.0	(14)
(15)	Precipitation	PrecAvg	28.5	2.8	2.0	1.9	2.1	2.4	2.0	2.2	2.4	2.2	2.8	2.9	2.9	(15)
(16)		PrecMax	38.7	7.2	4.7	3.7	5.9	5.4	5.6	7.0	5.8	4.6	5.0	4.9	5.2	(16)
(17)		PrecMin	18.5	0.3	0.4	0.3	0.1	0.4	0.4	0.4	0.3	0.3	0.6	1.3	0.9	(17)
(18)		PrecStd	5.1	1.4	1.1	0.9	1.4	1.1	1.3	1.4	1.3	1.2	1.2	1.1	1.3	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	53.0	54.6	60.3	68.9	73.6	79.7	83.7	81.0	75.5	66.4	57.6	54.1	(19)
(20)			MCWB	50.8	50.6	51.2	56.7	61.8	65.5	66.0	66.5	63.4	60.2	55.8	52.6	(20)
(21)		2%	DB	51.0	51.3	55.7	62.6	69.1	74.3	78.6	75.7	70.2	61.9	55.5	52.7	(21)
(22)			MCWB	49.4	48.7	49.5	53.6	59.5	62.5	63.7	64.3	61.2	57.6	54.0	51.4	(22)
(23)		5%	DB	49.1	49.5	52.9	58.6	65.1	70.3	74.5	71.7	66.7	59.8	53.6	50.9	(23)
(24)			MCWB	47.4	47.2	48.4	51.4	57.3	60.6	62.4	61.7	59.3	56.7	51.9	49.7	(24)
(25)		10%	DB	47.3	47.8	50.8	55.4	61.2	66.6	71.0	68.5	64.2	58.1	51.9	49.0	(25)
(26)			MCWB	45.8	45.8	47.2	49.5	54.8	58.6	61.0	60.5	58.2	55.5	50.3	47.7	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	51.7	51.9	53.0	58.1	63.8	67.7	68.0	68.3	65.5	61.6	56.5	53.1	(27)
(28)			MCDWB	52.3	53.7	56.5	65.7	70.9	77.4	78.8	77.3	71.4	65.3	57.0	53.5	(28)
(29)		2%	WB	49.8	49.5	51.1	54.8	60.6	63.8	65.4	65.4	62.8	59.1	54.3	51.8	(29)
(30)			MCDWB	50.8	50.7	54.1	60.9	67.4	71.3	74.3	72.7	67.6	60.8	55.1	52.6	(30)
(31)		5%	WB	47.7	47.8	49.4	52.5	58.1	61.6	63.7	63.6	61.0	57.5	52.4	49.9	(31)
(32)			MCDWB	48.7	49.1	52.0	57.0	63.5	68.1	71.9	69.2	64.9	59.1	53.4	50.7	(32)
(33)		10%	WB	46.0	46.2	47.8	50.4	55.9	59.7	62.0	62.0	59.4	56.0	50.5	47.8	(33)
(34)			MCDWB	47.2	47.7	50.3	54.6	60.3	65.2	69.1	66.5	62.9	57.7	51.6	48.8	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	8.9	9.8	12.2	14.6	15.0	15.6	16.0	14.6	14.0	11.4	9.3	8.4	(35)
(36)			MCDBR	10.5	10.8	14.8	18.9	19.7	21.3	21.8	18.8	17.3	12.1	10.2	9.5	(36)
(37)			MCWBR	10.4	9.1	10.1	11.7	11.9	11.8	10.0	9.2	9.9	8.7	9.4	9.5	(37)
(38)		5% WB	MCDBR	10.2	10.5	13.0	17.0	17.3	18.7	18.8	16.0	15.1	11.4	10.0	9.7	(38)
(39)			MCWBR	10.5	9.4	9.9	11.3	11.3	11.4	10.1	9.1	9.9	9.3	9.7	10.0	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.317	0.332	0.364	0.387	0.392	0.388	0.385	0.374	0.359	0.344	0.319	0.307	(40)	
(41)		taud	2.373	2.393	2.299	2.249	2.269	2.304	2.318	2.372	2.413	2.439	2.420	2.349	(41)	
(42)		Ebn at Noon	218	250	261	269	273	275	273	271	261	241	216	199	(42)	
(43)		Edh at Noon	19	25	33	39	40	39	38	34	29	23	18	17	(43)	
(44)	All-Sky Solar Radiation	RadAvg	250	462	806	1240	1516	1653	1569	1299	979	566	301	198	(44)	
(45)		RadStd	22	58	105	142	94	169	161	103	83	50	33	23	(45)	

Historical Trends

		Heating		Cooling			Degree-Days					
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(46)
(47)	Regional (94 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(47)

Nomenclature: See separate page