

BRIZE NORTON, United Kingdom

WMO: 036490

Lat: 51.7583N

Lon: 1.5781W

Elev: 88

StdP: 100.27

Time Zone: 0.00 (EUW)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-3.6	-2.3	-6.4	2.2	-0.9	-5.1	2.5	-0.3	11.1	7.6	10.1	7.0	2.2	40	0.553

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.4	27.0	18.2	25.0	17.3	23.1	16.5	19.2	24.7	18.2	22.9	17.3	21.5	3.7	170

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
17.2	12.4	20.8	16.4	11.8	19.9	15.6	11.2	19.1	54.6	24.7	51.6	23.0	49.0	21.6	23.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 9.4	8.3	7.4	-6.6	30.3	2.0	2.2	-8.0	31.9	-9.2	33.2	-10.3	34.4	-11.7	36.0		
(5)			-7.1	21.0	1.9	1.3	-8.5	22.0	-9.6	22.7	-10.6	23.5	-12.0	24.4		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	10.5	4.7	5.0	6.8	9.1	12.1	15.1	17.4	17.0	14.5	11.2	7.4	5.0	(6)
(7)		DBStd	5.41	3.30	3.17	2.94	2.91	2.87	2.53	2.52	2.41	2.32	2.82	3.11	3.72	(7)
(8)		HDD10.0	739	167	141	105	50	12	0	0	0	1	19	88	157	(8)
(9)		HDD18.3	2914	424	373	358	278	194	102	49	56	118	221	328	412	(9)
(10)		CDD10.0	908	1	1	5	22	76	153	229	217	134	57	9	3	(10)
(11)		CDD18.3	42	0	0	0	0	1	5	20	15	2	0	0	0	(11)
(12)		CDH23.3	374	0	0	0	1	9	59	176	113	13	2	0	0	(12)
(13)		CDH26.7	71	0	0	0	0	0	11	36	23	1	0	0	0	(13)
(14)	Wind	WSAvg	3.4	3.8	3.9	3.9	3.6	3.5	3.2	3.0	2.9	3.0	3.3	3.2	3.5	(14)
(15)	Precipitation	PrecAvg	725	71	51	47	53	61	52	56	61	57	70	74	73	(15)
(16)		PrecMax	982	182	119	93	151	137	142	178	147	116	128	124	132	(16)
(17)		PrecMin	471	7	10	8	2	9	9	10	8	8	15	33	22	(17)
(18)		PrecStd	130	35	29	22	36	28	32	35	34	31	31	27	32	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	12.8	13.3	16.9	21.9	24.6	28.0	30.0	29.1	25.2	20.3	15.4	13.7	(19)
(20)			MCWB	11.1	10.7	10.9	14.1	16.5	18.2	18.9	19.0	16.9	16.1	13.5	12.0	(20)
(21)		2%	DB	11.8	11.7	14.4	18.4	22.1	24.9	27.3	26.4	22.4	17.8	14.2	12.7	(21)
(22)			MCWB	10.4	9.8	10.1	12.4	15.4	17.1	18.1	18.4	16.4	14.4	12.6	11.4	(22)
(23)		5%	DB	10.7	10.8	12.8	16.1	19.9	22.6	25.2	23.9	20.5	16.6	13.3	11.8	(23)
(24)			MCWB	9.3	8.9	9.4	11.2	14.3	16.0	17.3	17.1	15.3	14.0	11.7	10.5	(24)
(25)		10%	DB	9.7	9.8	11.5	14.3	17.6	20.6	23.2	21.9	19.1	15.6	12.3	10.7	(25)
(26)			MCWB	8.4	8.2	8.8	10.1	13.0	15.0	16.6	16.2	14.7	13.4	10.8	9.4	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	11.7	11.5	12.0	14.8	17.7	19.9	20.3	20.6	18.8	16.8	14.2	12.5	(27)
(28)			MCDWB	12.4	12.9	14.6	20.1	22.3	26.3	27.0	27.0	22.7	19.5	14.9	13.3	(28)
(29)		2%	WB	10.6	10.2	11.0	13.0	16.1	17.8	19.1	19.0	17.4	15.5	13.0	11.7	(29)
(30)			MCDWB	11.6	11.4	13.3	17.5	21.0	22.6	25.0	24.1	20.7	17.3	13.9	12.7	(30)
(31)		5%	WB	9.5	9.3	10.2	11.7	14.9	16.7	18.2	18.0	16.5	14.6	11.9	10.7	(31)
(32)			MCDWB	10.5	10.5	12.2	15.1	18.8	21.1	23.4	22.2	19.3	16.1	13.1	11.7	(32)
(33)		10%	WB	8.6	8.4	9.3	10.6	13.6	15.7	17.3	17.1	15.5	13.8	10.9	9.6	(33)
(34)			MCDWB	9.6	9.7	11.2	13.7	16.9	19.6	21.9	20.7	18.1	15.2	12.1	10.6	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	5.5	6.0	7.3	8.6	8.9	9.0	9.4	8.9	8.4	7.1	5.9	5.3	(35)
(36)			MCDBR	6.1	6.5	9.0	11.4	12.4	12.7	13.1	12.1	10.6	7.6	6.0	5.6	(36)
(37)			MCWBR	5.6	5.1	5.7	6.5	6.8	6.2	5.6	5.2	5.4	5.0	5.0	5.3	(37)
(38)		5% WB	MCDWB	6.1	6.3	7.8	10.0	11.0	10.9	11.2	10.0	9.1	6.9	5.9	5.7	(38)
(39)			MCWBR	5.8	5.4	5.5	6.1	6.4	6.0	5.5	5.1	5.4	5.2	5.3	5.4	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.323	0.339	0.373	0.396	0.401	0.397	0.394	0.383	0.367	0.351	0.325	0.313	(40)	
(41)		taud	2.359	2.373	2.274	2.226	2.248	2.286	2.304	2.357	2.397	2.422	2.406	2.338	(41)	
(42)		Ebn at Noon	678	777	813	838	852	857	853	844	815	752	672	620	(42)	
(43)		Edh at Noon	63	81	107	126	129	126	121	109	94	76	59	54	(43)	
(44)	All-Sky Solar Radiation	RadAvg	0.80	1.46	2.54	3.91	4.77	5.22	4.96	4.11	3.10	1.80	0.96	0.63	(44)	
(45)		RadStd	0.07	0.19	0.34	0.45	0.30	0.53	0.50	0.33	0.27	0.16	0.11	0.07	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (90 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page