

ANDREWSFIELD, United Kingdom

WMO: 036840

Lat: 51.8961N

Lon: 0.4506E

Elev: 285

StdP: 14.54

Time Zone: 0.00 (EUW)

Period: 98-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	26.4	28.6	21.8	16.5	29.8	24.0	18.4	31.4	32.1	49.9	28.9	49.7	6.2	30	0.603

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	17.3	80.0	65.3	76.4	63.8	73.3	62.3	67.3	76.6	65.4	73.4	63.8	70.8	9.6	140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
63.9	89.8	70.1	62.3	85.0	68.1	60.9	80.8	66.8	31.8	76.5	30.4	73.5	29.2	70.9	76.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
25.4	22.3	19.7	DB	21.6	86.7	4.8	3.6	18.2	89.3	15.3	91.4	12.6	93.4	9.1	96.0
			WB	20.9	71.5	4.8	2.4	17.4	73.3	14.7	74.7	12.0	76.1	8.5	77.8

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	50.5	40.0	40.4	43.7	48.0	53.4	58.4	62.8	62.5	58.4	52.2	45.0	41.0
	DBStd	9.76	5.72	5.75	5.45	5.38	5.09	4.75	4.68	4.35	4.51	4.99	5.43	6.27
	HDD50	1392	312	271	204	98	23	1	0	0	1	33	165	284
	HDD65	5352	775	689	661	510	360	204	102	103	204	399	601	744
	CDD50	1587	1	3	8	38	128	255	396	386	252	100	15	5
	CDD65	71	0	0	0	0	0	7	33	25	5	1	0	0
	CDH74	597	0	0	0	1	5	66	282	200	38	5	0	0
	CDH80	110	0	0	0	0	0	7	52	48	3	0	0	0
	WSAvg	9.5	11.0	10.8	10.3	9.1	8.9	8.3	8.3	8.5	8.8	9.6	9.7	10.7
	PrecAvg	23.0	2.0	1.6	1.3	1.6	1.8	1.9	2.0	2.3	1.8	2.3	2.4	2.0
(15) Precipitation	PrecMax	29.7	4.1	3.7	3.4	4.1	4.0	4.3	3.6	4.6	3.5	5.1	4.8	4.0
	PrecMin	16.7	0.4	0.1	0.2	0.0	0.3	0.5	0.7	0.2	0.7	0.6	0.9	0.6
	PrecStd	3.9	0.9	1.0	0.8	1.2	1.0	1.1	0.9	1.2	0.9	1.1	1.1	0.9
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	54.7	56.7	61.7	71.0	74.5	80.6	85.0	85.3	78.6	68.7	60.2	56.5
		MCWB	51.9	51.7	52.3	57.9	62.5	65.7	67.0	67.7	63.3	61.0	57.3	53.8
	2%	DB	53.0	53.4	57.6	64.7	70.8	75.4	80.5	79.2	73.3	64.3	57.4	54.4
		MCWB	50.8	49.9	50.6	55.0	60.5	63.4	64.7	65.8	62.3	58.6	54.6	52.2
	5%	DB	50.9	51.1	54.8	60.8	67.4	71.8	76.9	74.7	69.8	61.7	55.3	52.6
		MCWB	48.7	48.0	49.4	52.9	58.6	62.0	63.9	63.6	60.7	57.4	52.7	50.5
	10%	DB	48.9	49.0	52.5	57.5	63.7	68.6	73.4	71.7	66.7	59.8	53.3	50.6
		MCWB	46.8	46.3	48.0	50.9	56.3	60.0	62.2	61.6	59.1	56.3	51.0	48.5
	0.4%	WB	53.1	52.7	54.0	59.3	65.2	68.4	69.5	70.8	66.6	62.0	58.2	54.5
		MCDB	53.9	55.4	58.8	68.0	71.2	78.2	82.4	80.5	74.2	66.6	59.3	55.7
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	51.1	50.4	52.1	56.2	61.8	65.3	66.8	67.3	64.1	60.1	55.2	52.7
		MCDB	52.6	52.7	55.9	62.8	68.7	72.5	76.6	76.5	70.5	63.1	56.6	54.2
	5%	WB	48.9	48.5	50.5	54.0	59.3	63.0	65.0	64.9	62.3	58.5	53.2	50.8
		MCDB	50.6	50.6	54.1	59.3	65.8	69.4	73.9	72.3	67.3	60.8	54.9	52.4
	10%	WB	47.0	46.8	48.6	51.9	57.2	61.1	63.4	63.2	60.6	57.0	51.2	48.7
		MCDB	48.7	48.9	51.9	56.4	62.5	67.2	71.3	69.2	64.9	59.3	53.0	50.5
(35) Mean Daily Temperature Range	5% DB	MDBR	9.0	9.8	12.5	15.3	16.0	16.6	17.3	16.7	15.1	11.9	9.9	8.6
		MCDBR	10.5	12.1	16.1	20.4	21.5	21.3	23.2	21.9	19.1	13.1	10.8	9.4
		MCWBR	10.1	9.3	10.4	11.9	12.7	11.4	10.3	10.3	9.6	8.9	9.5	8.8
	5% WB	MCDBR	10.5	11.2	14.7	18.5	19.5	19.6	20.5	19.7	16.2	11.7	10.5	9.4
		MCWBR	10.4	9.4	10.6	11.9	12.4	11.3	10.3	10.4	9.5	9.1	9.8	9.1
(40) Clear-Sky Solar Irradiance	taub		0.325	0.341	0.376	0.398	0.403	0.406	0.404	0.394	0.373	0.357	0.329	0.315
	taud		2.377	2.385	2.280	2.238	2.262	2.278	2.295	2.346	2.400	2.433	2.422	2.364
	Ebn at Noon		214	246	257	265	269	269	267	264	256	236	211	196
	Edh at Noon		19	25	34	39	40	40	39	35	30	24	18	17
(44) All-Sky Solar Radiation	RadAvg		241	455	808	1286	1542	1682	1601	1339	1005	579	295	189
	RadStd		22	67	97	128	112	132	153	100	82	54	33	24

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (81 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page