

ANDREWSFIELD, United Kingdom

WMO: 036840

Lat: 51.8961N

Lon: 0.4506E

Elev: 87

StdP: 100.28

Time Zone: 0.00 (EUW)

Period: 98-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-3.1	-1.9	-5.7	2.4	-1.2	-4.4	2.6	-0.3	14.3	9.9	12.9	9.8	2.8	30	0.603

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.6	26.7	18.5	24.7	17.6	22.9	16.8	19.6	24.8	18.5	23.0	17.7	21.5	4.3	140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
17.7	12.8	21.2	16.9	12.1	20.1	16.1	11.5	19.3	56.2	24.7	52.7	23.1	50.0	21.6	24.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 11.4	10.0	8.8	DB	-5.8	30.4	2.7	2.0	-7.7	31.8	-9.3	33.0	-10.8	34.1	-12.7	35.6	(4)
(5)			WB	-6.2	22.0	2.7	1.3	-8.1	22.9	-9.6	23.7	-11.1	24.5	-13.1	25.5	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	10.3	4.4	4.7	6.5	8.9	11.9	14.7	17.1	16.9	14.6	11.2	7.2	5.0	(6)	
	DBStd	5.42	3.18	3.19	3.03	2.99	2.83	2.64	2.60	2.42	2.51	2.77	3.01	3.48	(7)	
	HDD10.0	773	173	151	113	54	13	1	0	0	1	18	92	158	(8)	
	HDD18.3	2973	431	383	367	283	200	113	57	57	113	222	334	413	(9)	
	CDD10.0	882	1	2	4	21	71	142	220	214	140	56	8	3	(10)	
	CDD18.3	39	0	0	0	0	0	4	18	14	3	1	0	0	(11)	
	CDH23.3	332	0	0	0	1	3	37	157	111	21	3	0	0	(12)	
	CDH26.7	61	0	0	0	0	0	4	29	27	2	0	0	0	(13)	
(14) Wind	WSAvg	4.2	4.9	4.8	4.6	4.1	4.0	3.7	3.7	3.8	3.9	4.3	4.3	4.8	(14)	
(15) Precipitation	PrecAvg	584	50	41	34	40	45	47	52	58	45	58	62	52	(15)	
	PrecMax	755	103	94	87	105	101	110	91	118	89	129	123	102	(16)	
	PrecMin	424	11	3	5	0	8	12	17	4	17	16	24	14	(17)	
	PrecStd	99	22	26	20	30	25	29	22	30	22	29	29	24	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	12.6	13.7	16.5	21.6	23.6	27.0	29.5	29.6	25.9	20.4	15.7	13.6	(19)	
		MCWB	11.1	10.9	11.3	14.4	16.9	18.7	19.4	19.8	17.4	16.1	14.1	12.1	(20)	
	2%	DB	11.7	11.9	14.2	18.2	21.5	24.1	26.9	26.2	23.0	17.9	14.1	12.4	(21)	
		MCWB	10.4	9.9	10.3	12.8	15.8	17.5	18.1	18.8	16.9	14.8	12.5	11.2	(22)	
	5%	DB	10.5	10.6	12.7	16.0	19.7	22.1	25.0	23.7	21.0	16.5	12.9	11.5	(23)	
		MCWB	9.3	8.9	9.7	11.6	14.8	16.7	17.7	17.6	15.9	14.1	11.5	10.3	(24)	
	10%	DB	9.4	9.4	11.4	14.2	17.6	20.3	23.0	22.0	19.3	15.5	11.8	10.3	(25)	
		MCWB	8.2	7.9	8.9	10.5	13.5	15.5	16.8	16.5	15.1	13.5	10.5	9.2	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	11.7	11.5	12.2	15.2	18.5	20.2	20.8	21.6	19.2	16.7	14.5	12.5	(27)	
		MCDB	12.2	13.0	14.9	20.0	21.8	25.7	28.0	26.9	23.4	19.2	15.2	13.2	(28)	
	2%	WB	10.6	10.2	11.2	13.5	16.5	18.5	19.3	19.6	17.8	15.6	12.9	11.5	(29)	
		MCDB	11.5	11.5	13.3	17.1	20.4	22.5	24.8	24.7	21.4	17.3	13.7	12.3	(30)	
	5%	WB	9.4	9.2	10.3	12.2	15.2	17.2	18.3	18.3	16.8	14.7	11.8	10.5	(31)	
		MCDB	10.3	10.3	12.3	15.2	18.8	20.8	23.3	22.4	19.6	16.0	12.7	11.4	(32)	
	10%	WB	8.3	8.2	9.2	11.0	14.0	16.2	17.5	17.3	15.9	13.9	10.7	9.3	(33)	
		MCDB	9.3	9.4	11.1	13.6	16.9	19.6	21.8	20.7	18.3	15.2	11.7	10.3	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	5.0	5.5	7.0	8.5	8.9	9.2	9.6	9.3	8.4	6.6	5.5	4.8	(35)	
		MCDBR	5.8	6.7	8.9	11.3	12.0	11.9	12.9	12.2	10.6	7.3	6.0	5.2	(36)	
	5% WB	MCWBR	5.6	5.2	5.8	6.6	7.1	6.3	5.7	5.7	5.3	5.0	5.3	4.9	(37)	
		MCWBR	5.9	6.2	8.2	10.3	10.8	10.9	11.4	11.0	9.0	6.5	5.8	5.2	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.325	0.341	0.376	0.398	0.403	0.406	0.404	0.394	0.373	0.357	0.329	0.315	(40)	
		taud	2.377	2.385	2.280	2.238	2.262	2.278	2.295	2.346	2.400	2.433	2.422	2.364	(41)	
	Edn at Noon		675	774	809	836	849	849	843	833	808	745	666	617	(42)	
		Edh at Noon	61	80	106	124	127	127	123	111	94	75	58	53	(43)	
(44) All-Sky Solar Radiation	RadAvg		0.76	1.43	2.55	4.05	4.86	5.30	5.05	4.22	3.17	1.83	0.93	0.59	(44)	
	RadStd		0.07	0.21	0.31	0.40	0.35	0.42	0.48	0.32	0.26	0.17	0.10	0.08	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (81 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page