

WALTON-ON-THE-NAZE, United Kingdom

WMO: 036960

Lat: 51.851N

Lon: 1.267E

Elev: 5

StdP: 101.26

Time Zone: 0.00 (EUW)

Period: 94-07

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-1.3	-0.3	-4.4	2.6	1.2	-3.3	2.9	1.8	16.4	8.2	14.6	7.1	4.7	300	0.625

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	5.8	23.4	18.9	22.2	18.4	21.4	17.8	20.0	22.4	19.2	21.5	18.5	20.8	4.3	210

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
18.9	13.7	21.6	18.2	13.1	21.0	17.5	12.5	20.3	57.1	22.6	54.7	21.5	52.4	20.8	22.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
13.3	11.8	10.4	DB	-3.6	26.7	0.5	1.4	-3.9	27.7	-4.2	28.5	-4.5	29.3	-4.9	30.3	
			WB	-4.0	21.4	0.4	0.8	-4.3	22.0	-4.5	22.5	-4.8	23.0	-5.1	23.6	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	11.0	5.2	5.4	6.8	9.0	12.2	15.3	17.6	18.0	15.7	12.5	8.4	5.7	(6)
(7)		DBStd	5.27	2.60	2.74	2.65	2.46	2.22	2.33	2.16	2.13	2.18	2.57	2.78	2.96	(7)
(8)		HDD10.0	641	150	129	103	47	7	0	0	0	0	9	61	135	(8)
(9)		HDD18.3	2717	408	362	358	279	191	94	39	33	83	183	297	391	(9)
(10)		CDD10.0	1011	1	1	4	17	74	159	237	248	171	84	13	2	(10)
(11)		CDD18.3	45	0	0	0	0	0	3	17	22	3	0	0	0	(11)
(12)		CDH23.3	36	0	0	0	0	0	4	13	18	1	0	0	0	(12)
(13)		CDH26.7	1	0	0	0	0	0	0	0	1	0	0	0	0	(13)
(14)	Wind	WSAvg	5.2	6.2	5.8	5.3	4.8	4.9	4.6	4.3	4.2	4.8	5.7	5.3	5.9	(14)
(15)	Precipitation	PrecAvg	567	50	40	34	37	42	50	45	53	47	60	58	53	(15)
(16)		PrecMax	749	107	93	90	98	96	121	93	114	98	148	117	105	(16)
(17)		PrecMin	388	11	5	9	0	8	10	9	5	8	1	19	12	(17)
(18)		PrecStd	93	23	24	21	26	26	33	20	32	26	33	27	27	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	12.3	12.6	15.1	16.8	19.7	23.9	24.9	25.2	22.6	18.9	15.5	13.1	(19)
(20)			MCWB	10.2	9.8	10.8	12.5	15.8	18.1	19.2	19.5	17.8	15.4	13.6	11.3	(20)
(21)		2%	DB	11.0	11.2	13.0	14.8	17.7	21.3	23.1	23.5	20.9	17.5	14.1	11.8	(21)
(22)			MCWB	9.2	9.1	9.8	11.5	14.3	16.6	18.4	19.5	17.4	15.0	12.4	10.4	(22)
(23)		5%	DB	9.8	10.1	11.6	13.6	16.6	19.9	22.1	22.4	19.9	16.6	13.1	10.9	(23)
(24)			MCWB	8.4	8.1	9.1	10.9	13.5	16.0	18.2	18.9	17.0	14.7	11.5	9.8	(24)
(25)		10%	DB	8.8	9.1	10.5	12.5	15.7	18.9	21.2	21.6	19.1	16.0	12.2	10.0	(25)
(26)			MCWB	7.5	7.5	8.5	10.1	12.8	15.6	17.7	18.3	16.3	14.3	10.8	8.8	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	10.6	10.6	11.6	13.2	16.4	18.9	20.4	21.2	19.0	16.4	14.1	11.7	(27)
(28)			MCDWB	11.8	11.9	13.9	15.5	18.4	22.1	23.5	23.8	21.0	17.5	15.1	12.6	(28)
(29)		2%	WB	9.5	9.4	10.4	12.2	14.8	17.6	19.6	20.3	18.2	15.7	12.6	10.7	(29)
(30)			MCDWB	10.6	10.7	12.3	14.3	17.2	20.1	22.4	22.6	20.1	16.8	13.6	11.5	(30)
(31)		5%	WB	8.6	8.5	9.6	11.2	14.0	16.8	18.9	19.6	17.6	15.2	11.8	9.8	(31)
(32)			MCDWB	9.6	9.7	11.2	13.1	16.1	19.1	21.3	21.8	19.4	16.3	12.7	10.7	(32)
(33)		10%	WB	7.7	7.8	8.8	10.5	13.2	16.2	18.2	19.0	16.9	14.7	11.1	9.0	(33)
(34)			MCDWB	8.7	8.9	10.2	12.2	15.1	18.4	20.6	21.1	18.7	15.9	12.1	9.9	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	3.7	4.4	4.8	5.2	5.2	5.7	5.7	5.8	5.4	4.8	4.3	3.8	(35)
(36)			MCDBR	5.0	5.2	6.2	6.8	6.3	6.8	6.6	6.3	6.0	5.0	4.5	4.2	(36)
(37)			MCWBR	4.6	4.1	4.2	4.0	3.8	4.2	3.8	3.7	4.0	3.7	3.8	3.9	(37)
(38)		5% WB	MCDBR	4.9	4.9	5.6	5.9	5.7	5.8	5.5	5.3	5.2	4.1	4.1	4.1	(38)
(39)			MCWBR	4.7	4.2	4.2	3.8	3.9	4.3	3.6	3.6	3.8	3.6	3.8	3.9	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.331	0.348	0.384	0.405	0.411	0.414	0.412	0.403	0.382	0.365	0.337	0.321	(40)	
(41)		taud	2.374	2.381	2.277	2.249	2.278	2.294	2.312	2.358	2.407	2.428	2.414	2.365	(41)	
(42)		Ebn at Noon	668	766	801	830	842	842	837	824	800	736	656	611	(42)	
(43)		Edh at Noon	62	80	107	123	125	125	121	110	94	76	59	53	(43)	
(44)	All-Sky Solar Radiation	RadAvg	0.76	1.44	2.55	4.07	4.87	5.33	5.07	4.24	3.18	1.83	0.93	0.59	(44)	
(45)		RadStd	0.07	0.21	0.31	0.40	0.36	0.41	0.48	0.32	0.26	0.17	0.10	0.08	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (77 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page