

CHIVENOR, United Kingdom

WMO: 037070

Lat: 51.0892N

Lon: 4.1486W

Elev: 27

StdP: 14.68

Time Zone: 0.00 (EUW)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	28.8	31.3	22.4	16.9	32.9	25.1	19.1	34.8	38.7	46.6	34.3	48.0	8.1	90	0.653

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	12.1	76.5	64.3	72.7	62.8	69.9	61.7	66.1	73.2	64.5	69.9	63.2	67.9	11.6	130

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
63.7	88.3	68.3	62.4	84.4	66.8	61.2	80.8	65.7	30.8	73.4	29.6	70.0	28.7	68.1	74.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 31.6	28.1	25.2	DB	24.3	82.4	3.1	3.3	22.1	84.7	20.3	86.7	18.5	88.5	16.3	91.0	(4)
(5)			WB	23.3	69.7	3.0	2.3	21.1	71.3	19.4	72.7	17.7	74.0	15.5	75.7	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	52.3	43.6	43.8	46.0	49.2	54.2	59.0	62.2	62.1	59.0	54.4	48.6	45.0
	DBStd	8.18	5.40	4.92	4.60	4.47	4.33	3.96	3.55	3.42	3.51	4.55	4.98	5.90
	HDD50	860	202	177	136	65	11	0	0	0	0	15	83	171
	HDD65	4672	662	593	589	474	336	187	102	102	183	330	493	621
	CDD50	1701	5	4	11	41	140	269	379	376	270	151	40	15
	CDD65	39	0	0	0	0	0	6	16	14	3	0	0	0
	CDH74	238	0	0	0	1	8	57	104	59	8	1	0	0
	CDH80	36	0	0	0	0	0	10	16	10	0	0	0	0
Wind	WSAvg	11.8	13.7	13.2	12.6	11.4	11.1	10.5	10.0	10.1	10.7	12.1	12.3	13.6
Precipitation	PrecAvg	40.7	4.4	3.3	2.6	2.3	2.4	2.8	2.9	3.2	3.1	4.6	4.8	4.5
	PrecMax	54.2	7.6	7.3	4.5	5.5	5.0	6.6	8.6	5.8	5.8	8.3	8.3	8.9
	PrecMin	31.3	0.7	0.8	0.8	0.6	0.3	0.6	0.4	0.6	0.7	1.5	2.4	1.6
	PrecStd	5.6	1.7	1.6	1.0	1.3	1.1	1.6	1.7	1.5	1.2	1.5	1.6	2.0
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	55.7	57.0	62.2	70.1	74.6	80.6	82.0	80.8	74.8	67.5	60.2	57.9
		MCWB	53.1	52.7	52.9	57.7	61.7	65.9	66.3	66.5	65.3	61.2	57.3	55.0
	2%	DB	54.1	53.8	57.4	63.5	69.4	73.8	76.8	74.2	70.2	63.9	58.4	56.0
		MCWB	52.0	50.7	51.1	53.8	59.6	62.7	63.8	64.6	62.3	59.2	55.8	53.8
	5%	DB	52.7	52.1	54.5	59.1	65.1	69.4	72.3	70.6	67.4	62.3	57.2	54.6
		MCWB	50.6	49.5	50.2	51.9	56.9	60.3	62.7	62.9	60.7	58.3	54.6	52.4
	10%	DB	51.1	50.8	52.5	56.3	61.8	66.2	69.1	68.1	65.3	60.9	55.8	52.9
		MCWB	49.1	48.5	49.1	50.8	55.5	59.2	61.8	61.7	59.8	57.5	53.2	50.7
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	53.9	53.6	54.4	58.3	63.7	67.4	68.2	68.6	66.5	62.8	58.3	55.6
		MCDB	54.9	55.8	59.0	67.5	71.5	78.1	78.5	76.3	71.9	66.3	59.6	56.9
	2%	WB	52.5	51.4	52.6	55.0	60.5	63.7	65.7	66.0	64.0	60.7	56.5	54.3
		MCDB	53.7	53.0	55.9	61.2	67.2	71.4	73.5	71.8	68.0	62.8	58.0	55.8
	5%	WB	50.9	50.3	51.1	53.3	58.4	61.6	64.1	64.4	62.4	59.3	55.2	52.9
		MCDB	52.3	51.8	53.6	57.6	63.6	67.5	70.0	68.5	65.9	61.5	56.7	54.4
	10%	WB	49.4	49.0	49.9	51.6	56.4	60.0	62.8	63.1	61.0	58.1	53.7	51.2
		MCDB	50.9	50.7	52.1	55.6	60.7	64.8	67.5	66.9	64.3	60.5	55.6	52.8
Mean Daily Temperature Range	5% DB	MDBR	8.6	9.4	11.0	12.9	13.1	12.4	12.1	11.7	12.3	10.5	9.4	8.8
		MCDBR	8.6	9.8	14.3	18.1	19.1	19.3	19.5	16.2	15.6	11.2	8.9	8.1
		MCWBR	8.4	8.1	9.7	10.8	11.1	10.6	9.6	8.7	9.5	7.8	7.6	8.1
	5% WB	MCDBR	8.7	8.8	11.7	15.3	16.8	16.1	15.4	13.5	12.8	9.7	8.2	7.8
		MCWBR	8.9	8.0	9.0	9.9	10.4	9.6	8.9	8.3	9.1	7.9	7.8	8.3
Clear-Sky Solar Irradiance	taub	0.334	0.347	0.376	0.390	0.397	0.386	0.387	0.373	0.366	0.356	0.332	0.324	
	taud	2.341	2.370	2.302	2.290	2.309	2.373	2.374	2.431	2.439	2.434	2.393	2.314	
	Ebn at Noon	213	246	259	269	272	276	273	272	261	239	213	195	
	Edh at Noon	21	26	33	38	39	37	36	32	29	24	20	18	
All-Sky Solar Radiation	RadAvg	247	489	867	1376	1677	1830	1689	1416	1060	594	309	193	
	RadStd	23	49	93	111	100	167	134	102	75	46	27	23	

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (49 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page