

LISCOMBE, United Kingdom

WMO: 037100

Lat: 51.0869N

Lon: 3.6089W

Elev: 1138

StdP: 14.10

Time Zone: 0.00 (EUW)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	25.5	27.7	21.6	16.9	28.8	23.9	18.8	30.2	34.3	45.8	30.8	44.5	12.2	70	0.669

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	13.4	73.7	63.8	70.3	61.9	67.4	60.2	65.1	71.3	63.1	68.2	61.5	65.6	7.6	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
62.9	89.4	67.1	61.2	84.1	64.7	59.7	79.8	63.0	30.6	71.7	29.1	68.5	27.9	65.7	74.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
27.6	24.5	21.9	DB	23.3	78.2	3.2	3.2	21.0	80.6	19.2	82.4	17.4	84.3	15.1	86.6	(4)
			WB	22.5	68.9	3.3	2.5	20.2	70.7	18.2	72.2	16.4	73.6	14.0	75.5	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	48.3	39.1	39.3	41.9	45.7	50.3	55.3	58.9	58.3	55.0	50.0	44.3	40.3	(6)
(7)		DBStd	8.55	5.44	5.31	5.07	4.87	4.92	4.42	4.28	3.89	3.64	4.42	4.73	5.68	(7)
(8)		HDD50	1632	338	299	254	145	56	4	0	0	3	54	177	302	(8)
(9)		HDD65	6127	803	719	716	579	457	292	198	213	299	464	621	766	(9)
(10)		CDD50	995	0	0	3	17	64	164	274	257	155	54	6	1	(10)
(11)		CDD65	14	0	0	0	0	0	2	7	5	0	0	0	0	(11)
(12)		CDH74	86	0	0	0	0	1	15	42	28	0	0	0	0	(12)
(13)		CDH80	3	0	0	0	0	0	1	1	1	0	0	0	0	(13)
(14)	Wind	WSAvg	10.7	13.0	12.6	12.5	11.0	10.5	9.1	8.2	8.4	8.8	10.7	11.4	12.4	(14)
(15)	Precipitation	PrecAvg	57.4	6.6	4.6	4.9	3.5	3.4	3.4	4.1	4.8	5.5	6.4	6.8		(15)
(16)		PrecMax	68.1	14.3	10.2	11.5	7.7	7.8	7.2	7.2	9.5	12.0	11.0	11.0	16.9	(16)
(17)		PrecMin	41.5	2.0	0.4	0.9	0.4	0.4	0.4	0.6	1.1	1.3	0.6	2.1	2.0	(17)
(18)		PrecStd	7.5	3.2	2.4	2.2	1.8	1.9	1.7	1.5	2.2	2.4	3.0	2.3	3.1	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	51.7	53.3	59.2	66.7	71.1	76.0	78.4	78.1	70.2	63.7	55.8	53.0	(19)
(20)			MCWB	50.9	48.5	51.5	56.0	62.0	64.4	65.9	65.2	63.5	58.3	54.9	52.2	(20)
(21)		2%	DB	50.2	49.9	54.0	60.8	66.2	71.0	74.3	72.0	66.4	59.8	54.1	51.7	(21)
(22)			MCWB	49.5	48.1	48.1	52.9	58.4	61.4	64.1	63.4	60.5	56.9	53.1	51.2	(22)
(23)		5%	DB	48.4	48.0	50.9	56.4	62.5	67.3	70.8	68.1	63.4	57.8	52.7	50.2	(23)
(24)			MCWB	47.6	46.7	47.5	49.7	55.9	59.8	62.2	60.9	58.9	56.0	51.8	49.5	(24)
(25)		10%	DB	46.8	46.5	48.7	53.1	58.8	63.6	67.3	65.0	61.1	56.3	51.3	48.5	(25)
(26)			MCWB	45.9	45.1	46.5	48.2	53.6	57.6	60.2	59.5	57.7	54.8	50.2	47.8	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	51.2	51.0	52.1	57.0	63.1	67.0	68.0	67.9	64.7	60.4	55.5	52.7	(27)
(28)			MCDWB	51.3	52.1	56.3	63.9	69.6	73.2	75.7	74.7	67.8	62.5	55.8	52.7	(28)
(29)		2%	WB	49.6	48.5	49.9	53.4	59.3	62.8	65.2	64.3	62.1	58.0	53.6	51.3	(29)
(30)			MCDWB	50.0	49.5	52.1	59.8	65.0	68.9	72.6	69.4	64.8	58.9	53.8	51.5	(30)
(31)		5%	WB	47.7	47.0	48.4	51.0	56.8	60.3	63.1	62.4	60.1	56.6	52.1	49.8	(31)
(32)			MCDWB	48.2	47.9	50.1	54.6	61.1	65.6	69.0	66.3	62.3	57.4	52.5	50.1	(32)
(33)		10%	WB	46.2	45.5	46.9	49.2	54.6	58.4	61.2	60.7	58.5	55.1	50.5	48.0	(33)
(34)			MCDWB	46.7	46.4	48.5	52.4	57.9	62.7	65.7	63.8	60.3	56.1	51.1	48.5	(34)
(35)	Mean Daily Temperature Range	MDBR	7.8	8.5	10.2	12.6	13.2	13.5	13.4	12.7	11.7	9.7	8.3	7.9	(35)	
(36)		5% DB	MCDBR	8.8	9.4	13.3	17.2	18.2	19.2	19.3	16.8	14.5	10.8	8.6	8.4	(36)
(37)			MCWBR	8.8	8.1	9.5	11.3	12.4	13.1	11.7	10.2	10.0	8.2	7.9	8.6	(37)
(38)		5% WB	MCDBR	8.8	8.8	11.3	14.8	16.2	17.2	17.0	14.4	12.9	9.7	8.0	8.3	(38)
(39)			MCWBR	9.1	8.2	9.2	10.6	11.7	12.4	11.3	9.8	10.0	8.2	8.0	8.7	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.315	0.327	0.355	0.369	0.374	0.366	0.365	0.354	0.346	0.336	0.313	0.304	(40)	
(41)		taud	2.390	2.420	2.349	2.326	2.341	2.389	2.394	2.445	2.460	2.470	2.441	2.358	(41)	
(42)		Ebn at Noon	224	255	267	276	279	282	280	279	268	248	223	206	(42)	
(43)		Edh at Noon	20	25	32	36	37	36	35	32	28	23	19	17	(43)	
(44)	All-Sky Solar Radiation	RadAvg	252	482	855	1334	1627	1767	1658	1382	1041	585	311	198	(44)	
(45)		RadStd	23	55	106	132	86	178	139	113	72	47	30	24	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (57 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page