

LISCOMBE, United Kingdom

WMO: 037100

Lat: 51.0869N

Lon: 3.6089W

Elev: 347

StdP: 97.23

Time Zone: 0.00 (EUW)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-3.6	-2.4	-5.8	2.4	-1.8	-4.5	2.7	-1.0	15.3	7.7	13.8	7.0	5.5	70	0.669

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	7.5	23.2	17.7	21.3	16.6	19.7	15.6	18.4	21.8	17.3	20.1	16.4	18.7	3.4	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
17.2	12.8	19.5	16.2	12.0	18.2	15.4	11.4	17.2	53.3	22.1	49.8	20.3	47.1	18.7	23.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
12.3	11.0	9.8	-4.8	25.7	1.8	1.8	-6.1	27.0	-7.1	28.0	-8.1	29.0	-9.4	30.3		
			-5.3	20.5	1.8	1.4	-6.6	21.5	-7.6	22.3	-8.7	23.1	-10.0	24.1		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual													
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	9.0	3.9	4.1	5.5	7.6	10.1	13.0	14.9	14.6	12.8	10.0	6.8	4.6
(7)		DBStd	4.75	3.02	2.95	2.82	2.71	2.74	2.46	2.38	2.16	2.02	2.46	2.63	3.15
(8)		HDD10.0	907	188	166	141	81	31	2	0	0	2	30	98	168
(9)		HDD18.3	3404	446	399	398	322	254	162	110	118	166	258	345	426
(10)		CDD10.0	553	0	0	2	9	36	91	152	143	86	30	3	1
(11)		CDD18.3	8	0	0	0	0	0	1	4	3	0	0	0	0
(12)		CDH23.3	48	0	0	0	0	1	8	23	16	0	0	0	0
(13)		CDH26.7	2	0	0	0	0	0	1	1	1	0	0	0	0
(14)	Wind	WSAvg	4.8	5.8	5.6	5.6	4.9	4.7	4.1	3.7	3.8	4.0	4.8	5.1	5.6
(15)	Precipitation	PrecAvg	1457	167	118	125	89	86	86	86	104	121	140	163	172
(16)		PrecMax	1730	363	260	291	196	198	184	184	242	306	279	280	430
(17)		PrecMin	1055	50	9	23	9	11	10	15	28	32	16	53	52
(18)		PrecStd	190	81	61	57	45	49	43	38	56	61	76	58	80
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4% DB	11.0	11.8	15.1	19.3	21.7	24.4	25.8	25.6	21.2	17.6	13.2	11.6	
(20)		0.4% MCWB	10.5	9.2	10.8	13.4	16.7	18.0	18.8	18.4	17.5	14.6	12.7	11.2	
(21)		2% DB	10.1	10.0	12.2	16.0	19.0	21.7	23.5	22.2	19.1	15.5	12.3	10.9	
(22)		2% MCWB	9.7	8.9	8.9	11.6	14.7	16.4	17.8	17.4	15.8	13.8	11.7	10.6	
(23)		5% DB	9.1	8.9	10.5	13.6	16.9	19.6	21.6	20.0	17.5	14.3	11.5	10.1	
(24)		5% MCWB	8.6	8.1	8.6	9.8	13.3	15.4	16.8	16.0	15.0	13.3	11.0	9.7	
(25)		10% DB	8.2	8.0	9.3	11.7	14.9	17.6	19.6	18.3	16.2	13.5	10.7	9.2	
(26)		10% MCWB	7.7	7.3	8.0	9.0	12.0	14.2	15.7	15.3	14.3	12.7	10.1	8.8	
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4% WB	10.7	10.5	11.2	13.9	17.3	19.5	20.0	19.9	18.2	15.8	13.1	11.5	
(28)		0.4% MCDB	10.7	11.2	13.5	17.7	20.9	22.9	24.3	23.7	19.9	16.9	13.2	11.5	
(29)		2% WB	9.8	9.2	10.0	11.9	15.1	17.1	18.5	18.0	16.7	14.4	12.0	10.7	
(30)		2% MCDB	10.0	9.7	11.1	15.4	18.3	20.5	22.5	20.8	18.2	14.9	12.1	10.8	
(31)		5% WB	8.7	8.3	9.1	10.6	13.8	15.7	17.3	16.9	15.6	13.6	11.2	9.9	
(32)		5% MCDB	9.0	8.8	10.1	12.6	16.2	18.7	20.6	19.1	16.8	14.1	11.4	10.1	
(33)		10% WB	7.9	7.5	8.3	9.6	12.5	14.7	16.2	16.0	14.7	12.9	10.3	8.9	
(34)		10% MCDB	8.2	8.0	9.2	11.3	14.4	17.1	18.7	17.7	15.7	13.4	10.6	9.2	
(35)	Mean Daily Temperature Range	MDBR	4.4	4.7	5.7	7.0	7.3	7.5	7.5	7.1	6.5	5.4	4.6	4.4	
(36)		5% DB MCDBR	4.9	5.2	7.4	9.6	10.1	10.7	10.7	9.3	8.0	6.0	4.8	4.6	
(37)		5% WB MCWBR	4.9	4.5	5.3	6.3	6.9	7.3	6.5	5.7	5.5	4.5	4.4	4.8	
(38)		5% WB MCDBR	4.9	4.9	6.3	8.2	9.0	9.6	9.5	8.0	7.2	5.4	4.4	4.6	
(39)	Clear-Sky Solar Irradiance	taub	0.315	0.327	0.355	0.369	0.374	0.366	0.365	0.354	0.346	0.336	0.313	0.304	
(40)		taud	2.390	2.420	2.349	2.326	2.341	2.389	2.394	2.445	2.460	2.470	2.441	2.358	
(41)		Ebn at Noon	705	803	841	870	880	889	884	878	845	781	704	650	
(42)		Edh at Noon	62	78	100	114	118	114	111	101	89	73	59	55	
(43)	All-Sky Solar Radiation	RadAvg	0.79	1.52	2.70	4.21	5.13	5.57	5.23	4.36	3.28	1.84	0.98	0.62	
(44)		RadStd	0.07	0.17	0.33	0.42	0.27	0.56	0.44	0.36	0.23	0.15	0.09	0.08	

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (57 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page