

ODIHAM, United Kingdom

WMO: 037610

Lat: 51.2389N

Lon: 0.9450W

Elev: 405

StdP: 14.48

Time Zone: 0.00 (EUW)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	25.2	27.8	20.0	15.2	30.3	22.5	17.2	32.1	34.3	49.1	31.5	49.5	6.1	230	0.623

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	16.2	80.3	64.6	76.5	63.1	73.2	61.7	66.5	76.5	64.8	73.1	63.3	70.4	9.4	170

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
63.0	87.4	69.0	61.6	83.3	67.5	60.3	79.4	66.1	31.2	76.8	29.9	73.1	28.8	70.5	74.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 27.6	24.2	21.4	19.1	85.8	3.3	4.0	16.7	88.7	14.8	91.0	12.9	93.2	10.5	96.1		
(5)			18.5	69.8	3.2	2.0	16.2	71.3	14.3	72.4	12.5	73.5	10.2	75.0		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	50.8	40.3	40.8	44.0	48.2	53.7	59.1	63.0	62.6	57.8	52.2	45.5	41.2	(6)
(7)		DBStd	9.72	5.99	5.79	5.27	5.36	5.31	4.51	4.50	4.32	4.20	5.12	5.62	6.63	(7)
(8)		HDD50	1339	302	259	194	93	22	0	0	0	1	35	154	279	(8)
(9)		HDD65	5268	765	677	652	503	351	185	94	102	218	397	586	738	(9)
(10)		CDD50	1618	1	2	8	40	137	273	404	389	236	104	18	6	(10)
(11)		CDD65	72	0	0	0	0	1	8	33	27	3	0	0	0	(11)
(12)		CDH74	612	0	0	0	2	17	90	275	203	23	2	0	0	(12)
(13)		CDH80	109	0	0	0	0	0	13	51	44	1	0	0	0	(13)
(14)	Wind	WSAvg	10.4	12.3	11.9	11.1	10.0	9.8	9.3	9.1	9.1	9.3	10.4	10.6	11.6	(14)
(15)	Precipitation	PrecAvg	31.5	3.4	2.2	2.5	2.2	2.2	2.0	2.2	2.9	3.1	3.3	3.4	(15)	
(16)		PrecMax	42.2	6.1	7.4	6.5	4.4	5.7	6.0	4.4	4.6	7.4	8.2	8.2	8.1	(16)
(17)		PrecMin	21.9	0.0	0.0	0.1	0.1	0.2	0.2	0.4	0.3	0.3	0.3	0.9	0.6	(17)
(18)		PrecStd	4.2	1.9	1.6	1.4	1.1	1.2	1.4	1.1	1.1	2.0	2.0	1.9	1.7	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	54.0	55.6	62.7	71.8	76.4	81.7	84.8	84.9	77.3	68.1	59.6	56.0	(19)
(20)			MCWB	51.5	50.1	51.7	57.0	61.4	64.7	66.2	66.5	63.6	60.7	56.8	53.2	(20)
(21)		2%	DB	52.6	52.6	57.8	65.3	72.3	76.3	80.7	79.5	72.2	63.7	57.3	54.4	(21)
(22)			MCWB	50.4	49.3	49.5	53.9	59.6	62.8	64.4	65.0	61.8	58.3	54.8	52.2	(22)
(23)		5%	DB	51.0	50.8	54.6	61.0	67.9	72.3	76.8	74.9	68.4	61.6	55.7	53.0	(23)
(24)			MCWB	48.8	47.9	48.7	51.7	57.6	60.8	63.2	62.7	59.6	57.3	53.1	50.8	(24)
(25)		10%	DB	49.2	49.2	52.1	57.5	63.6	68.9	73.0	71.2	65.7	59.9	54.0	51.2	(25)
(26)			MCWB	47.1	46.5	47.5	49.8	55.1	59.3	62.0	61.3	58.5	56.4	51.5	48.9	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	52.5	51.9	53.2	58.5	63.9	67.5	68.7	68.9	65.7	62.1	57.7	54.1	(27)
(28)			MCDWB	53.5	54.2	57.8	68.7	71.7	79.2	80.8	81.3	72.9	66.8	58.9	55.1	(28)
(29)		2%	WB	50.9	50.1	51.3	55.2	61.0	64.4	66.3	66.3	63.5	60.0	55.4	52.8	(29)
(30)			MCDWB	52.2	51.9	55.3	63.5	68.9	72.8	76.9	75.5	69.2	62.5	56.9	54.2	(30)
(31)		5%	WB	49.0	48.5	50.1	52.8	58.6	62.1	64.6	64.5	61.7	58.5	53.7	51.1	(31)
(32)			MCDWB	50.6	50.4	53.4	58.5	66.0	69.7	73.9	71.6	66.2	60.6	55.4	52.8	(32)
(33)		10%	WB	47.4	46.9	48.6	51.0	56.5	60.4	63.0	62.9	60.1	57.1	51.8	49.2	(33)
(34)			MCDWB	49.1	48.9	51.6	56.2	62.7	67.2	70.7	69.3	64.2	59.4	53.7	51.0	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	9.4	10.3	12.9	15.2	15.6	15.8	16.2	15.6	14.7	12.0	10.1	9.1	(35)
(36)			MCDBR	10.0	11.2	16.8	20.6	22.3	22.3	22.9	21.8	18.9	12.8	10.0	8.5	(36)
(37)			MCWBR	9.8	8.9	10.7	11.4	11.5	11.2	10.0	9.7	10.0	8.6	8.7	8.5	(37)
(38)		5% WB	MCDWB	9.9	10.1	14.1	18.3	19.7	19.5	19.6	17.9	15.8	11.1	9.6	9.0	(38)
(39)			MCWBR	9.9	9.0	10.0	10.9	11.2	10.8	9.9	9.2	9.9	8.6	9.0	9.1	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.326	0.341	0.377	0.398	0.402	0.400	0.394	0.386	0.370	0.354	0.328	0.315	(40)	
(41)		taud	2.373	2.381	2.277	2.234	2.265	2.297	2.320	2.361	2.399	2.427	2.418	2.358	(41)	
(42)		Ebn at Noon	217	248	258	266	271	272	271	267	259	239	215	200	(42)	
(43)		Edh at Noon	20	26	34	40	40	40	38	35	30	24	19	17	(43)	
(44)	All-Sky Solar Radiation	RadAvg	260	475	831	1295	1567	1734	1644	1370	1026	591	312	205	(44)	
(45)		RadStd	21	60	111	141	97	172	150	109	83	51	35	24	(45)	

Historical Trends

		Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (81 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page