

LONDON CITY AP, United Kingdom

WMO: 037683

Lat: 51.505N

Lon: 0.055E

Elev: 19

StdP: 14.69

Time Zone: 0.00 (EUW)

Period: 07-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 28.8	(c) 31.7	(d) 22.6	(e) 17.1	(f) 33.9	(g) 24.6	(h) 18.7	(i) 35.2	(j) 27.2	(k) 50.3	(l) 24.8	(m) 50.7	(n) 6.1	(o) 20	(p) 0.556

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	13.8	82.4	65.9	78.7	63.7	75.4	62.7	67.5	78.3	65.7	74.6	64.3	72.4	8.5	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
63.0	86.2	71.1	62.4	84.3	70.4	60.9	79.8	68.8	31.9	78.2	30.5	74.7	29.5	72.5	75.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
22.9	20.4	18.3	26.6	89.6	3.6	4.2	24.0	92.6	21.9	95.1	19.9	97.4	17.3	100.5
			25.4	71.2	3.2	2.1	23.1	72.7	21.3	74.0	19.5	75.2	17.2	76.7
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	53.9	42.7	43.3	46.6	51.7	57.0	62.5	67.1	65.8	61.2	55.4	48.4	44.6
	DBStd	9.99	5.87	5.77	5.51	5.41	5.32	4.90	4.74	4.12	4.17	4.93	5.43	6.37
	HDD50	896	232	196	129	42	7	0	0	0	0	12	92	186
	HDD65	4253	691	609	570	400	251	106	30	37	129	300	498	632
	CDD50	2329	6	8	24	93	225	375	530	490	335	179	44	20
	CDD65	210	0	0	0	1	5	31	95	62	14	2	0	0
	CDH74	1066	0	0	0	12	26	170	518	266	64	10	0	0
	CDH80	233	0	0	0	1	0	32	123	64	12	1	0	0
(14) Wind	WSAvg	9.3	9.8	9.7	9.8	8.8	9.3	9.3	9.2	9.1	8.6	8.5	9.1	10.0
(15) Precipitation	PrecAvg	23.1	2.0	1.3	1.8	1.7	1.9	1.9	1.7	1.9	2.2	2.4	2.2	2.1
	PrecMax	31.5	5.0	3.5	3.9	4.2	3.5	4.2	3.6	4.6	5.7	5.4	5.5	4.4
	PrecMin	17.2	0.4	0.3	0.2	0.4	0.0	0.2	0.4	0.3	0.2	0.1	0.7	0.5
	PrecStd	3.4	1.1	0.7	0.9	0.9	1.0	1.2	0.9	1.1	1.5	1.7	1.2	1.0
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	57.4	59.2	64.6	75.4	77.2	84.2	89.5	87.4	80.8	73.1	62.7	59.3
		MCWB	53.6	52.0	52.9	58.4	63.0	67.3	69.3	68.1	63.7	62.3	58.7	54.7
	2%	DB	55.2	55.6	60.4	68.1	73.4	78.6	82.7	80.5	73.8	66.6	60.7	57.4
		MCWB	51.7	50.0	51.5	55.5	60.6	63.4	65.7	64.6	62.5	59.9	56.4	53.4
	5%	DB	53.4	53.6	57.2	63.0	69.8	75.0	79.1	76.6	70.2	64.4	58.7	55.6
		MCWB	49.7	48.8	50.0	53.1	59.4	62.4	64.0	63.8	61.1	58.8	54.5	52.0
	10%	DB	51.5	51.7	55.1	60.6	66.4	71.6	76.6	73.3	68.1	62.5	56.8	53.8
		MCWB	47.9	47.7	48.9	51.9	56.5	60.4	63.4	62.0	59.6	57.5	52.9	50.1
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	54.3	53.0	54.3	59.8	65.3	69.1	70.0	69.2	67.6	62.8	59.2	55.5
		MCDB	57.5	58.1	61.5	72.4	72.6	82.3	84.4	83.1	76.1	68.6	61.9	58.4
	2%	WB	52.2	51.2	52.5	56.5	62.1	65.6	67.5	66.7	64.6	60.9	56.7	54.3
		MCDB	55.0	54.9	58.2	66.1	70.3	74.4	78.4	77.2	72.1	66.1	59.9	57.3
	5%	WB	50.1	49.8	51.3	54.7	59.9	63.5	65.9	65.0	62.7	59.5	54.7	52.6
		MCDB	52.5	52.8	56.2	62.2	67.6	71.4	75.4	73.0	68.0	63.8	58.0	55.8
	10%	WB	48.3	48.1	49.5	52.6	58.2	61.6	64.3	63.7	61.1	58.2	52.8	50.9
		MCDB	51.2	51.7	54.3	59.1	65.2	69.4	73.6	70.5	66.2	62.0	56.2	54.0
(35) Mean Daily Temperature Range	5% DB	MDBR	7.7	8.6	10.9	13.0	13.2	13.7	13.8	12.6	12.1	9.9	8.1	7.8
		MCDBR	9.1	11.5	15.0	18.3	17.9	18.8	18.9	17.4	15.5	11.8	8.4	8.3
		MCWBR	9.4	7.8	8.5	9.2	8.8	8.8	7.4	6.9	7.2	7.2	7.1	7.8
	5% WB	MCDBR	9.0	9.9	13.7	17.2	15.7	17.4	16.9	14.6	13.0	10.8	8.5	8.3
		MCWBR	9.4	8.0	8.8	9.3	8.7	9.0	7.5	7.2	8.0	7.6	8.0	8.0
(40) Clear-Sky Solar Irradiance	taub		0.333	0.348	0.386	0.407	0.412	0.413	0.409	0.399	0.381	0.364	0.336	0.322
	taud		2.369	2.370	2.260	2.223	2.249	2.273	2.292	2.338	2.387	2.416	2.414	2.356
	Ebn at Noon		213	244	254	263	267	267	266	263	254	235	210	195
	Edh at Noon		20	26	35	40	41	41	39	36	30	24	19	17
(44) All-Sky Solar Radiation	RadAvg		253	462	812	1281	1535	1703	1615	1343	1011	582	303	197
	RadStd		22	66	106	134	105	151	151	106	83	54	35	25

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (79 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page