

LONDON CITY AP, United Kingdom

WMO: 037683

Lat: 51.505N

Lon: 0.055E

Elev: 6

StdP: 101.26

Time Zone: 0.00 (EUW)

Period: 07-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -1.8	(c) -0.2	(d) -5.2	(e) 2.4	(f) 1.1	(g) -4.1	(h) 2.7	(i) 1.8	(j) 12.1	(k) 10.2	(l) 11.1	(m) 10.4	(n) 2.7	(o) 20	(p) 0.556

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 7	(b) 7.7	(c) 28.0	(d) 18.8	(e) 26.0	(f) 17.6	(g) 24.1	(h) 17.1	(i) 19.7	(j) 25.7	(k) 18.7	(l) 23.7	(m) 17.9	(n) 22.4	(o) 3.8	(p) 90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
17.2	12.3	21.7	16.9	12.0	21.4	16.0	11.4	20.4	56.3	25.7	53.2	23.7	50.7	22.5	24.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 10.2	(b) 9.1	(c) 8.2	(e) -3.0	(f) 32.0	(g) 2.0	(h) 2.3	(i) -4.4	(j) 33.7	(k) -5.6	(l) 35.0	(m) -6.7	(n) 36.4	(o) -8.2	(p) 38.1		
(4) 10.2	(5) 9.1	(6) 8.2	(7) -3.7	(8) 21.8	(9) 1.8	(10) 1.2	(11) -4.9	(12) 22.6	(13) -6.0	(14) 23.3	(15) -7.0	(16) 24.0	(17) -8.2	(18) 24.9		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	12.2	6.0	6.3	8.1	10.9	13.9	16.9	19.5	18.8	16.2	13.0	9.1	7.0
	DBStd	5.55	3.26	3.21	3.06	3.00	2.95	2.72	2.63	2.29	2.32	2.74	3.01	3.54
	HDD10.0	498	129	109	72	23	4	0	0	0	0	7	51	103
	HDD18.3	2363	384	338	317	222	139	59	17	21	72	167	277	351
	CDD10.0	1294	3	4	13	52	125	208	294	272	186	99	24	11
	CDD18.3	117	0	0	0	1	3	17	53	34	8	1	0	0
	CDH23.3	592	0	0	0	7	14	94	288	148	36	6	0	0
	CDH26.7	129	0	0	0	1	0	18	68	36	7	1	0	0
Wind	WSAvg	4.1	4.4	4.3	4.4	3.9	4.2	4.2	4.1	4.1	3.9	3.8	4.1	4.4
Precipitation	PrecAvg	586	51	34	46	44	48	47	44	49	55	60	56	53
	PrecMax	801	126	89	98	106	88	107	92	118	146	137	139	113
	PrecMin	437	9	7	4	9	1	6	9	7	4	3	17	12
	PrecStd	86	27	19	22	24	25	30	24	28	39	42	31	25
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	14.1	15.1	18.1	24.1	25.1	29.0	32.0	30.8	27.1	22.8	17.1	15.2
		MCWB	12.0	11.1	11.6	14.7	17.2	19.6	20.7	20.0	17.6	16.8	14.9	12.6
	2%	DB	12.9	13.1	15.8	20.0	23.0	25.9	28.2	26.9	23.2	19.2	15.9	14.1
		MCWB	10.9	10.0	10.8	13.1	15.9	17.4	18.7	18.1	16.9	15.5	13.6	11.9
	5%	DB	11.9	12.0	14.0	17.2	21.0	23.9	26.2	24.8	21.2	18.0	14.8	13.1
		MCWB	9.9	9.3	10.0	11.7	15.2	16.9	17.8	17.7	16.2	14.9	12.5	11.1
	10%	DB	10.8	11.0	12.8	15.9	19.1	22.0	24.8	22.9	20.1	17.0	13.8	12.1
		MCWB	8.8	8.7	9.4	11.1	13.6	15.8	17.4	16.7	15.3	14.2	11.6	10.1
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	12.4	11.6	12.4	15.5	18.5	20.6	21.1	20.7	19.8	17.1	15.1	13.1
		MCDB	14.2	14.5	16.4	22.5	22.5	27.9	29.1	28.4	24.5	20.3	16.6	14.7
	2%	WB	11.2	10.7	11.4	13.6	16.7	18.7	19.7	19.3	18.1	16.0	13.7	12.4
		MCDB	12.8	12.7	14.6	18.9	21.3	23.5	25.8	25.1	22.3	18.9	15.5	14.1
	5%	WB	10.0	9.9	10.7	12.6	15.5	17.5	18.8	18.3	17.1	15.3	12.6	11.5
		MCDB	11.4	11.6	13.5	16.8	19.8	21.9	24.1	22.8	20.0	17.7	14.4	13.2
	10%	WB	9.0	9.0	9.7	11.5	14.5	16.4	17.9	17.6	16.2	14.6	11.6	10.5
		MCDB	10.7	10.9	12.4	15.0	18.5	20.8	23.1	21.4	19.0	16.7	13.4	12.2
Mean Daily Temperature Range	5% DB	MDBR	4.3	4.8	6.1	7.2	7.3	7.6	7.7	7.0	6.7	5.5	4.5	4.3
		MCDBR	5.0	6.4	8.3	10.2	9.9	10.5	10.5	9.7	8.6	6.5	4.7	4.6
		MCWBR	5.2	4.3	4.7	5.1	4.9	4.9	4.1	3.8	4.0	4.0	3.9	4.3
	5% WB	MCDBR	5.0	5.5	7.6	9.6	8.7	9.7	9.4	8.1	7.2	6.0	4.7	4.6
		MCWBR	5.2	4.5	4.9	5.2	4.8	5.0	4.1	4.0	4.4	4.2	4.5	4.5
Clear-Sky Solar Irradiance	taub	0.333	0.348	0.386	0.407	0.412	0.413	0.409	0.399	0.381	0.364	0.336	0.322	
	taud	2.369	2.370	2.260	2.223	2.249	2.273	2.292	2.338	2.387	2.416	2.414	2.356	
	Ebn at Noon	671	768	801	829	842	843	840	829	802	740	663	616	
	Edh at Noon	63	82	109	127	129	128	123	112	96	77	60	55	
All-Sky Solar Radiation	RadAvg	0.80	1.46	2.56	4.04	4.84	5.37	5.09	4.24	3.19	1.84	0.95	0.62	
	RadStd	0.07	0.21	0.34	0.42	0.33	0.47	0.47	0.34	0.26	0.17	0.11	0.08	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (79 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page