

LONDON ST JAMES PARK, United Kingdom

WMO: 037700

Lat: 51.5049N

Lon: 0.1310W

Elev: 16

StdP: 14.69

Time Zone: 0.00 (EUW)

Period: 10-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	29.4	31.4	22.0	16.6	34.8	24.1	18.3	35.1	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	15.4	83.2	65.7	79.3	64.3	76.1	63.0	67.9	78.9	66.1	75.8	64.7	73.2	N/A	N/A

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
63.9	88.9	71.7	62.4	84.4	70.1	61.1	80.6	68.7	32.2	78.4	30.8	76.0	29.7	73.2	75.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
N/A	N/A	N/A	DB	26.4	91.1	2.0	3.1	24.9	93.3	23.8	95.1	22.6	96.8	21.2	99.1	
			WB	25.7	71.9	2.3	2.1	24.0	73.4	22.7	74.6	21.5	75.8	19.8	77.3	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	53.7	42.2	43.1	47.0	51.9	56.9	62.3	66.9	65.1	60.7	55.2	47.7	44.5	(6)
(7)		DBStd	9.93	5.44	5.54	5.46	5.69	5.48	4.82	4.82	4.34	4.46	4.94	5.66	6.09	(7)
(8)		HDD50	921	246	200	121	41	6	0	0	0	0	12	109	186	(8)
(9)		HDD65	4321	708	612	557	393	258	109	33	51	142	304	520	634	(9)
(10)		CDD50	2274	4	8	29	99	221	369	525	467	321	175	39	17	(10)
(11)		CDD65	198	0	0	0	1	8	28	93	53	13	2	0	0	(11)
(12)		CDH74	1237	0	0	0	19	52	203	599	281	71	12	0	0	(12)
(13)		CDH80	294	0	0	0	1	2	45	159	72	13	2	0	0	(13)
(14)	Wind	WSAvg	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(14)
(15)	Precipitation	PrecAvg	23.1	2.0	1.3	1.8	1.7	1.9	1.9	1.7	1.9	2.2	2.4	2.2	2.1	(15)
(16)		PrecMax	31.5	5.0	3.5	3.9	4.2	3.5	4.2	3.6	4.6	5.7	5.4	5.5	4.4	(16)
(17)		PrecMin	17.2	0.4	0.3	0.2	0.4	0.0	0.2	0.4	0.3	0.2	0.1	0.7	0.5	(17)
(18)		PrecStd	3.4	1.1	0.7	0.9	0.9	1.0	1.2	0.9	1.1	1.5	1.7	1.2	1.0	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	55.8	60.5	66.3	76.8	79.0	85.3	89.8	87.5	81.5	73.4	62.2	59.0	(19)
(20)			MCWB	52.8	52.3	53.0	59.0	63.9	67.3	69.9	68.9	64.9	63.0	58.4	54.3	(20)
(21)		2%	DB	54.1	55.5	61.5	70.2	74.7	79.3	84.2	80.9	74.7	67.2	60.1	56.7	(21)
(22)			MCWB	51.1	50.8	51.7	56.6	61.5	64.4	65.9	65.8	62.6	60.0	56.5	53.3	(22)
(23)		5%	DB	52.4	53.0	57.8	64.8	70.4	75.1	80.2	76.3	70.9	64.4	58.3	55.3	(23)
(24)			MCWB	49.4	49.0	50.5	54.6	59.2	62.3	64.9	63.6	61.2	58.4	54.8	52.2	(24)
(25)		10%	DB	50.7	51.1	54.9	60.9	66.5	71.8	76.6	73.0	68.4	62.2	56.1	53.8	(25)
(26)			MCWB	47.7	47.5	48.9	51.8	56.6	60.8	63.4	61.9	59.9	57.3	53.1	50.7	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	53.7	53.3	54.6	60.9	66.0	69.3	70.8	69.7	68.1	63.4	59.3	55.3	(27)
(28)			MCDB	55.3	58.4	62.5	75.1	75.6	83.1	87.2	84.3	75.4	72.6	61.7	57.6	(28)
(29)		2%	WB	52.1	51.3	52.9	57.7	62.7	66.3	67.9	66.9	65.2	61.0	57.3	54.0	(29)
(30)			MCDB	54.0	54.7	59.0	68.6	71.8	74.8	79.5	77.2	72.6	65.6	59.7	56.3	(30)
(31)		5%	WB	49.8	49.9	51.6	55.3	60.4	63.9	66.1	65.3	63.0	59.7	55.3	52.7	(31)
(32)			MCDB	52.0	52.6	57.1	63.4	68.3	72.1	76.8	73.4	68.4	63.4	57.6	55.3	(32)
(33)		10%	WB	48.2	48.2	50.0	53.2	58.4	62.0	64.6	63.8	61.4	58.3	53.3	50.9	(33)
(34)			MCDB	50.6	51.2	55.1	59.8	65.2	70.3	74.4	70.8	66.5	61.5	56.0	53.6	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	8.3	9.1	11.8	14.3	14.8	15.2	15.4	14.6	14.0	11.0	8.9	8.7	(35)
(36)			MCDBR	9.6	11.7	16.5	20.7	20.4	20.9	21.2	19.3	17.6	12.9	9.1	8.2	(36)
(37)			MCWBR	9.2	8.0	9.1	10.3	10.0	9.9	8.3	7.8	8.2	7.5	7.5	7.5	(37)
(38)		5% WB	MCDBR	9.4	10.7	15.0	19.0	18.2	18.7	18.8	16.4	14.3	11.5	8.9	8.3	(38)
(39)			MCWBR	9.5	8.0	9.2	9.8	9.6	10.1	8.6	7.8	8.4	7.8	8.1	8.1	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.332	0.348	0.385	0.406	0.411	0.412	0.408	0.398	0.380	0.363	0.336	0.322	(40)	
(41)		taud	2.367	2.370	2.260	2.221	2.249	2.273	2.292	2.338	2.387	2.416	2.412	2.353	(41)	
(42)		Ebn at Noon	213	244	254	263	267	268	266	263	255	235	210	195	(42)	
(43)		Edh at Noon	20	26	35	40	41	40	39	36	30	24	19	17	(43)	
(44)	All-Sky Solar Radiation	RadAvg	255	463	810	1268	1526	1691	1603	1333	1004	580	305	199	(44)	
(45)		RadStd	22	64	108	138	102	158	153	107	84	53	35	25	(45)	

Historical Trends

		Heating		Cooling			Degree-Days				
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(46)
		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47)	Regional (81 neighbors)	(m)									(47)
		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	

Nomenclature: See separate page